Permit Application for Stationary Sources of Air Pollution New Source Review

CPV Towantic, LLC

September 2014



Prepared for:

CPV Towantic, LLC

50 Braintree Hill Office Park, Suite 300 Braintree, MA 02184

For Submittal to:

Connecticut Department of Energy and Environmental Protection

79 Elm Street Hartford, CT 06106

Prepared by:

Tetra Tech, Inc.

238 Littleton Road, Suite 201B Westford, MA 01886



TABLE OF CONTENTS

Permit Application For Stationary Sources Of Air Pollution	1
Attachment AA – Copy Of Public Notice And Certification Form	AA-1
Attachment A – Executive Summary	A-1
Attachment B – Applicant Background Information	B-1
Attachment C – Site Plan	
Attachment D – Usgs Topographic Quadrangle Map	D-1
Attachment E – Supplemental Application Forms	E-1
Attachment F – Premises Information Form	F-1
Attachment G – Best Available Control Technology Analysis	G-1
Attachment H – Major Modification Determination Form	H-1
Attachment I – Prevention Of Significant Deterioration	I-1
Attachment J – Non-Attainment New Source Review	J-1
Attachment K – Operation And Maintenance Plan	K-1
Attachment L – Ambient Air Quality Analysis	L-1
Attachment M – Applicant Compliance Information	M-1
Attachment N – Marked Up Permit	N-1
Attachment O – Coastal Consistency Review Form	O-1
Attachment P – Copy Of Response to Request For Natural Diversity Database (NDDB) State Listed Speriew Form	
Attachment Q – Conservation or Preservation Restriction Information	
Attachment R – Copy Of Written Environmental Justice Public Participation Plan Approval Letter	
Appendix A – Supporting Emissions Calculations	
Appendix B – Vendor Supplied Emissions Data	
LIST OF TABLES	
Table A-1: Proposed LAER and BACT Emission Rates – Combustion Turbines	A-3
Table E-2: Short-Term Emission Rates for Ancillary Equipment	E-4
Table E-3: Facility-Wide Annual Potential Emissions (tons per year [tpy])	E-5
Table G-1: Combustion Turbine BACT and LAER NO _x Rate Emission Limits	G-4
Table G-2: Auxiliary Boiler BACT and LAER NO _x Rate Emission Limits	G-5
Table G-3: Combustion Turbine Permitted CO, PM, GHG and NH ₃ Emission Rate Limits	G-9
Table G-4: Start-up/Shutdown Emission Rates (lbs/hr)	G-18



Table G-6: Emergency Engine Emission Guarantees	G-21
Table L-1. National Ambient Air Quality Standards	L-5
Table L-2. PSD Regulatory Threshold Evaluations	L-6
Table L-3. SILs, NAAQS, and PSD Increments	L-7
Table L-4. Stack Characteristics	L-8
Table L-5. Load Scenarios and Emission Rates for a General Electric (GE) 7HA.01 Combustion Natural Gas (per unit)	_
Table L-6. Load Scenarios and Emission Rates for a GE 7HA.01 Combustion Turbine Firing ULSD	(per unit)L-9
Table L-7. Startup Condition Stack Parameters for Each Fuel	L-10
Table L-8. Stack Parameters for Ancillary Equipment	L-10
Table L-9. Ambient Air Quality Monitoring Data and Selected Background Concentrations	L-13
Table L-10. Maximum Predicted Impact Concentrations	L-15
Table L-11. Cumulative NAAQS Compliance Assessment	L-17
Table L-12. Cumulative PSD Increment Compliance Assessment	L-17
Table L-13. Vegetation Impact Screening Thresholds Assessment	L-19
LIST OF FIGURES	
Figure G-1: CO ₂ Pipelines in the United States	G-15
Figure L-1: Wind Rose Plot	L-ii
Figure L-2: Urban/Rural Land Use Determination Map	L-ii

ACRONYMS/ABBREVIATIONS

Acronyms/Abbreviations	Definition
°F	degrees Fahrenheit
%	percent
ACC	air cooled condenser
BACT	Best Available Control Technology
Bhp	brake horsepower
Btu/kW-hr	British thermal unit per kilowatt-hour
CARB	California Air Resources Board
CCS	carbon capture and storage
CFR	Code of Federal Regulations
CO	carbon monoxide
CO ₂	carbon dioxide
CO _{2e}	carbon dioxide equivalent
CPV Towantic	CPV Towantic, LLC
CT#1	combustion turbine #1
CT#2	combustion turbine #2
CTG	combustion turbine generator
DB#1	duct burner #1
DB#2	duct burner #2
DEEP	Connecticut Department of Energy and Environmental Protection
EAB	Environmental Appeals Board
GE	General Electric
GHG	greenhouse gases
g/bhp	grams per break-horse power hour
g/kW-hr	grams per kilowatt-hour
gr S/100 scf	grains of sulfur per 100 standard cubic feet
H ₂ SO ₄	sulfuric acid
HAP	hazardous air pollutant
HFCs	hydrofluorocarbons
HHV	higher heating value
HRSG	heat recovery steam generator
IGCC	Integrated Gasification Combined-Cycle
ISO	International Organization for Standardization
kW	kilowatt



Acronyms/Abbreviations	Definition
LAER	Lowest Achievable Emission Rate
lb/MMBtu	pound per million British thermal units
lb/MW-hr	pound per megawatt-hour
lb/hr	pounds per hour
lbs	pounds
LLO	Low Load Operation
LNB	low NO _x burner
MACT	Maximum Achievable Control Technology
MASC	Maximum Allowable Stack Concentration
MMBtu	million British thermal units
MMBtu/hr	million British thermal units per hour
MW	megawatt
MWh	megawatt-hour
NETL	National Energy Technology Laboratory
NESHAP	National Emission Standard for Hazardous Air Pollutants
NH ₃	ammonia
NO _x	nitrogen oxides
NNSR	Non-Attainment New Source Review
NSPS	New Source Performance Standards
NSR	New Source Review
NSR Manual	New Source Review Workshop Manual: Prevention of Significant Deterioration and Nonattainment Area Permitting
O ₂	oxygen
O ₃	ozone
Pb	lead
PM	particulate matter
PM _{2.5}	particulate matter with an aerodynamic diameter of 2.5 micrometers or less
PM ₁₀	particulate matter with an aerodynamic diameter of 10 micrometers or less
ppm	parts per million
ppmvd	parts per million volume dry
the Project	A nominal 805-megawatt combined-cycle generating facility located on Woodruff Hill Road in Oxford, Connecticut
PSD	Prevention of Significant Deterioration
RACT	Reasonably Achievable Control Technology
RBLC	RACT/BACT/LAER Clearinghouse



Acronyms/Abbreviations	Definition
SCR	selective catalytic reduction
SF ₆	sulfur hexafluoride
SIP	State Implementation Plan
SO ₂	sulfur dioxide
SO ₃	sulfur trioxide
STG	steam turbine generator
SU/SD	start-up/shutdown
tpy	tons per year
ULSD	ultra low sulfur distillate
USEPA	United States Environmental Protection Agency
USGS	United States Geologic Survey
VOC	volatile organic compound

PERMIT APPLICATION FOR STATIONARY SOURCES OF AIR POLLUTION

Provided on the following pages is a completed Permit Application for Stationary Sources of Air Pollution Form (DEEP-NSR-APP-200).





CPPU USE ONLY
App No.:
Doc No.:
Check No.:
Program: Air Engineering

Permit Application for Stationary Sources of Air Pollution - New Source Review

Please complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-200) to ensure the proper handling of your application. Print or type unless otherwise noted. You must submit the permit application fee(s), a copy of the published notice of permit application, and the completed <u>Certification of Notice Form</u> (DEEP-APP-005A) along with this form.

Note: If you are applying for a *minor modification* or a *revision* to an existing New Source Review permit, please use the appropriate <u>Minor Modification Application Form</u> (DEEP–NSR-APP-200MM) or <u>Revision Application Form</u> (DEEP-NSR-APP-200R).

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Applicant Name:	CPV Towantic, LLC	Town Where Site is Located:	Oxford, CT
-----------------	-------------------	-----------------------------	------------

Part I: Application and Source Type Summary

More than one permit may be applied for using one application form if the sources are located at the same premises. Complete and attach the appropriate supplemental application forms for each unit included in this application package. *Each* unit or process line requires a separate permit.

Unit	Source Type	Application Type	Existing Permit or Registration No. (If applicable)	DEEP Use Only	
No.		Application Type		Application No.	Permit No.
CT1	Combustion Turbine #1	New Non-Minor Mod			
CT2	Combustion Turbine #2	New Non-Minor Mod			
DB1	Duct Burner #1	New Non-Minor Mod			
DB2	Duct Burner #2	New Non-Minor Mod			
AB	Auxliary Boiler	New Non-Minor Mod			
EG	Emergency Generator Engine	New Non-Minor Mod			

□ Check here if additional sheets are necessary to identify all sources that are included in this application package, and label and attach them to this sheet.

the HRSGs with natural gas fired duct burners will be conducted.	Brief Description of Project:	Combined cycle combusiton turbine electric power generating plant firing natural gas as the primary fuel with ultra low sulfur diesel fuel as backup. Supplemental firing of the HRSGs with natural gas fired duct burners will be conducted.
--	-------------------------------	---



	CPPU USE ONLY
,	App No.:
[Doc No.:
(Check No.:
	Program: Air Engineering

Permit Application for Stationary Sources of Air Pollution - New Source Review

Please complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-200) to ensure the proper handling of your application. Print or type unless otherwise noted. You must submit the permit application fee(s), a copy of the published notice of permit application, and the completed <u>Certification of Notice Form</u> (DEEP-APP-005A) along with this form.

Note: If you are applying for a *minor modification* or a *revision* to an existing New Source Review permit, please use the appropriate <u>Minor Modification Application Form</u> (DEEP–NSR-APP-200MM) or <u>Revision Application Form</u> (DEEP-NSR-APP-200R).

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Applicant Name:	CPV Towantic, LLC	Town Where Site is Located:	Oxford, CT
-----------------	-------------------	-----------------------------	------------

Part I: Application and Source Type Summary

More than one permit may be applied for using one application form if the sources are located at the same premises. Complete and attach the appropriate supplemental application forms for each unit included in this application package. *Each* unit or process line requires a separate permit.

Unit	Source Type	Application Type	Existing Permit or Registration No. (If applicable)	DEEP Use Only	
No.	Course Type			Application No.	Permit No.
FP	Emergency Fire Pump Engine	New Non-Minor Mod			
		☐ New ☐ Non-Minor Mod			
		☐ New ☐ Non-Minor Mod			
		☐ New ☐ Non-Minor Mod			
		☐ New ☐ Non-Minor Mod			
		☐ New ☐ Non-Minor Mod			

Check here if additional sheets are necessary to identify all sources that are included in this
application package, and label and attach them to this sheet.

Brief Description of Project: Brief Description of Project: Combined cycle combusiton turbine electric power generating plant firing natural gas the primary fuel with ultra low sulfur diesel fuel as backup. Supplemental firing of the HRSGs with natural gas fired duct burners will be conducted.	
--	--

1b of 10

Part II: Fee & Public Notice Information

1. FEE INFORMATION		
A permit application fee of \$940.00 [#195] is to be submitted with this application	Number of Sources from Part I	7
form for each source listed in Part II. For municipalities, as defined in CGS section 22a-170, a 50% reduction applies. The application will not be processed until the application fee is received. The fee shall be paid by check or money order to the	Application Fee per source	\$940
Department of Energy and Environmental Protection or by such other method as the commissioner may allow. The permit fee(s) will be calculated subject to the provisions of RCSA section 22a-174-26 and billed at a later date.	Municipality	⊠ No □ Yes, 50% disc.
	Total Enclosed	\$6,580
2. PUBLIC NOTICE INFORMATION		
The public notice of application must be published <i>prior</i> to submitting an application, as required in CGS section 22a-6g. A copy of the public notice of application and the completed <u>Certification of Notice Form</u> (DEEP-APP-005A) must be included as Attachment AA to this application. Your application will <i>not</i> be processed if Attachment AA is not included.	Date of Publication	08/15/2014

Part III: Applicant Information

- *If an applicant is a corporation, limited liability company, limited partnership, limited liability partnership, or a statutory trust, it must be registered with the Secretary of State. If applicable, the applicant's name shall be stated exactly as it is registered with the Secretary of State. Please note, for those entities registered with the Secretary of State, the registered name will be the name used by DEEP. This information can be accessed at the Secretary of State's database (CONCORD). (www.concord-sots.ct.gov/CONCORD/index.jsp)
- If an applicant is an individual, provide the legal name (include suffix) in the following format: First Name; Middle Initial; Last Name; Suffix (Jr, Sr., II, III, etc.).
- If there are any changes or corrections to your company/facility or individual mailing or billing address or contact information, please complete and submit the Request to Change Company/Individual Information to the address indicated on the form. If there is a change in name of the entity holding a DEEP license or a change in ownership, contact the Office of Planning and Program Development (OPPD) at 860-424-3003. For any other changes you must contact the specific program from which you hold a current DEEP license.

1.	APPLICANT INFORMATION					
	Applicant Name	CPV Towantic, LLC c/o Co Check at least one: The applicant must be eith	quipment owner		☐ equipment ope	rator
	Mailing Address	50 Braintree Hill Office Par	k, Suite 300			
	City/Town	Braintree	State	MA	Zip Code	02184
	Business Phone No.	(781) 848-3611	Extension N	о.		
	Contact Person	Andrew Bazinet				
	Title	Director of Development				
		abazinet@cpv.com				
	Email	By providing this e-mail address DEEP, at this electronic address your security settings to be sure notify DEEP if your e-mail addre	s, concerning the you can receive	subject a	pplication. Please reme	ember to check

Part III: Applicant Information (continued)

			business entity federal agency	☐ municipali☐ state ager	-	☐ individu	al
	Applicant Type	entity:	Business Type	☐ corporation☐ limited part☐ statutory tru	nership \square	limited liability of limited liability pother:	· ·
	, ppinoant Typo	a business	Secretary of the State business ID No.	0606312 Check here the Secretary of		ness is NOT regi ce.	stered with
		l į	This information can be (www.concord-sots.ct.	accessed at the S gov/CONCORD/in	ecretary of Standex.jsp)	te's database (CO	NCORD).
	Applicant's interest in property at which the proposed activity is to be located		site owner easement holder Other:	option hold	der	lessee	
	Are there co-applicants?	☐ If "Y	Yes es", attach additional s	⊠ No heet(s) with the r	equired infor	mation as above).
	Did the Applicant attend a Pre- Application Meeting or an Application Review Meeting with DEEP air staff? (check all that apply)	Who	No Yes, Pre-Application Mobilean Yes, Application Review	Air v Meeting: Da	Staff Name(g: 05/07/2014 s): Jim Grillo, Kid g: 08/13/2014 s): Jim Grillo, Kid	
2.	BILLING CONTACT (If different than	the a	applicant)				
	Name						
	Mailing Address						
	City/Town			State		Zip Code	
	Contact Person						
	Business Phone No.			Extension N	o.		
	Email						
3.	PRIMARY CONTACT FOR DEPARTM	/ENT	AL CORRESPONDEN	CE AND INQUIF	RIES (if diffe	rent than the ap	oplicant)
	Name						
	Title						
	Company/Individual Name						
	Mailing Address						
	City/Town			State		Zip Code	
	Business Phone No.			Extension N	o.		
	Email						
	By providing this e-mail address you are ag subject application. Please remember to ch						

please notify DEEP if your e-mail address changes.

4 of 10

Part III: Applicant Information (continued)

4.	EQUIPMENT OWNER OR EQUIPMENT operator)	NT OPERATOR (Only comple	ete if applicant	is no	ot both e	equipment ow	ner and
	Name	Check one:	ent owner			equipment ope	rator
	Title						
	Company/Individual Name						
	Mailing Address						
	City/Town		State			Zip Code	
	Business Phone No.		Extension No				
	Email						
5.	ENGINEER(s) OR CONSULTANT(s) (If different than the applicant)	EMPLOYED OR RETAINED T	O ASSIST IN P	REP	ARING 1	THIS APPLICA	TION
	Name	Steven J. Babcock, P.E.					
	Title	Consulting Engineer					
	Company/Individual Name	Tetra Tech, Inc.					
	Mailing Address	160 Federal St., 3 rd Floor					
	City/Town	Boston	State	МА		Zip Code	02110
	Business Phone No.	617-443-7500	Extension No		7533		
	Email	steven.j.babcock@tetratec	h.com				
	Service Provided	Preparation of forms and s	upplemental in	form	ation		

 $[\]hfill \Box$ Check here if additional sheets are necessary. Label and attach them to this sheet.

Part IV: Site Information

1.	SITE NAME AND LOCATION						
	Name of Site	CPV Towantic, LL	.c				
	Street Address or Location Description	16 Woodruff Hill F	Road				
	City/Town	Oxford		State	СТ	Zip Code	06478
2.	INDIAN LANDS						
	Is or will the premises be located on fede Indian lands?	rally recognized	☐ Yes	\boxtimes	No		
3.	COASTAL MANAGEMENT ACT CONSIST	ENCY					
	Is or will the activity which is the subject application be located within the coastal delineated on DEEP approved coastal boundary is availawww.lisrc.uconn.edu. (Click on the upper tabe column labeled "Maps", then "Coastal Conne local town hall or on the "Coastal Boundary DEEP Maps and Publications (860-424-355)	boundary as undary maps? able at or left hand ecticut") or the Map" available at	☐ Yes		No		
	If yes, Is this an application for a new per modification of an existing permit where footprint of the subject activity is modified?		applicat delineat you mus	nd if the ion is loc ed on DE st comple Form (D	ated with EEP apprete	ubmit a <u>Coasta</u>	
	If the activity is not located within the coathe activity which is the subject of this apwithin the coastal area? (see town list in the	plication located	☐ Yes	\boxtimes	No		
4.	NATURAL DIVERSITY DATA BASE (NDD	B) - ENDANGERED	AND TH	REATEN	IED SPE	CIES	
	According to the most current "State and Species and Natural Communities Map", which is the subject of this application lo area identified as a habitat for endangere special concern species?	is the activity cated within an	∑ Yes Date of	_	No		
	Is this an application for a new permit or an existing permit where the physical foo subject activity is modified? For more information visit the DEEP website http://www.ct.gov/deep/nddbrequest or call to 424-3011.	etprint of the	identifie special for NDD APP-00 Please and ma applica The CT	nd if the d as a haconcern so B State 17) to the note ND y requirent. NDDB re	abitat for especies, of Listed Sp address so DB revieus additional esponse I	ecies Review is specified on the way was generally to the contract of the cont	nreatened or submit a Request Form (DEEP-te form. akes 4 to 6 weeks tation from the

Part IV: Site Information (continued)

5.	AQUIFER PROTECTION AREAS	
	Is the site located within a mapped Level A or Level B Aquifer Protection Area, as defined in CGS section 22a-354a through 22a-354bb?	☐ Yes
	If yes, check if Level A or Level B If Level A, are any of the <u>regulated activities</u> , as defined in RCSA section 22a-354i-1(34), conducted on this site?	☐ Level A or ☐ Level B ☐ Yes ☐ No If yes , and your business is not already registered with the Aquifer Protection Program, contact the local aquifer protection agent or DEEP to take appropriate actions.
		For more information on the Aquifer Protection Area Program visit the DEEP website at www.ct.gov/deep/aquiferprotection or contact the program at 860-424-3020.
6.	CONSERVATION OR PRESERVATION RESTRICTION	
	Is the premises subject to a conservation or preservation restriction?	☐ Yes
		If yes, proof of written notice of this application to the holder of such restriction or a letter from the holder of such restriction verifying that this application is in compliance with the terms of the restriction, must be submitted as Attachment Q.
7.	ENVIRONMENTAL JUSTICE COMMUNITY	
	Does the site include an applicable facility which is located within an Environmental Justice Community, as defined in the Environmental Justice Public Participation Guidelines (Guidelines)?	☐ Yes ☐ No If yes, and this application is for a new or expanded permit, <i>prior</i> to submitting this application prepare an <i>Environmental Justice Public Participation Plan</i> (DEEP-EJ-PLAN-001) in accordance with the Guidelines and submit such plan to: Environmental Justice Program Office of the Commissioner Department of Energy and Environmental Protection
		79 Elm Street Hartford, CT 06106-5127 Once you have received written approval for your Environmental Justice Public Participation Plan from the
		DEEP, submit this completed application with a copy of the Plan approval as Attachment R.
8.	AIR QUALITY STATUS	
	Indicate the air quality status of the area in which the premises is or will be located.	Ozone: ☐ Severe Non-Attainment ☐ Serious Non-Attainment
	(Check all that apply. See instructions for the air quality attainment status of Connecticut municipalities).	PM _{2.5} : ☐ Non-Attainment ☑ Attainment

Part IV: Site Information (continued)

9.	MAJOR STATIONARY SOURCE	
	Is the premises a major stationary source?	⊠ Yes □ No
		If yes, indicate the pollutant(s), if any, for which the premises exceeds the major stationary source threshold: ☑ PM ☑ PM₁0 ☑ PM₂.5 ☐ SO₂ ☑ NOx ☑ CO ☐ VOC ☐ Pb ☑ CO₂ ☐ HAPs
	Is the premises operating under the GPLPE?	☐ Yes No
		If yes, indicate the Approval of Registration No.: -GPLPE
10.	. SIC CODES	Primary 4911 Secondary Other Other
11.	NAICS CODE	221112

Part V: Attachments

Check the applicable box below for each attachment being submitted with this application form. When submitting any supporting documents, please label the documents as indicated in this Part (e.g., Attachment A, etc.) and be sure to include the applicant's name as indicated on this application form.

All referenced forms may be accessed electronically, in **WORD** and PDF versions, on the <u>Air Emissions Permits</u> webpage.

Attachment	Attachm	ent Name	Form No.	Required?	Attached
AA		Public Notice of Application and Original tion of Notice Form	DEEP-APP-005A	Required	\boxtimes
А	Executiv	e Summary	DEEP-NSR-APP-222	Required	
В	Applicar	t Background Information	DEEP-APP-008	Required	
С	Site Plai	n - An 8 ½" X 11" copy of the Site Plan	No DEEP form	Required	
D		dap - An 8 ½" X 11" copy of the relevant portion of Quadrangle Map indicating the exact location of the ty or site	No DEEP form	Required	
	Supplen	nental Application Forms			
	٦.	E201: Manufacturing or Processing Operations	DEEP-NSR-APP-201	If Applicable	
	the	E202: Fuel Burning Equipment	DEEP-NSR-APP-202	If Applicable	\boxtimes
	priate forms for the in Part II of this form.	E203: Incinerators or Landfill Flares	DEEP-NSR-APP-203	If Applicable	
	form t II o	E204: Volatile Liquid Storage	DEEP-NSR-APP-204	If Applicable	
Е	iate I Par	E205: Surface Coating or Printing Operations	DEEP-NSR-APP-205	If Applicable	
	appropriate forms for the listed in Part II of this fon	E206: Metal Plating or Surface Treatment Operations	DEEP-NSR-APP-206	If Applicable	
	the a	E207: Metal Cleaning Degreasers	DEEP-NSR-APP-207	If Applicable	
	Select the appropropropers by Source types listed	E208: Concrete, Asphalt Concrete, Mineral Processing or Other Similar Equipment	DEEP-NSR-APP-208	If Applicable	
	SC	E209: Site Remediation Equipment	DEEP-NSR-APP-209	If Applicable	

Part V: Attachments (continued)

Attachment	Attachment Name	Form No.	Required?	Attached
	E210: Air Pollution Control Equipment	DEEP-NSR-APP-210	If Applicable	\boxtimes
Е	E211: Stack and Building Parameters	DEEP-NSR-APP-211	Required	\boxtimes
	E212: Unit Emissions	DEEP-NSR-APP-212	Required	\boxtimes
F	Premises Information Form	DEEP-NSR-APP-217	Required	\boxtimes
G	BACT Determination Form	DEEP-NSR-APP-214	Required	\boxtimes
Н	Major Modification Determination Form	DEEP-NSR-APP-213	If Applicable	
ı	Prevention of Significant Deterioration (PSD) of Air Quality Form	DEEP-NSR-APP-216	If Applicable	\boxtimes
J	Non-Attainment Review Form	DEEP-NSR-APP-215	If Applicable	
К	Operation and Maintenance Plan	No DEEP form	If Applicable	
L	Ambient Air Quality Analysis	No DEEP form	If Applicable	\boxtimes
М	Applicant Compliance Information	DEEP-APP-002	Required	\boxtimes
N	Marked Up Permit - For non-minor modifications, attach a marked up copy of the current NSR permit noting proposed changes		If Applicable	\boxtimes
0	Coastal Consistency Review Form	DEEP-APP-004	If Applicable	
Р	Copy of Response to Request for Natural Diversity Data Base (NDDB) State Listed Species Review Form and additional documentation		If Applicable	\boxtimes
Q	Conservation or Preservation Restriction Information	No DEEP form	If Applicable	
R	Copy of the Written Environmental Justice Public Participation Plan Approval Letter		If Applicable	

Part VI: Applicant Certification

The authorized representative and the individual(s) responsible for actually preparing the application must sign this part. An application will be considered insufficient unless all required signatures are provided.

"I have personally examined and am familiar with the information submitted in this document and all attachments thereto, and I certify that based on reasonable investigation, including my inquiry of those individuals responsible for obtaining the information, the submitted information is true, accurate and complete to the best of my knowledge and belief. I understand that any false statement made in the submitted information may be punishable as a criminal offense under section 22a-175 of the Connecticut General Statutes, under section 53a-157b of the Connecticut General Statutes, and in accordance with any applicable statute. I certify that this application is on complete and accurate forms as prescribed by the commissioner without alteration of the text. I certify that I have complied with all notice requirements as listed in section 22a-6g of the General Statutes." APPLICANT: Date Signature of Applicant 915/14 CPV Towantic, LLC, By: Gary A. Lambert Name of Applicant (print or type) President, CPV Towantic Holding Company, LLC acting solely in its capacity as Managing Member of Title (if applicable) PREPARER: Signature of Preparer Date yun Kesock 9/5/14 Lynn Gresock Name of Preparer (print or type) Title (if applicable) Vice President

Submit one hardcopy or electronic copy (in the form of a CD) of the completed application package. If submitting an electronic copy, DEEP-NSR-APP-200 and DEEP-APP-005A must be submitted as a hardcopy with original signatures along with the CD and such form should also be scanned and included in the CD. The Department of Energy and Environmental Protection (DEEP) encourages all applicants to submit their application electronically.

Submit completed form to:

CENTRAL PERMIT PROCESSING UNIT DEPARTMENT OF ENERGY AND ENVIRONMENTAL PROTECTION 79 ELM STREET HARTFORD, CONNECTICUT 06106-5127

Note: A Permit Application Transmittal Form (DEEP-APP-001) is not required with this application form.

Please remember to publish notice of the permit application **prior** to submitting your completed application to DEEP. Send a copy of the published notice to the chief elected official of the municipality in which the regulated activity is proposed and provide DEEP with a copy of the published notice, as described in the instructions, attached to a completed <u>Certification of Notice Form</u> (DEEP-APP-005A) as Attachment AA to this application.

ATTACHMENT AA - COPY OF PUBLIC NOTICE AND CERTIFICATION FORM

Provided on the following page is a copy of the Public Notice of Application and Original Certification of Notice Form (DEEP-APP-005A). The provided copy of the Public Notice of Application is a photocopy of the notice published in the New Haven Register on Friday, August 15, 2014.





Connecticut Department of Energy & Environmental Protection

Certification of Notice Form - Notice of Application

DEEP USE ONLY

Division
Application No.

CPV Toward	tic, LLC	, certify that
(Name of Ap	oplicant)	
he attached notice represents a true copy of the r	notice that appeared in	The New Haven Register
		(Name of Newspaper)
on Friday, August 15, 2014		
(Date)		
also certify that I have provided a copy of said no	otice to the chief elected r	nunicipal official listed below as
required by section 22a-6g CGS.		
George R. Temple	First Sele	otman - Town of Oxford
Name of Official	Title of O	ficial
	7110 01 0	norui
	7100 07 0	notar
S.B. Church Memorial Town Hall, 486 Oxford Road	77100	notar
	, mo d. 5.	notar
	7110 0. 5	, and a
	СТ	06478-1298
Address Oxford		06478-1298
Address Oxford	СТ	
Address Oxford	СТ	06478-1298
Address Oxford	CT State	06478-1298 Zip Code
Address Oxford	CT State	06478-1298 Zip Code
City/Town	CT State	06478-1298
Address Oxford	CT State	06478-1298 Zip Code
Address Oxford City/Town	CT State Date President, CPV acting solely in	O6478-1298 Zip Code Towantic Holding Company, LLC its capacity as Managing Member of
Oxford City/Town Signature of Applicant	CT State 2 Date President, CPV	O6478-1298 Zip Code Towantic Holding Company, LLC its capacity as Managing Member of

AFFIDAVIT OF PUBLICATION

New Haven Register

STATE OF CONNECTICUT

County of New Haven	
I, Christopher Gilson of New Haven, C am a Sales Representative of the New	Connecticut, being duly sworn, do depose and say that I were Haven Register, and that on
the following date	to wit. 8/15/14
there was published in the regular daily	y edition of the said newspaper an
advertisement,	

And that the newspaper extracts hereto annexed were clipped from each of the above-named issues of said newspaper.

Burlon Colelle

My commission expires <u>July 31, 2019</u>

Copy of Notice of Permit Application

Printed in the New Haven Register on Friday, August 15, 2014

Notice of Permit Application

Town: Oxford

Notice is hereby given that CPV Towantic, LLC (the "applicant") of 50 Braintree Hill Office Park, Suite 300, Braintree, MA 02184 will submit to the Department of Energy and Environmental Protection an application under section 22a-174 of the Connecticut General Statutes for a permit to construct, install, enlarge or establish an air contaminant source and to operate such air contaminant source and to operate such air contaminant source regulated under the federal Clean Air Act.

Specifically, the applicant proposes to construct and operate an 805 megawatt combined cycle electric generating facility. The proposed activity will take place at 16 Woodruff Hill Road, Oxford, Connecticut.

The proposed activity will potentially affect air resources.

Interested persons may obtain copies of the application from Lynn Gresock, Tetra Tech, 238 Littleton Road, Suite 201B, Westford, MA 01886 and 978-203-5352.

The application will be available for inspection at the Department of Energy and Environmental Protection, Bureau of Air Management, Engineering & Enforcement Division, 79 Elm Street, 5th floor, Hartford, CT 06106-5127, 860-424-4152, from 8:30 to 4:30 Monday through Friday. Please call in advance to schedule review of the application.

ATTACHMENT A – EXECUTIVE SUMMARY

Provided on the following pages is a completed Executive Summary form (DEEP-NSR-APP-222). Prior to the form, a brief project description is provided outlining:

- A description of the proposed regulated activities;
- A synopsis of the environmental and engineering analyses, include a summary or cross-reference to appropriate data analyses;
- A conclusion of any environmental impacts and the proposed timeline for construction; and
- Information describing the changes in project configuration from the project's current approval (issued on June 1, 2010).



I. LOCATION OF THE FACILITY

CPV Towantic, LLC (CPV Towantic) proposes to construct and operate a nominal 805-megawatt (MW) combined-cycle electric generating facility (the Project) located on Woodruff Hill Road in Oxford, Connecticut. The proposed Project will be constructed on a 26-acre parcel at a greenfield location in Oxford, Connecticut. The site is located in New Haven County, approximately 5 miles southwest of Waterbury, Connecticut and approximately 0.5 mile to the east of the Waterbury-Oxford Airport. The exact location of the facility and equipment can be found in Attachments C and D of this application.

II. PROJECT DESCRIPTION

CPV Towantic proposes to construct and operate a nominal 805-MW combined-cycle electric generating facility located on Woodruff Hill Road in Oxford, Connecticut. The proposed Project is an update of the currently authorized Project previously approved by the Connecticut Department of Energy and Environmental Protection (DEEP), Town-Permit Number #144-0011 dated June 1, 2010. The changes from the approved project include the following:

- Update in combustion turbine to a General Electric (GE) Model 7HA.01;
- · Addition of supplemental natural gas firing of the heat recover steam generators (HRSG); and
- Incorporation of layout adjustments of equipment on the site.

This application has been prepared to include all the information requested for a new project.

The proposed Project will consist of two GE Model 7HA.01 combustion turbine-generators (CTGs) exhausting into two supplementary-fired HRSGs. The CTGs will be fired primarily with natural gas, with limited use of ultra-low sulfur distillate (ULSD) oil as backup fuel. The steam produced from the HRSGs will power one reheat tandem compound double flow steam turbine generator (STG). The STG exhaust steam will be condensed via a multi-fan air cooled condenser (ACC). The balance of the Project will include an auxiliary boiler, emergency generator engine, emergency fire pump engine, and an aqueous ammonia (NH₃) storage tank.

The Project will have potential emissions above the Prevention of Significant Deterioration (PSD) major source threshold for nitrogen oxides (NO_x), carbon monoxide (CO), particulate matter ($PM/PM_{10}/PM_{2.5}$), and greenhouse gases (PMSR). The Project will have potential PMSR0, emissions above the non-attainment new source review (PMSR1) threshold. The Project will also have potential emissions of sulfuric acid mist (PMSR2) and volatile organic compounds (PMSR3) above their respective PMSR3 significant emissions thresholds. Therefore, the Project will be subject to PMSR4, and PMSR5. The Project will be subject to PMSR5 permitting for PMSR6.

CPV Towantic is applying for a New Source Review (NSR) permit from the DEEP for the Project. The NSR permit is required under Section 22a-174-3a of the Connecticut regulations. This document, along with the accompanying DEEP forms and other appended materials, is the PSD and NNSR application for the Project.

Emissions of sulfur dioxide (SO₂) will be below its PSD significant emissions rate threshold but above the DEEP de minimis permitting threshold based on potential emissions as specified in Section 22a-174-3a(a)(1)(D). Emissions of NH₃ will also be above the DEEP de minimis permitting threshold. As a result, SO₂ and NH₃ emissions will trigger DEEP Best Available Control Technology (BACT) requirements under Section 22a-174-3a(j)(1)(C); this application also addresses the permitting requirements for these pollutants.

Emissions of NO_x are subject to NNSR and the Project is required to implement Lowest Achievable Emission Rate (LAER) controls for this pollutant. The Project will install selective catalytic reduction (SCR) to control NO_x emissions. The proposed LAER emission rates for the CTGs are provided in Table A-1. The basis for the NO_x LAER emission rate is provided in Attachment J, including a completed Non-Attainment Review of Air Quality form (DEEP-NSR-APP-215).



Table A-1: Proposed LAER and BACT Emission Rates - Combustion Turbines

Pollutant	Natural Gas Firing (without duct firing)	Natural Gas Firing (with duct firing)	ULSD Firing
NO _x	2.0 ppmvd @15% oxygen (O ₂)	2.0 ppmvd @15% O ₂	5.0 ppmvd @15% O ₂
VOC	1.0 ppmvd @15% O ₂	2.0 ppmvd @15% O ₂	2.0 ppmvd @15% O ₂
CO	0.9 ppmvd @15% O ₂	1.7 ppmvd @15% O ₂	2.0 ppmvd @15% O ₂
PM/PM ₁₀ /PM _{2.5}	0.0041 lb/MMBtu (at full load)	0.0081 lb/MMBtu (at full load)	0.020 lb/MMBtu (at full load)
H ₂ SO ₄	0.00115 lb/MMBtu	0.00117 lb/MMBtu	0.00125 lb/MMBtu
GHG	7,220 Btu/kW-hr (net, at ISO full load, no supplemental firing, natural gas firing) 2,656,018 tons per rolling 12-month period		
SO ₂	0.0015 lb/MMBtu (≤0.5 gr S/100 scf)	0.0015 lb/MMBtu (≤0.5 gr S/100 scf)	0.0015 lb/MMBtu (≤15 ppmw S)
NH ₃	5.0 ppmvd @15% O ₂	5.0 ppmvd @15% O ₂	5.0 ppmvd @15% O ₂

ppmvd = parts per million volume dry basis

lb/MMBtu = pounds per million British thermal units of fuel fired

Btu/kW-hr = British thermal units of fuel fired per kilowatt of electricity generated

lb/MW-hr = pounds per megawatt hour of electricity generated

gr S/100 scf = grains of sulfur per 100 standard cubic feet of natural gas

ppmw = parts per million weight

Emissions of CO, PM/PM₁₀/PM_{2.5}, H₂SO₄, GHGs, NO_x, and VOC are subject to PSD and the Project is required to implement BACT controls for these pollutants. Emissions of NO_x will satisfy BACT requirements by meeting LAER requirements as discussed above. The Project will install an oxidation catalyst to control CO and VOC emissions. The Project will fire natural gas as the primary fuel, with limited use of ULSD to limit H₂SO₄ emissions. Advanced combined-cycle combustion turbine technology will be used to satisfy BACT for GHG emissions. The proposed PSD BACT emission rates for the CGTs are provided below in Table A-1. The basis for the PSD BACT emission rates are provided in Attachment I, including a completed PSD of Air Quality form (DEEP-NSR-APP-216).

A dispersion modeling analysis was conducted in accordance with DEEP and United States Environmental Protection Agency (USEPA) regulations, standards and guidance. The proposed LAER and BACT emission rates were used in the analysis. The analysis shows that the predicted ambient concentrations are in compliance with all applicable ambient air quality standards. A complete discussion of the dispersion modeling analysis and results is provided in Attachment L.

The Project is proposed to begin construction in December 2015 with commencement of operation in 2018.



Attachment A: Executive Summary

Applicant Name: CPV Towantic, LLC

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-200) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this attachment to provide information for the project which is the subject of this application package.

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Part I: Location of Facility or Activity

Woodruff Hill Road, Oxford, CT

Part II: Application Table of Contents

Provide a Table of Contents of the application which includes the *Permit Application for Stationary Sources of Air Pollution Form* (DEEP-NSR-APP-200), and a list of all supplemental application forms, plans, drawings, reports, studies, or other supporting documentation which are attached as part of the application, along with the corresponding attachment label and the number of pages (e.g., Executive Summary - Attachment A - 4 pgs.).

Permit Application for Stationary Sources of Air Pollution (DEEP-BSR-APP-200) - 17 pages

Attachment AA: Copy of Public Notice and Certification Form (DEEP-APP-005A) - 3 pages

Attachment A: Executive Summary (DEEP-NSR-APP-222) - 6 pages

Attachment B: Applicant Background Information (DEEP-APP-008) - 6 pages

Attachment C: Site Plan - 3 pages

Attachment D: United States Geological Survey (USGS) Topographic Quadrangle Map - 2 pages

Attachment E202: Fuel Burning Equipment (DEEP-NSR-APP-202) - 37 pages

Attachment E210: Air Pollution Control Equipment (DEEP-NSR-APP-210) - 10 pages

Attachment E211: Stack and Building Parameters (DEEP-NSR-APP-211) - 3 pages

Attachment E212: Unit Emissions (DEEP-NSR-APP-212) - 10 pages

Attachment F: Premises Information Form (DEEP-NSR-APP-217) - 11 pages

Attachment G: BACT Determination Form (DEEP-NSR-APP-214) - 159 pages

Attachment G1: Background Search - Existing BACT Determination (DEEP-NSR-APP-214b) - 125 pages

Attachment G2: Cost/Economic Impact Analysis (DEEP-NSR-APP-214c) - 20 pages

Attachment G3: Summary of Best Available Control Technology Review (DEEP-NSR-APP-214d) - 1 page

Attachment H: Major Modification Determination Form - Not Required

Attachment I: Prevention of Significant Deterioration (PSD) of Air Quality Form (DEEP-NSR-APP-216) - 7 pages

Attachment J: Non-Attainment Review Form (DEEP-NSR-APP-215) - 18 pages

Attachment K: Operation and Maintenance Plan - Not Applicable

Attachment L: Ambient Air Quality Analysis - 58 pages

Attachment M: Applicant Compliance Information Form - 3 pages

Attachment N: Marked Up Permit - 21 pages

Attachment O: Coastal Consistency Review Form - Not Required

Attachment P: Copy of Response to Request for Natural Diversity Database (NDDB) State Listed Species

Review Form - 5 pages

Attachment Q: Conservation of Preservation Restriction Information - Not Required

Attachment R: Copy of Written Environmental Justice Public Participation Plan Approval Letter - Not

Required

Appendix A: Emissions Calcuations - 18 pages

Appendix B: Manufacturer Information - 84 pages		
☐ Check here if additional sheets are necessary, and label and attach them to this sheet.		

Attachment A: Executive Summary (continued)

Part III: Project Description Provide a brief project description which includes:			
a description of the proposed regulated activities;			
a synopsis of the environmental and engineering analyses;			
summaries of data analysis;			
a conclusion of any environmental impacts and the proposed timeline for construction; and			
• for a renewal or modification provide a list of changes in circumstances or information on which the			
previous permit or registration was based.			
See previous attached text			

Bureau of Air Management DEEP-NSR-APP-222

☐ Check here if additional sheets are necessary, and label and attach them to this sheet.

ATTACHMENT B - APPLICANT BACKGROUND INFORMATION

Provided on the following pages is a completed Applicant Background Information form (DEEP-APP-008).





Connecticut Department of Energy & Environmental Protection

Applicant Background Information

Check the box by the entity which best describes the applicant and complete the requested information. You must choose one of the following: corporation, limited liability company, limited partnership, general partnership, voluntary association and individual or business type.

Check the box if additional sheets are necessary. If so, label and attach additional sheet(s required information.	s) to this sheet with the
Parent Corporation	
Name:	
Mailing Address:	
City/Town: State: Zip C	Code:
Business Phone: ext.:	
Contact Person: Phone:	ext.
E-mail:	
2. Subsidiary Corporation:	
Name:	
Mailing Address:	
City/Town: State: Zip C	Code:
Business Phone: ext.:	
Contact Person: Phone:	ext.
E-mail:	
3. Directors:	
Name:	
Mailing Address:	
City/Town: State: Zip C	Code:
Business Phone: ext.:	
E-mail:	
4. Officers:	
Name:	
Mailing Address:	
	Code:
Business Phone: ext.:	-
E-mail:	

\boxtimes	Limited Liability Company				
	Check the box if additional sheets are necessary. If so, la sheet with the required information.	bel and attach a	dditional sheet(s) to this		
1.	List each member.				
	Name: CPV Towantic, LLC				
	Mailing Address: 50 Braintree Hill Office Park, Suite 300				
	City/Town: Braintree	State: MA	Zip Code: 02184		
	Business Phone: (781) 848-3611	ext.:			
	E-mail:				
	Name:				
	Mailing Address:				
	City/Town:	State:	Zip Code:		
	Business Phone:	ext.:			
	E-mail:				
	Name:				
	Mailing Address:				
	City/Town:	State:	Zip Code:		
	Business Phone:	ext.:			
	E-mail:				
List any manager(s) who, through the articles of organization, are vested the management of th business, property and affairs of the limited liability company.					
	Name: Gary Lambert				
	Mailing Address: 50 Braintree Hill Office Park, Suite 300				
	City/Town: Braintree	State: MA	Zip Code: 02184		
	Business Phone: (781) 848-2786	ext.:			
	E-mail: ppodurgiel@cpv.com				
	Name:				
	Mailing Address:				
	City/Town:	State:	Zip Code:		
	Business Phone:	ext.:			
	E-mail:				
	Name:				
	Mailing Address:				
	City/Town:	State:	Zip Code:		
	Business Phone:	ext.:	-		
	E-mail:				

	Limited Partnership		
	Check the box if additional sheets are sheet with the required information.	necessary. If so, label and attach	additional sheet(s) to this
1.	General Partners:		
	Name:		
	Mailing Address:		
	City/Town:	State:	Zip Code:
	Business Phone:	ext.:	
	Contact Person:	Phone:	ext.
	E-mail:		
	Name:		
	Mailing Address:		
	City/Town:	State:	Zip Code:
	Business Phone:	ext.:	
	Contact Person:	Phone:	ext.
	E-mail:		
	Name:		
	Mailing Address:		
	City/Town:	State:	Zip Code:
	Business Phone:	ext.:	
	Contact Person:	Phone:	ext.
	E-mail:		
2.	Limited Partners:		
	Name:		
	Mailing Address:		
	City/Town:	State:	Zip Code:
	Business Phone:	ext.:	
	Contact Person:	Phone:	ext.
	E-mail:		
	Name:		
	Mailing Address:		
	City/Town:	State:	Zip Code:
	Business Phone:	ext.:	
	Contact Person:	Phone:	ext.
	E-mail:		

	General Partnership		
	Check the box if additional sheets are necess sheet with the required information.	sary. If so, label and attach	additional sheet(s) to this
1.	General Partners:		
	Name:		
	Mailing Address:		
	City/Town:	State:	Zip Code:
	Business Phone:	ext.:	
	Contact Person:	Phone:	ext.
	E-mail:		
	Name:		
	Mailing Address:		
	City/Town:	State:	Zip Code:
	Business Phone:	ext.:	
	Contact Person:	Phone:	ext.
	E-mail:		
	Name:		
	Mailing Address:		
	City/Town:	State:	Zip Code:
	Business Phone:	ext.:	
	Contact Person:	Phone:	ext.
	E-mail:		
	Name:		
	Mailing Address:		
	City/Town:	State:	Zip Code:
	Business Phone:	ext.:	
	Contact Person:	Phone:	ext.
	E-mail:		
	Name:		
	Mailing Address:		
	City/Town:	State:	Zip Code:
	Business Phone:	ext.:	
	Contact Person:	Phone:	ext.
	E-mail:		

	Voluntary Association		
	Check box if additional sheets are necessary. If with the required information.	so, label and attach ad	ditional sheet(s) to this sheet
1.	List authorized persons of association or list all members of association.		
	Name:		
	Mailing Address:		
	City/Town:	State:	Zip Code:
	Business Phone:	ext.:	
	E-mail:		
	Name:		
	Mailing Address:		
	City/Town:	State:	Zip Code:
	Business Phone:	ext.:	
	E-mail:		
	Name:		
	Mailing Address:		
	City/Town:	State:	Zip Code:
	Business Phone:	ext.:	
	E-mail:		
	Name:		
	Mailing Address:		
	City/Town:	State:	Zip Code:
	Business Phone:	ext.:	
	E-mail:		
	Individual or Other Business Type		
<u> </u>	Check the box, if additional sheets are necessar	rv If so, label and attac	h additional sheet(s) to this
	sheet with the required information.	y. 11 00, 1000 0.10 0.10	Tradational onsol(e, 15 time
1.	Name:		
	Mailing Address:		
	City/Town:	State:	Zip Code:
	Business Phone:	ext.:	
	E-mail:		
2.	State other names by which the applicant is known, including business names.		
	Name:		


ATTACHMENT C - SITE PLAN


Provided on the following page is an 8½" x 11" drawing to scale showing the location of the Project. Additional plans and drawings are provided such that the following requested information is provided:


- The north meridian arrow and the scale shown as a bar scale;
- The exact location of the stacks from which the sources will exhaust;
- The latitude and longitude of the stacks;
- A boundary lines of the property and measurements (identified by use of drawing scales);
- The horizontal distance from the stack base to the nearest property line (identified by use of scales);
- The top view of all buildings or structures, indicating actual dimensions;
- The location of all stacks on the property; and
- The final grade elevation (i.e., height) of all structures on the property.

Due to the amount of detail in these drawings, an 11" x 17" version is also provided.










ATTACHMENT D - USGS TOPOGRAPHIC QUADRANGLE MAP

Provided on the following page is an 8½" x 11" figure of the relevant portion of a United States Geological Survey (USGS) Quadrangle Map, at a scale of 1:24,000, including the names of the quadrangles. The figure shows the exact location of the Project site and the proposed activities, including an outline of the premises boundary.





ATTACHMENT E - SUPPLEMENTAL APPLICATION FORMS

The following supplemental attachment forms are provided, unless indicated as "Not Applicable":

- Attachment E202: Fuel Burning Equipment:
 - Auxiliary Boiler (AB)
 - Attachment E202-A: Flow Diagram
 - Attachment E202-B: Manufacturer Information (See Appendix B)
 - Attachment E202-C: Emissions Profile (Not Applicable)
 - Combustion Turbine #1 (CT#1)
 - Attachment E202-A: Flow Diagram
 - Attachment E202-B: Manufacturer Information (See Appendix B)
 - Attachment E202-C: Emissions Profile (See Appendix A)
 - Combustion Turbine #2 (CT#2)
 - Attachment E202-A: Flow Diagram
 - Attachment E202-B: Manufacturer Information (See Appendix B)
 - Attachment E202-C: Emissions Profile (See Appendix A)
 - Duct Burner for CT#1 (DB#1)
 - Attachment E202-A: Flow Diagram
 - Attachment E202-B: Manufacturer Information (Information is not available)
 - Attachment E202-C: Emissions Profile (Not Applicable)
 - Duct Burner for CT#2 (DB#2)
 - Attachment E202-A: Flow Diagram
 - Attachment E202-B: Manufacturer Information (Information is not available)
 - Attachment E202-C: Emissions Profile (Not Applicable)
 - Emergency Generator Engine (EG)
 - Attachment E202-A: Flow Diagram
 - Attachment E202-B: Manufacturer Information (See Appendix B)
 - Attachment E202-C: Emissions Profile (Not Applicable)
 - Emergency Fire Pump Engine (FP)
 - Attachment E202-A: Flow Diagram
 - Attachment E202-B: Manufacturer Information (See Appendix B)
 - Attachment E202-C: Emissions Profile (Not Applicable)



- Attachment E210: Air Pollution Control Equipment (DEEP-NSR-APP-210)
 - Attachment E210(SCR1) Manufacturer Information (Information was not available)
 - Attachment E210(OC1)* Manufacturer Information (Information was not available)
 - Attachment E210(SCR2) Manufacturer Information (Information was not available)
 - Attachment E210(OC2) Manufacturer Information (Information was not available)
- Attachment E211: Stack and Building Parameters (DEEP-NSR-APP-211)
 - Attachment E211-A: Plot Plan (See Attachment C)
- Attachment E212: Unit Emissions (DEEP-NSR-APP-212)
 - o AB
- Attachment E212-A: Sample Calculations (See Appendix A)
- Attachment E212-B: Completed CT Maximum Allowable Stack Concentration (MASC) spreadsheet (See Appendix A)
- Attachment E212-C: Completed Carbon Dioxide Equivalent (CO_{2e}) Calculator Spreadsheet (See Appendix A)
- o CT#1 / DB#1
 - Attachment E212-A: Sample Calculations (See Appendix A)
 - Attachment E212-B: Completed CTMASC spreadsheet (See Appendix A)
 - Attachment E212-C: Completed CO_{2e} Calculator Spreadsheet (See Appendix A)
- o CT#2 / DB#2
 - Attachment E212-A: Sample Calculations (See Appendix A)
 - Attachment E212-B: Completed CT MASC spreadsheet (See Appendix A)
 - Attachment E212-C: Completed CO_{2e} Calculator Spreadsheet (See Appendix A)
- o EG
 - Attachment E212-A: Sample Calculations (See Appendix A)
 - Attachment E212-B: Completed CTMASC spreadsheet (See Appendix A)
 - Attachment E212-C: Completed CO_{2e} Calculator Spreadsheet (See Appendix A)
- o FP
- Attachment E212-A: Sample Calculations (See Appendix A)
- Attachment E212-B: Completed CTMASC spreadsheet (See Appendix A)
- Attachment E212-C: Completed CO_{2e} Calculator Spreadsheet (See Appendix A)

Prior to the forms is a discussion of the emission sources, the procedures used to calculate potential emissions, and operating restrictions taken to limit potential emissions.

^{*}OC = Oxidation Catalyst





POTENTIAL EMISSIONS METHODOLOGY

This section presents short-term and long-term potential emissions from each emission source for the Project. CPV Towantic proposes to use dry low- NO_x combustion and SCR to minimize NO_x emissions from the CTGs. Combustion controls and an oxidation catalyst will be used to minimize CO and VOC emissions from the CTGs. $PM/PM_{10}/PM_{2.5}$, SO_2 , and H_2SO_4 will be limited through the use of natural gas as the primary fuel for the CTGs with limited firing of ULSD as backup fuel. The duct burners and auxiliary boiler will be fired solely with natural gas. ULSD will be used for the emergency generator and fire pump engines. Attachment G of this application contains a control technology analysis to demonstrate that these controls meet applicable LAER and BACT requirements. Appendix A of this application contains detailed emission calculations and Appendix B contains equipment specifications and vendor performance data for the proposed emission sources.

EMISSION SOURCES

The emission sources for the Project will include the following:

- Two combined-cycle electric power generation units, each consisting of a GE Model 7HA.01 CTG with an
 associated HRSG. Each HRSG will be equipped with duct burners for supplemental firing. Steam from
 both HRSGs will be sent to a common STG. Each unit will be equipped with dry low-NO_x combustors,
 SCR for NO_x control, and an oxidation catalyst for control of CO and VOC;
- One natural gas-fired auxiliary boiler rated at 92.4 million British thermal units per hour (MMBtu/hr), equipped with ultra low-NO_x burners (Cleaver Brooks "Nebraska" D-type boiler or equivalent);
- One emergency diesel generator engine rated at 1,500 kilowatt (kW) (standby rating), firing ULSD oil (Caterpillar 3512C or equivalent);
- One emergency diesel fire pump engine rated at approximately 315 kW, firing ULSD (Clarke JW6H-UFADJ0 or equivalent); and
- Fugitive emissions of GHGs from onsite electrical circuit breakers and natural gas handling equipment.

The Project will utilize an ACC for condenser cooling and there will be no emissions from this equipment. The Project will also include miscellaneous insignificant sources such as a ULSD storage tank, aqueous ammonia storage tank and lubricant oil storage tanks.

SHORT-TERM EMISSIONS

Combustion Turbine and Duct Burners

Short-term potential emission rates for each combined-cycle unit, including the CTG and associated duct burner, are presented in Table E-1. The pound per hour (lb/hr) rates shown are based on 100% load operation at -14.2 degrees Fahrenheit (°F) with duct burner firing, and represent the worst-case operating scenario. Potential emission rates are presented in: ppmvd at 15% O_2 ; lb/MMBtu on a high heating value (HHV) basis; and lb/hr. SO_2 emissions are based on a maximum natural gas sulfur content of 0.5 gr S/100 scf.



Table E-1: Maximum Short-Term Emission Rates for Combustion Turbines and Duct Burners (per unit)

	Natural Gas Firing			UL		
Pollutant	ppmvd (15% O ₂)	lb/MMBtu	lb/hr	ppmvd (15% O ₂)	lb/MMBtu	lb/hr
NO _x , all conditions	2.0	0.0074	26.8	5.0	0.0194	52.0
CO, unfired	0.9	0.0020	5.3	2.0	0.0047	12.7
CO, fired	1.7	0.0038	13.8	N/A	N/A	N/A
VOC, unfired	1.0	0.0013	3.4	2.0	0.0027	6.2
VOC, fired	2.0	0.0026	8.8	N/A	N/A	N/A
SO ₂ , all conditions	N/A	0.0015	6.2	N/A	0.0015	4.9
PM/PM ₁₀ /PM _{2.5} , unfired ^a	N/A	0.0041	9.7	N/A	0.020	42.6
PM/PM ₁₀ /PM _{2.5} , fired ^a	N/A	0.0081	20.4	N/A	N/A	N/A
H ₂ SO ₄ , all conditions	N/A	0.0012	4.0	N/A	0.0013	3.2
NH ₃ , all conditions	5.0	0.0068	24.7	5.0	0.0072	19.2

^a PM/PM₁₀/PM_{2.5} lb/MMBtu emission rates are at full operating load.

Ancillary Equipment

Short-term potential emission rates for the auxiliary boiler and the emergency engines are presented in Table E-2. Potential emission rates are presented in lb/MMBtu; grams per kilowatt-hour (g/kWh) or grams/brake horsepower (g/bhp), as appropriate; and in lb/hr.

Table E-2: Short-Term Emission Rates for Ancillary Equipment

	Auxiliary	Boiler	Emergency Generator		Fire Pump	
Pollutant	lb/MMBtu	lb/hr	g/bhp	lb/hr	g/kWh	lb/hr
NO _x	0.011	1.01	4.08	19.84	3.8	2.64
СО	0.037	3.42	0.44	2.14	0.9	0.63
VOC	0.0041	0.38	0.11	0.53	0.1	0.07
SO ₂	0.0015	0.14	0.0015 lb/MMBtu	0.02	0.0015 lb/MMBtu	0.004
PM/ PM ₁₀ / PM _{2.5}	0.007	0.65	0.03	0.15	0.13	0.09
H ₂ SO ₄	0.00011	0.011	0.00011 lb/MMBtu	0.002	0.00011 lb/MMBtu	0.0003

Annual Emissions

The proposed potential annual emissions from the Project are summarized in Table E-3. Potential annual emissions are based on 8,760 operating hours for each combustion turbine along with the following assumptions:

- Combustion turbines operating for 3,790 hours per year at 100% load, operating at 59°F, firing gas without duct firing;
- Combustion turbines operating for 4,250 hours per year at 100% load, operating at 59°F, firing gas with duct firing;
- Combustion turbines operating for 720 hours per year at 100% load, operating at 59°F, firing ULSD;
- The auxiliary boiler, operating 4,000 hours per year at 100% load; and
- The emergency generator and fire pump engines each operating 300 hours per year at 100% load.



60

0.00004

2.8E-07

N/A

0.003

2,678,612^b

25.3

0.034

155.3

11.6

Unit 1 Unit 2 Auxiliary **Emergency Facility Fire Pump Pollutant** (CTG & HRSG) (CTG & HRSG) **Boiler** Generator Total NO_x^a 94.7 94.7 2.02 2.98 0.40 194.7 0.09 64.5 64.5 6.83 0.32 136.2 VOCa 24.5 24.5 0.75 0.08 0.01 49.9 19.7 19.7 0.28 0.003 0.001 39.7 PM/PM₁₀/PM_{2.5} 76.7 76.7 0.02 0.01 1.29 154.7

21,627

0.02

9.1E-05

N/A

0.35

354

0.0002

1.7E-06

N/A

0.01

Table E-3: Facility-Wide Annual Potential Emissions (tons per year [tpy])

Total HAPS

GHGs (as CO₂e)

COa

 SO_2

 H_2SO_4

 NH_3

Lead (Pb)

1,328,009

12.7

1.7E-02

77.7

5.60

1,328,009

12.7

1.7E-02

77.7

5.60

The combustion turbines have higher mass emission rates of NO_x, CO, and VOC during start-up and shutdown (SU/SD) than during steady-state operation. The impact of increased emissions during SU/SD was evaluated to determine their impact on potential emissions for the Project. Start-ups for combined-cycle systems are generally classified as cold, warm, and hot depending upon the length of time the unit has been off-line prior to start-up. The length of start-ups will vary with the type of start-up and equipment temperatures. However, the GE 7HA.01 combustion turbines can reach full load from initial start-up in no more than one hour for all start types.

The maximum number of starts per year per turbine was determined based upon turbine vendor recommendations and projected operation in the competitive power marketplace. The increase in emissions per type of start was quantified using emissions and operating data provided by GE. The increase in emissions for each type of start was then compared to the reduction in emissions associated with the turbine downtime preceding each type of SU/SD event. Any increase in SU/SD emissions for each type of start was added to the potential steady state emissions. This potential to emit approach represents the worst-case maximum potential to emit for the Project. Each start type was evaluated with a shutdown, as a start-up cannot occur without a prior shutdown. Based upon this analysis, the incremental increase in emissions from a hot start was the worst case and, therefore, it was assumed that the Project would have 200 hot starts and 50 cold starts per year. The incremental increase in potential emissions due to SU/SD is as follows:

NO_x: 0 tpy per turbine

CO: 29.5 tpy per turbine

VOC: 6.3 tpy per turbine

SU/SD emissions calculations are provided in detail in Appendix A.



^a Includes incremental emissions due to start-up and shutdown.

^b Includes 554 tpy of fugitive GHG emissions from circuit breakers and natural gas handling.

Hazardous Air Pollutant Emissions

Potential annual hazardous air pollutant (HAP) emissions are presented in detail in Appendix A. The operating scenarios described above were applied when calculating potential HAP emissions. Total HAP emissions from the Project are estimated to be 11.6 tpy, with a maximum potential emission for any single HAP (formaldehyde) of 2.7 tpy.



Applicant Name: CPV Towantic, LLC		
Unit No.: AB		DEEP USE ONLY
Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-202) to ensure the proper handling of your application. Print or type unless otherwise noted.	App. No.:	

Note: Certain external combustion units may be operated pursuant to RCSA section 22a-174-3b or -3c in lieu of a permit to construct and operate pursuant to RCSA section 22a-174-3a.

Complete a separate form for each fuel burning source.

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Part I: General

Type of Unit (check one)	☑ Boiler☐ IC Engine☐ Duct Burner	☐ Heater/Furnace☐ Turbine☐ Other (specify):	
Manufacturer and Model Number	CB-Nebraska NB-300D-70 (or equivalent)		
Construction Date			
Manufacture Date			
Is this unit subject to Title 40 CFR Part 60, NSPS?	☐ No Yes, Subpart(s) Dc		
Is this unit subject to Title 40 CFR Part 63, MACT?	☐ No ☑ Yes, Subpart(s) JJJJJJ		
Maximum Design Heat Input	92.4 MMBtu/hr		
Typical Heat Input	92.4 MMBtu/hr		
Maximum Operating Schedule	24 hours/day	4,000 hours/year	
	Space Heat:	%	
Percentage of Annual Use in Each Category	Process Heat:	100 %	
	Power:	%	

Fuel Type	% Sulfur by weight	Higher Heating Value (BTU)	Maximum Hourly Firing Rate	Maximum Annual Fuel Usage	Units (gal or ft³)
Natural Gas	0.0016	1,028	89,900	359,600,000	ft3

Burner Manufacturer and Model Number	CB-NATCOM (or equivalent)
Number of Burners	1
Burner Maximum Rated Capacity (per burner)	92.4 MMBtu/hr
Firing Type and Method Information (Choose a	Il that apply)
Oil/Gas Fired Unit	☐ Tangentially Fired ☐ Horizontally Opposed (normal) Fired ☐ Other (specify):
Pulverized Coal Fired Unit	 □ Dry Bottom □ Wall Fired □ Horizontally Fired □ Other (specify):
Coal/Wood Fired Stoker Unit	☐ Overfeed ☐ Underfeed ☐ Spreader ☐ Hand Fed ☐ IGCC (Integrated Gasification Combined Cycle) ☐ Other (specify):
Coal/Wood Fired Fluidized Bed Combustor	☐ Circulating Bed ☐ Bubbling Bed ☐ Cyclone Furnace ☐ Other (specify):
Other Coal/Wood Fired Unit	☐ Suspension Firing ☐ Dutch Oven/Fuel Cell Oven ☐ Over Fire Air ☐ Other (specify):

Part IV: Internal Combustion (IC) Unit Information (IC Engine or Turbine)

art IV. Internal Combustion (IC) Only information (IC Engine of Turbine)				
IC Engine Information				
IC Engine Operation (check one)	☐ Emergency Only	☐ Emergency/Non-Emergency		
IC Engine Ignition (check one)	Compression	☐ Spark		
IC Engine Type (check one)	☐ 4-Stroke Rich Burn (4SRB) ☐ 4-Stroke Lean Burn (4SLB) ☐ 2-Stroke Lean Burn (2SLB)			
IC Engine Brake Horsepower	HP			
IC Engine Power Output	MW			
Turbine Information	•			
Turbine Operation (check one)	☐ Emergency Only	☐ Emergency/Non-Emergency		
Turbine Type (check one)	☐ Simple Cycle	☐ Combined Cycle		
Turbine Power Output	MW			
Part V: Combustion Controls Information (Check all that apply)				
		☐ Fly Ash Reinjection☐ Reburn		

Type of Combustion Control(s) or Modifications(s)	 □ Low NOx Burners □ Flue Gas Recirculation □ Selective Catalytic Reduction □ Coal Reburn □ Gas Reburn □ Lean Burn □ Rich Burn □ Low Excess Air □ Other (specify): 	☐ Fly Ash Reinjection ☐ Reburn ☐ Selective Non-Catalytic Reduction ☐ Oxidation Catalyst ☐ 3-way Catalyst ☐ Over Fire Air ☐ Biased Burner Firing ☐ Burners Out of Service ☐ None
---	---	---

Part VI: Attachments

Please check the attachments being submitted as verification that all applicable attachments have been submitted with this application form. When submitting such documents, please label the documents as indicated in this Part (e.g., Attachment E202-A, etc.) and be sure to include the applicant's name.

	Process Information and Flow Diagram – Submit a process flow diagram indicating all related equipment, air pollution control equipment and stacks, as applicable. Identify all materials entering and leaving each such device indicating quantities and parameters relevant to the proper operation of the device. Indicate all monitoring devices and controls. REQUIRED
☐ Attachment E202-B:	Manufacturer Information - Submit copies of the manufacturer specification sheets for the unit, the air pollution control equipment and the monitoring systems. REQUIRED
☐ Attachment E202-C:	Turbine Emissions Profiles - Submit copies of manufacturer's emissions profile data for steady state and transient operation of the turbine. IF APPLICABLE

Applicant Name: CPV Towantic, LLC	
Unit No.: CT1	DEEP USE ONLY
Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-202) to ensure the proper handling of your application. Print or type unless otherwise noted.	App. No.:

Note: Certain external combustion units may be operated pursuant to RCSA section 22a-174-3b or -3c in lieu of a permit to construct and operate pursuant to RCSA section 22a-174-3a.

Complete a separate form for each fuel burning source.

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Part I: General

Type of Unit (check one)	☐ Boiler ☐ IC Engine ☐ Duct Burner	☐ Heater/Furnace☑ Turbine☐ Other (specify):	
Manufacturer and Model Number	GE 7HA01		
Construction Date			
Manufacture Date			
Is this unit subject to Title 40 CFR Part 60, NSPS?	☐ No ☑ Yes, Subpart(s) KKKK		
Is this unit subject to Title 40 CFR Part 63, MACT?	☐ No ☐ Yes, Subpart(s) YYYY (stayed indefinitely)		
Maximum Design Heat Input	2,526 @ -14.2F MMBtu/hr		
Typical Heat Input	2,426 @ ISO conditi	ons MMBtu/hr	
Maximum Operating Schedule	24 hours/day	8760 hours/year	
	Space Heat:	%	
Percentage of Annual Use in Each Category	Process Heat:	%	
	Power:	100%	

Fuel Type	% Sulfur by weight	Higher Heating Value (BTU)	Maximum Hourly Firing Rate	Maximum Annual Fuel Usage	Units (gal or ft ³)
Natural Gas	0.0016	1,028	2.46E06	2.15E10	ft3
ULSD	0.0015	138,000	18,290	1.3E7	gal

Burner Manufacturer and Model Number		
Number of Burners		
Burner Maximum Rated Capacity (per burner)	MMBtu/hr	
Firing Type and Method Information (Choose a	all that apply)	
Oil/Gas Fired Unit	☐ Tangentially Fired ☐ Horizontally Opposed (normal) Fired ☐ Other (specify):	
Pulverized Coal Fired Unit	☐ Dry Bottom ☐ Wall Fired ☐ Horizontally Fired ☐ Other (specify):	☐ Wet Bottom☐ Tangentially Fired☐ Vertically Fired
Coal/Wood Fired Stoker Unit	☐ Overfeed ☐ Spreader ☐ IGCC (Integrated Gas	☐ Underfeed ☐ Hand Fed sification Combined Cycle)
Coal/Wood Fired Fluidized Bed Combustor	☐ Circulating Bed ☐ Cyclone Furnace ☐ Other (specify):	☐ Bubbling Bed
Other Coal/Wood Fired Unit	☐ Suspension Firing ☐ Dutch Oven/Fuel Cel ☐ Over Fire Air ☐ Other (specify):	l Oven

Part IV: Internal Combustion (IC) Unit Information (IC Engine or Turbine)

IC Engine Information	
IC Engine Operation (check one)	☐ Emergency Only ☐ Emergency/Non-Emergency
IC Engine Ignition (check one)	☐ Compression ☐ Spark
IC Engine Type (check one)	☐ 4-Stroke Rich Burn (4SRB) ☐ 4-Stroke Lean Burn (4SLB) ☐ 2-Stroke Lean Burn (2SLB)
IC Engine Brake Horsepower	HP
IC Engine Power Output	MW
Turbine Information	
Turbine Operation (check one)	☐ Emergency Only ☐ Emergency/Non-Emergency
Turbine Type (check one)	☐ Simple Cycle ☐ Combined Cycle
Turbine Power Output	262 @ ISO conditions MW

Part V: Combustion Controls Information (Check all that apply)

Type of Combustion Control(s) or Modifications(s)	□ Low NOx Burners □ Flue Gas Recirculation □ Selective Catalytic Reduction □ Coal Reburn □ Gas Reburn □ Lean Burn □ Rich Burn □ Low Excess Air □ Other (specify):	☐ Fly Ash Reinjection ☐ Reburn ☐ Selective Non-Catalytic Reduction ☑ Oxidation Catalyst ☐ 3-way Catalyst ☐ Over Fire Air ☐ Biased Burner Firing ☐ Burners Out of Service ☐ None
--	---	---

Part VI: Attachments

Please check the attachments being submitted as verification that all applicable attachments have been submitted with this application form. When submitting such documents, please label the documents as indicated in this Part (e.g., Attachment E202-A, etc.) and be sure to include the applicant's name.

⊠ Attachment E202-A:	Process Information and Flow Diagram – Submit a process flow diagram indicating all related equipment, air pollution control equipment and stacks, as applicable. Identify all materials entering and leaving each such device indicating quantities and parameters relevant to the proper operation of the device. Indicate all monitoring devices and controls. REQUIRED
☐ Attachment E202-B:	Manufacturer Information - Submit copies of the manufacturer specification sheets for the unit, the air pollution control equipment and the monitoring systems. REQUIRED
	Turbine Emissions Profiles - Submit copies of manufacturer's emissions profile data for steady state and transient operation of the turbine. IF APPLICABLE

Applicant Name: CPV Towantic, LLC		
Unit No.: CT2		DEEP USE ONLY
Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-202) to ensure the proper handling of your application. Print or type unless otherwise noted.	App. No.:	

Note: Certain external combustion units may be operated pursuant to RCSA section 22a-174-3b or -3c in lieu of a permit to construct and operate pursuant to RCSA section 22a-174-3a.

Complete a separate form for each fuel burning source.

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Part I: General

Type of Unit (check one)	☐ Boiler ☐ IC Engine ☐ Duct Burner	☐ Heater/Furnace☑ Turbine☐ Other (specify):	
Manufacturer and Model Number	GE 7HA01	GE 7HA01	
Construction Date			
Manufacture Date			
Is this unit subject to Title 40 CFR Part 60, NSPS?	☐ No ☐ Yes, Subpart(s) KKKK		
Is this unit subject to Title 40 CFR Part 63, MACT?	☐ No ☐ Yes, Subpart(s) YYYY (stayed indefinitely)		
Maximum Design Heat Input	2,526 @ -14.2F MMBtu/hr		
Typical Heat Input	2,426 @ ISO conditions MMBtu/hr		
Maximum Operating Schedule	24 hours/day 8760 hours/year		
	Space Heat:	%	
Percentage of Annual Use in Each Category	Process Heat:	%	
	Power:	100%	

Fuel Type	% Sulfur by weight	Higher Heating Value (BTU)	Maximum Hourly Firing Rate	Maximum Annual Fuel Usage	Units (gal or ft ³)
Natural Gas	0.0016	1,028	2.46E06	2.15E10	ft3
ULSD	0.0015	138,000	18,290	1.3E7	gal

Burner Manufacturer and Model Number		
Number of Burners		
Burner Maximum Rated Capacity (per burner)	MMBtu/hr	
Firing Type and Method Information (Choose a	all that apply)	
Oil/Gas Fired Unit	☐ Tangentially Fired ☐ Horizontally Opposed (normal) Fired ☐ Other (specify):	
Pulverized Coal Fired Unit	☐ Dry Bottom ☐ Wall Fired ☐ Horizontally Fired ☐ Other (specify):	☐ Wet Bottom☐ Tangentially Fired☐ Vertically Fired
Coal/Wood Fired Stoker Unit	☐ Overfeed ☐ Spreader ☐ IGCC (Integrated Gas	☐ Underfeed ☐ Hand Fed sification Combined Cycle)
Coal/Wood Fired Fluidized Bed Combustor	☐ Circulating Bed ☐ Cyclone Furnace ☐ Other (specify):	☐ Bubbling Bed
Other Coal/Wood Fired Unit	☐ Suspension Firing ☐ Dutch Oven/Fuel Cel ☐ Over Fire Air ☐ Other (specify):	l Oven

Part IV: Internal Combustion (IC) Unit Information (IC Engine or Turbine)

IC Engine Information	
IC Engine Operation (check one)	☐ Emergency Only ☐ Emergency/Non-Emergency
IC Engine Ignition (check one)	☐ Compression ☐ Spark
IC Engine Type (check one)	☐ 4-Stroke Rich Burn (4SRB) ☐ 4-Stroke Lean Burn (4SLB) ☐ 2-Stroke Lean Burn (2SLB)
IC Engine Brake Horsepower	HP
IC Engine Power Output	MW
Turbine Information	
Turbine Operation (check one)	☐ Emergency Only ☐ Emergency/Non-Emergency
Turbine Type (check one)	☐ Simple Cycle ☐ Combined Cycle
Turbine Power Output	262 @ ISO conditions MW

Part V: Combustion Controls Information (Check all that apply)

Type of Combustion Control(s) or Modifications(s)	□ Low NOx Burners □ Flue Gas Recirculation □ Selective Catalytic Reduction □ Coal Reburn □ Gas Reburn □ Lean Burn □ Rich Burn □ Low Excess Air □ Other (specify):	☐ Fly Ash Reinjection ☐ Reburn ☐ Selective Non-Catalytic Reduction ☑ Oxidation Catalyst ☐ 3-way Catalyst ☐ Over Fire Air ☐ Biased Burner Firing ☐ Burners Out of Service ☐ None
--	---	---

Part VI: Attachments

Please check the attachments being submitted as verification that all applicable attachments have been submitted with this application form. When submitting such documents, please label the documents as indicated in this Part (e.g., Attachment E202-A, etc.) and be sure to include the applicant's name.

⊠ Attachment E202-A:	Process Information and Flow Diagram – Submit a process flow diagram indicating all related equipment, air pollution control equipment and stacks, as applicable. Identify all materials entering and leaving each such device indicating quantities and parameters relevant to the proper operation of the device. Indicate all monitoring devices and controls. REQUIRED
☐ Attachment E202-B:	Manufacturer Information - Submit copies of the manufacturer specification sheets for the unit, the air pollution control equipment and the monitoring systems. REQUIRED
	Turbine Emissions Profiles - Submit copies of manufacturer's emissions profile data for steady state and transient operation of the turbine. IF APPLICABLE

Applicant Name: CPV Towantic, LLC		
Unit No.: DB1		DEEP USE ONLY
Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-202) to ensure the proper handling of your application. Print or type unless otherwise noted.	App. No.:	

Note: Certain external combustion units may be operated pursuant to RCSA section 22a-174-3b or -3c in lieu of a permit to construct and operate pursuant to RCSA section 22a-174-3a.

Complete a separate form for each fuel burning source.

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Part I: General

Type of Unit (check one)	☐ Boiler ☐ IC Engine ☑ Duct Burner	☐ Heater/Furnace☐ Turbine☐ Other (specify):
Manufacturer and Model Number	TBD	
Construction Date		
Manufacture Date		
Is this unit subject to Title 40 CFR Part 60, NSPS?	☐ No ☑ Yes, Subpart(s) KKKK	
Is this unit subject to Title 40 CFR Part 63, MACT?	No ☐ Yes, Subpart(s)	
Maximum Design Heat Input	962 MMBtu/hr	
Typical Heat Input	962 MMBtu/hr	
Maximum Operating Schedule	24 hours/day	4,250 hours/year
	Space Heat:	%
Percentage of Annual Use in Each Category	Process Heat:	%
	Power:	100%

Fuel Type	% Sulfur by weight	Higher Heating Value (BTU)	Maximum Hourly Firing Rate	Maximum Annual Fuel Usage	Units (gal or ft³)
Natural Gas	0.0016	1,028	935,895	3.98E09	ft3

Burner Manufacturer and Model Number		
Number of Burners		
Burner Maximum Rated Capacity (per burner)	MMBtu/hr	
Firing Type and Method Information (Choose all that apply)		
Oil/Gas Fired Unit	☐ Tangentially Fired ☐ Horizontally Opposed ☐ Other (specify):	d (normal) Fired
Pulverized Coal Fired Unit	☐ Dry Bottom ☐ Wall Fired ☐ Horizontally Fired ☐ Other (specify):	☐ Wet Bottom☐ Tangentially Fired☐ Vertically Fired
Coal/Wood Fired Stoker Unit	☐ Overfeed ☐ Spreader ☐ IGCC (Integrated Gas	☐ Underfeed ☐ Hand Fed sification Combined Cycle)
Coal/Wood Fired Fluidized Bed Combustor	☐ Circulating Bed ☐ Cyclone Furnace ☐ Other (specify):	☐ Bubbling Bed
Other Coal/Wood Fired Unit	☐ Suspension Firing ☐ Dutch Oven/Fuel Cel ☐ Over Fire Air ☐ Other (specify):	l Oven

Part IV: Internal Combustion (IC) Unit Information (IC Engine or Turbine)

IC Engine Information		
IC Engine Operation (check one)	☐ Emergency Only	☐ Emergency/Non-Emergency
IC Engine Ignition (check one)	☐ Compression	☐ Spark
IC Engine Type (check one)	☐ 4-Stroke Rich Burr☐ 4-Stroke Lean Bur☐ 2-Stroke Lean Bur	n (4SLB)
IC Engine Brake Horsepower	HP	
IC Engine Power Output	MW	
Turbine Information		
Turbine Operation (check one)	☐ Emergency Only	☐ Emergency/Non-Emergency
Turbine Type (check one)	☐ Simple Cycle	☐ Combined Cycle
Turbine Power Output	MW	

Type of Combustion Control(s) or Modifications(s)	 ☑ Low NOx Burners ☐ Flue Gas Recirculation ☑ Selective Catalytic Reduction ☐ Coal Reburn ☐ Gas Reburn ☐ Lean Burn ☐ Rich Burn ☐ Low Excess Air ☐ Other (specify): 	 ☐ Fly Ash Reinjection ☐ Reburn ☐ Selective Non-Catalytic Reduction ☑ Oxidation Catalyst ☐ 3-way Catalyst ☐ Over Fire Air ☐ Biased Burner Firing ☐ Burners Out of Service ☐ None

Part VI: Attachments

Please check the attachments being submitted as verification that all applicable attachments have been submitted with this application form. When submitting such documents, please label the documents as indicated in this Part (e.g., Attachment E202-A, etc.) and be sure to include the applicant's name.

	Process Information and Flow Diagram – Submit a process flow diagram indicating all related equipment, air pollution control equipment and stacks, as applicable. Identify all materials entering and leaving each such device indicating quantities and parameters relevant to the proper operation of the device. Indicate all monitoring devices and controls. REQUIRED
☐ Attachment E202-B:	Manufacturer Information - Submit copies of the manufacturer specification sheets for the unit, the air pollution control equipment and the monitoring systems. REQUIRED
☐ Attachment E202-C:	Turbine Emissions Profiles - Submit copies of manufacturer's emissions profile data for steady state and transient operation of the turbine. IF APPLICABLE

Applicant Name: CPV Towantic, LLC	
Unit No.: DB2	DEEP USE ONLY
Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-202) to ensure the proper handling of your application. Print or type unless otherwise noted.	App. No.:

Note: Certain external combustion units may be operated pursuant to RCSA section 22a-174-3b or -3c in lieu of a permit to construct and operate pursuant to RCSA section 22a-174-3a.

Complete a separate form for each fuel burning source.

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Part I: General

Type of Unit (check one)	☐ Boiler ☐ IC Engine ☑ Duct Burner	☐ Heater/Furnace☐ Turbine☐ Other (specify):
Manufacturer and Model Number	TBD	
Construction Date		
Manufacture Date		
Is this unit subject to Title 40 CFR Part 60, NSPS?	☐ No ☑ Yes, Subpart(s) KKKK	
Is this unit subject to Title 40 CFR Part 63, MACT?	No ☐ Yes, Subpart(s)	
Maximum Design Heat Input	962 MMBtu/hr	
Typical Heat Input	962 MMBtu/hr	
Maximum Operating Schedule	24 hours/day	4,250 hours/year
	Space Heat:	%
Percentage of Annual Use in Each Category	Process Heat:	%
	Power:	100%

Fuel Type	% Sulfur by weight	Higher Heating Value (BTU)	Maximum Hourly Firing Rate	Maximum Annual Fuel Usage	Units (gal or ft³)
Natural Gas	0.0016	1,028	935,895	3.98E09	ft3

Burner Manufacturer and Model Number		
Number of Burners		
Burner Maximum Rated Capacity (per burner)	MMBtu/hr	
Firing Type and Method Information (Choose all that apply)		
Oil/Gas Fired Unit	☐ Tangentially Fired ☐ Horizontally Opposed ☐ Other (specify):	d (normal) Fired
Pulverized Coal Fired Unit	☐ Dry Bottom ☐ Wall Fired ☐ Horizontally Fired ☐ Other (specify):	☐ Wet Bottom☐ Tangentially Fired☐ Vertically Fired
Coal/Wood Fired Stoker Unit	☐ Overfeed ☐ Spreader ☐ IGCC (Integrated Gas	☐ Underfeed ☐ Hand Fed sification Combined Cycle)
Coal/Wood Fired Fluidized Bed Combustor	☐ Circulating Bed ☐ Cyclone Furnace ☐ Other (specify):	☐ Bubbling Bed
Other Coal/Wood Fired Unit	☐ Suspension Firing ☐ Dutch Oven/Fuel Cel ☐ Over Fire Air ☐ Other (specify):	l Oven

Part IV: Internal Combustion (IC) Unit Information (IC Engine or Turbine)

IC Engine Information		
IC Engine Operation (check one)	☐ Emergency Only	☐ Emergency/Non-Emergency
IC Engine Ignition (check one)	☐ Compression	☐ Spark
IC Engine Type (check one)	☐ 4-Stroke Rich Burr☐ 4-Stroke Lean Bur☐ 2-Stroke Lean Bur	n (4SLB)
IC Engine Brake Horsepower	HP	
IC Engine Power Output	MW	
Turbine Information		
Turbine Operation (check one)	☐ Emergency Only	☐ Emergency/Non-Emergency
Turbine Type (check one)	☐ Simple Cycle	☐ Combined Cycle
Turbine Power Output	MW	

Type of Combustion Control(s) or Modifications(s)	 ☑ Low NOx Burners ☐ Flue Gas Recirculation ☑ Selective Catalytic Reduction ☐ Coal Reburn ☐ Gas Reburn ☐ Lean Burn ☐ Rich Burn ☐ Low Excess Air ☐ Other (specify): 	 ☐ Fly Ash Reinjection ☐ Reburn ☐ Selective Non-Catalytic Reduction ☑ Oxidation Catalyst ☐ 3-way Catalyst ☐ Over Fire Air ☐ Biased Burner Firing ☐ Burners Out of Service ☐ None

Part VI: Attachments

Please check the attachments being submitted as verification that all applicable attachments have been submitted with this application form. When submitting such documents, please label the documents as indicated in this Part (e.g., Attachment E202-A, etc.) and be sure to include the applicant's name.

	Process Information and Flow Diagram – Submit a process flow diagram indicating all related equipment, air pollution control equipment and stacks, as applicable. Identify all materials entering and leaving each such device indicating quantities and parameters relevant to the proper operation of the device. Indicate all monitoring devices and controls. REQUIRED
☐ Attachment E202-B:	Manufacturer Information - Submit copies of the manufacturer specification sheets for the unit, the air pollution control equipment and the monitoring systems. REQUIRED
☐ Attachment E202-C:	Turbine Emissions Profiles - Submit copies of manufacturer's emissions profile data for steady state and transient operation of the turbine. IF APPLICABLE

Applicant Name: CPV Towantic, LLC	
Unit No.: EG	DEEP USE ONLY
Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-202) to ensure the proper handling of your application. Print or type unless otherwise noted.	App. No.:

Note: Certain external combustion units may be operated pursuant to RCSA section 22a-174-3b or -3c in lieu of a permit to construct and operate pursuant to RCSA section 22a-174-3a.

Complete a separate form for each fuel burning source.

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Part I: General

Type of Unit (check one)	☐ Boiler ☐ IC Engine ☐ Duct Burner	☐ Heater/Furnace☐ Turbine☐ Other (specify):
Manufacturer and Model Number	Caterpillar 3512C (or equivalent)	
Construction Date		
Manufacture Date		
Is this unit subject to Title 40 CFR Part 60, NSPS?	☐ No	
Is this unit subject to Title 40 CFR Part 63, MACT?	☐ No	
Maximum Design Heat Input	14.4 MMBtu/hr	
Typical Heat Input	14.4 MMBtu/hr	
Maximum Operating Schedule	24 hours/day	300 hours/year
	Space Heat:	%
Percentage of Annual Use in Each Category	Process Heat:	%
	Power:	100%

Fuel Type	% Sulfur by weight	Higher Heating Value (BTU)	Maximum Hourly Firing Rate	Maximum Annual Fuel Usage	Units (gal or ft³)
ULSD	0.0015%	138,000	104.6	31,380	gal

Burner Manufacturer and Model Number		
Number of Burners		
Burner Maximum Rated Capacity (per burner)	MMBtu/hr	
Firing Type and Method Information (Choose a	all that apply)	
Oil/Gas Fired Unit	☐ Tangentially Fired ☐ Horizontally Opposed (normal) Fired ☐ Other (specify):	
Pulverized Coal Fired Unit	☐ Dry Bottom ☐ Wall Fired ☐ Horizontally Fired ☐ Other (specify):	☐ Wet Bottom☐ Tangentially Fired☐ Vertically Fired
Coal/Wood Fired Stoker Unit	☐ Overfeed ☐ Spreader ☐ IGCC (Integrated Gas	☐ Underfeed ☐ Hand Fed sification Combined Cycle)
Coal/Wood Fired Fluidized Bed Combustor	☐ Circulating Bed ☐ Cyclone Furnace ☐ Other (specify):	☐ Bubbling Bed
Other Coal/Wood Fired Unit	☐ Suspension Firing ☐ Dutch Oven/Fuel Cel ☐ Over Fire Air ☐ Other (specify):	l Oven

Part IV: Internal Combustion (IC) Unit Information (IC Engine or Turbine)

IC Engine Information			
IC Engine Operation (check one)			
IC Engine Ignition (check one)			
IC Engine Type (check one)	☐ 4-Stroke Rich Burn (4SRB) ☐ 4-Stroke Lean Burn (4SLB) ☐ 2-Stroke Lean Burn (2SLB)		
IC Engine Brake Horsepower	2,206 HP		
IC Engine Power Output	1.500 MW		
Turbine Information			
Turbine Operation (check one)	☐ Emergency Only ☐ Emergency/Non-Emergency		
Turbine Type (check one)	☐ Simple Cycle ☐ Combined Cycle		
Turbine Power Output	MW		

Part V: Combustion Controls Information (Check all that apply)

Type of Combustion Control(s) or Modifications(s)	☐ Low NOx Burners ☐ Flue Gas Recirculation ☐ Selective Catalytic Reduction ☐ Coal Reburn ☐ Gas Reburn ☐ Lean Burn ☐ Rich Burn ☐ Low Excess Air ☐ Other (specify):	☐ Fly Ash Reinjection ☐ Reburn ☐ Selective Non-Catalytic Reduction ☐ Oxidation Catalyst ☐ 3-way Catalyst ☐ Over Fire Air ☐ Biased Burner Firing ☐ Burners Out of Service ☒ None
--	---	---

Part VI: Attachments

Please check the attachments being submitted as verification that all applicable attachments have been submitted with this application form. When submitting such documents, please label the documents as indicated in this Part (e.g., Attachment E202-A, etc.) and be sure to include the applicant's name.

	Process Information and Flow Diagram – Submit a process flow diagram indicating all related equipment, air pollution control equipment and stacks, as applicable. Identify all materials entering and leaving each such device indicating quantities and parameters relevant to the proper operation of the device. Indicate all monitoring devices and controls. REQUIRED
☐ Attachment E202-B:	Manufacturer Information - Submit copies of the manufacturer specification sheets for the unit, the air pollution control equipment and the monitoring systems. REQUIRED
☐ Attachment E202-C:	Turbine Emissions Profiles - Submit copies of manufacturer's emissions profile data for steady state and transient operation of the turbine. IF APPLICABLE

Applicant Name: CPV Towantic, LLC		
Unit No.: FP		DEEP USE ONLY
Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-202) to ensure the proper handling of your application. Print or type unless otherwise noted.	App. No.:	

Note: Certain external combustion units may be operated pursuant to RCSA section 22a-174-3b or -3c in lieu of a permit to construct and operate pursuant to RCSA section 22a-174-3a.

Complete a separate form for each fuel burning source.

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Part I: General

Type of Unit (check one)	☐ Boiler ☑ IC Engine ☐ Duct Burner	☐ Heater/Furnace☐ Turbine☐ Other (specify):	
Manufacturer and Model Number	Clarke JW6H-UFAD	Clarke JW6H-UFADJ0 (or equivalent)	
Construction Date			
Manufacture Date			
Is this unit subject to Title 40 CFR Part 60, NSPS?	☐ No		
Is this unit subject to Title 40 CFR Part 63, MACT?	☐ No ☑ Yes, Subpart(s) ZZZZ		
Maximum Design Heat Input	2.45 MMBtu/hr		
Typical Heat Input	2.45 MMBtu/hr		
Maximum Operating Schedule	24 hours/day	300 hours/year	
	Space Heat:	N/A%	
Percentage of Annual Use in Each Category	Process Heat:	N/A%	
	Power:	N/A%	

Fuel Type	% Sulfur by weight	Higher Heating Value (BTU)	Maximum Hourly Firing Rate	Maximum Annual Fuel Usage	Units (gal or ft³)
ULSD	0.0015%	138,000	17.8	5,330	gal

Burner Manufacturer and Model Number		
Number of Burners		
Burner Maximum Rated Capacity (per burner)	MMBtu/hr	
Firing Type and Method Information (Choose a	all that apply)	
Oil/Gas Fired Unit	☐ Tangentially Fired ☐ Horizontally Opposed (normal) Fired ☐ Other (specify):	
Pulverized Coal Fired Unit	☐ Dry Bottom ☐ Wall Fired ☐ Horizontally Fired ☐ Other (specify):	☐ Wet Bottom☐ Tangentially Fired☐ Vertically Fired
Coal/Wood Fired Stoker Unit	☐ Overfeed ☐ Spreader ☐ IGCC (Integrated Gas	☐ Underfeed ☐ Hand Fed sification Combined Cycle)
Coal/Wood Fired Fluidized Bed Combustor	☐ Circulating Bed ☐ Cyclone Furnace ☐ Other (specify):	☐ Bubbling Bed
Other Coal/Wood Fired Unit	☐ Suspension Firing ☐ Dutch Oven/Fuel Cel ☐ Over Fire Air ☐ Other (specify):	l Oven

Part IV: Internal Combustion (IC) Unit Information (IC Engine or Turbine)

IC Engine Information					
IC Engine Operation (check one)		☐ Emergency/Non-Emergency			
IC Engine Ignition (check one)		Spark			
IC Engine Type (check one)	☐ 4-Stroke Rich Burn ☐ 4-Stroke Lean Burn ☐ 2-Stroke Lean Burn	n (4SLB)			
IC Engine Brake Horsepower	350 HP	350 HP			
IC Engine Power Output	N/A MW	N/A MW			
Turbine Information					
Turbine Operation (check one)	☐ Emergency Only	☐ Emergency/Non-Emergency			
Turbine Type (check one)	☐ Simple Cycle	☐ Combined Cycle			
Turbine Power Output	MW				

Part V: Combustion Controls Information (Check all that apply)

Type of Combustion Control(s) or Modifications(s)	☐ Low NOx Burners ☐ Flue Gas Recirculation ☐ Selective Catalytic Reduction ☐ Coal Reburn ☐ Gas Reburn ☐ Lean Burn ☐ Rich Burn ☐ Low Excess Air ☐ Other (specify):	 ☐ Fly Ash Reinjection ☐ Reburn ☐ Selective Non-Catalytic Reduction ☐ Oxidation Catalyst ☐ 3-way Catalyst ☐ Over Fire Air ☐ Biased Burner Firing ☐ Burners Out of Service ☑ None
--	---	---


Part VI: Attachments

Please check the attachments being submitted as verification that all applicable attachments have been submitted with this application form. When submitting such documents, please label the documents as indicated in this Part (e.g., Attachment E202-A, etc.) and be sure to include the applicant's name.

	Process Information and Flow Diagram – Submit a process flow diagram indicating all related equipment, air pollution control equipment and stacks, as applicable. Identify all materials entering and leaving each such device indicating quantities and parameters relevant to the proper operation of the device. Indicate all monitoring devices and controls. REQUIRED
☐ Attachment E202-B:	Manufacturer Information - Submit copies of the manufacturer specification sheets for the unit, the air pollution control equipment and the monitoring systems. REQUIRED
☐ Attachment E202-C:	Turbine Emissions Profiles - Submit copies of manufacturer's emissions profile data for steady state and transient operation of the turbine. IF APPLICABLE

ATTACHMENT E202-A - PROCESS FLOW DIAGRAMS


AUXILIARY BOILER – PROCESS FLOW DIAGRAM



NOTE: Material quantities provided in Appendix A

ATTACHMENT E202-A - PROCESS FLOW DIAGRAMS


COMBUSTION TURBINES AND DUCT BURNERS - PROCESS FLOW DIAGRAM



NOTE: Material quantities provided in Appendix A

ATTACHMENT E202-A - PROCESS FLOW DIAGRAMS

EMERGENCY GENERATOR AND FIRE PUMP ENGINES – PROCESS FLOW DIAGRAM



NOTE: Material quantities provided in Appendix A

Attachment E210: Air Pollution Control Equipment Supplemental Application Form

Applicant Name: CPV Towantic. LLC		DEEP USE ONLY
Unit No(s).: CT1/DB1 and CT1/DB2		DEEP USE ONLY
	App. No.:	
Complete this form in accordance with the instructions (DEED NSP INST 210) to ensure the proper handling of your		

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-210) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this supplemental application form to provide the air pollution control equipment information for all units that are part of this application package.

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Part I. Summary Sheet

Unit	Unit Decemention		Control Equipment		Pollutant(s)	*D '-	Or all Na
No.	Unit Description	No.	Туре	Efficiency (%)	Controlled	*Basis	Stack No.
CT1/DB	Combined Cycle Combustion Turbine #1	SCR1	SCR	90 (est)	NOx	Vendor Guarantee	1
CT1/DB	Combined Cycle Combustion Turbine #1	OC1	Oxidation Catal	90 (est)	co, voc	Vendor Guarantee	1
CT2/DB	Combined Cycle Combustion Turbine #2	SCR2	SCR	90 (est)	NOx	Vendor Guarantee	2
CT2/DB	Combined Cycle Combustion Turbine #2	OC2	Oxidation Catal	90 (est)	CO, VOC	Vendor Guarantee	2

^{*} Submit supporting documentation with this form, e.g., stack test data, manufacturer's guarantees, etc. as Attachment E210(Control Equipment No.).

1 of 10

☐ Check here if additional sheets are necessary, and label and attach them to this sheet.

Part II: Specific Control Equipment

1. Adsorption Device

Complete the appropriate subsection for each *distinct* piece of control equipment.

Control Equipment Number of Adsor Unit Number of Unit which Uses Ads		
Manufacturer and Model Numbe	r	
Construction Date		
Adsorbent		☐ Activated Charcoal Type: ☐ Granulated ☐ Other (specify): ☐ Powdered
Number of Beds		
Dimensions of Beds	Bed No. 1	Thickness in direction of gas flow: inches Cross-section area: square inches
Check here if additional sheets are necessary, and label	Bed No. 2	Thickness in direction of gas flow: inches Cross-section area: square inches
and attach them to this sheet.	Bed No. 3	Thickness in direction of gas flow: inches Cross-section area: square inches
Inlet Gas Temperature		°F
Design Pressure Drop Range Across Unit		inches H ₂ O
Gas Flow Rate		scfm
Type of Regeneration		☐ Replacement ☐ Steam

Other (specify):

Other (specify):

☐ Yes

%

%

%

☐ Alternate use of beds

Method of Regeneration

Pollutant(s) Controlled

Detector?

Maximum Operation Time Before Regeneration

Is Adsorber Equipped with a Break-Through

Collection Efficiency(s) of Adsorber

Control Efficiency(s) of Adsorber

Overall Control Efficiency(s)

☐ Source shut down

Describe procedures used to ensure that emissions from

☐ No

regeneration process are treated or minimized:

2. Afterburner (Incinerator for Air Pollution Control)

Control Equipment Number of Afterburner: OC1 & OC2 (Identical Devices)

Unit Number of Unit which Uses Afterburner: CT1/DB1 & CT2/DB2

Manufacturer and Model Number		TBD						
Construction Date		2015						
Type of Afterburner			☐ Thermal ☐ Catalytic ☐ Other (specify):					
Combustion Chamber		Length		Т	BD inches			
Dimensions		Cross-s	ection area	Т	TBD square inches			
Inlet Gas Temperature				7	00 °F			
Operating Temperature	Range	e of Cha	mber	6	00-800 °F			
Auxiliary Fuel Informati	on							
Fuel Type		Sulfur Veight	Higher Heating Value (BTU)	9	Maximum Hourly Firing Rate	Maximum Annual Fuel Usage	Units (gal or ft ³)	
None	١	V/A	N/A		N/A	N/A	N/A	
Number of Burners				N/A				
	Burner No. 1		N/A BTU per hour					
Burner Maximum Heat Input		Burner I	No. 2	BTU per hour				
Burner No. 3			BTU per hour					
Catalyst Used			Yes No)				
Catalyst Type				platinum				
Catalyst Sampling In	terval			TBD				
Heat Exchanger Used					☐ Yes	0		
Type of Heat Exchan	ger							
Heat Recovery								
Reagent Used			N/A					
Gas Flow Rate		1,052,605 @ ISO on gas w/o duct firing scfm						
Combustion Chamber Design Residence Time		Т	BD seconds					
Moisture Content of Exhaust Gas		9	%					
Heat Recovery			0 %					
Pollutant(s) Controlled			С	O & VOC				
Collection Efficiency(s) of Afterburner			1	00 %				

2. Afterburner (Incinerator for Air Pollution Control) (continued)

Control Equipment Number of Afterburner: OC1 & OC2 (Identical Devices)

Unit Number of Unit which Uses Afterburner: CT1/DB1 & CT2/DB2

Control Efficiency(s) of Afterburner	90% for CO %
Overall Control Efficiency(s)	90% for CO %

3. Condenser				
Control Equipment Number of Condenser:		_		
Unit Number of Unit which Uses Condenser:		-		
Manufacturer and Model Number				
Construction Date				
Heat Exchange Area	square feet			
Coolant Flow Rate	☐ Water: gpm ☐ Air: scfm ☐ Other (specify):			
Gas Flow Rate	scfm			
Coolant Temperature	In: °F	Out:	°F	
Gas Temperature	In: °F	Out:	°F	
Pollutant(s) Controlled				
Collection Efficiency(s) of Condenser	%			
Control Efficiency(s) of Condenser	%			
Overall Control Efficiency(s)	%			

4. Electrostatic Precipitator

Control Equipment Number of Electrostatic Precipitator:
Init Number of Unit which Uses Electrostatic Precipitator:

Manufacturer and Model Number				
Construction Date				
Collecting Electrode Area		square feet		
Gas Flow Rate		scfm		
Voltage Across the Precipitator Plates		kV		
Resistivity of Pollutants		ohms		
Number of Fields in the Precipitator				
Grain Loading	In:	grains/scf	Out:	grains/scf
Pollutant(s) Controlled				
Collection Efficiency(s) of Electrostatic Precipitator		%		
Control Efficiency(s) of Electrostatic Precipitator		%		
Overall Control Efficiency(s)		%		

5. Filter

Control Equipment Number of Filter:	
Unit Number of Unit which Uses Filter:	

Manufacturer and Model Number					
Construction Date					
Filtering Material					
Air to Cloth Ratio	square feet				
Net Cloth Area	square feet				
Number of Bags					
Cleaning Method	☐ Shaker ☐ Reverse Air ☐ Pulse Air ☐ Pulse Jet ☐ Other (specify):				
Gas Cooling Method	□ Ductwork Length: ft. Diameter: in. □ Heat Exchanger □ Bleed-in Air □ Water Spray □ Other (specify): □ Not Applicable				
Cooling Medium Flow Rate	☐ Bleed-in Air: scfm ☐ Water Spray: gpm				
Exhaust Gas Flow Rate	scfm				
Inlet Gas Temperature	°F				
Inlet Gas Dew Point	°F				
Grain Loading	In: grains/scf Out: grains/scf				
Design Pressure Drop Across Unit	inches H₂O				
Operating Pressure Drop Range Across Unit	inches H ₂ O				
Pollutant(s) Controlled					
Collection Efficiency(s) of Filter	%				
Control Efficiency(s) of Filter	%				
Overall Control Efficiency(s)	%				

6. Cyclone	
Control Equipment Number of Cyclone:	
Unit Number of Unit which Uses Cyclone:	
Manufacturer and Model Number	
Construction Date	
Type of Cyclone	☐ Single ☐ Multiple: Number of Cyclones
Gas Flow Rate	scfm
Grain Loading	In: grains/scf Out: grains/scf
Design Pressure Drop Across Unit	inches H ₂ O
Pollutant(s) Controlled	
Collection Efficiency(s) of Cyclone	%
Control Efficiency(s) of Cyclone	%
Overall Control Efficiency(s)	%
7. Mist Eliminator Control Equipment Number of Mist Eliminator: Unit Number of Unit which Uses Mist Eliminator:	
Manufacturer and Model Number	
Construction Date	
Face Velocity	feet per second
,	☐ Vertical Flow ☐ Horizontal Flow ☐ Diagonal
Design Pressure Drop Range Across Unit	
Design Pressure Drop Range Across Unit	inches H ₂ O
Design Pressure Drop Range Across Unit Flow Rate	inches H ₂ O

Overall Control Efficiency(s)

%

8. Scrubber

Control Equipment Number of Scrubber:	
Unit Number of Unit which Uses Scrubber	:

Manufacturer and Mode	l Number				
Construction Date					
		☐ Venturi			
		☐ Wet Fan			
		☐ Packed:	Packing Material Size: Packed Height: inches		
Type of Scrubber		☐ Spray:	Number of Nozzles: Nozzle No. 1 Pressure: psig Nozzle No. 2 Pressure: psig Nozzle No. 3 Pressure: psig Nozzle No. 4 Pressure: psig		
		Other (spec	eify):		
Design Pressure Drop R	ange Across Unit	inches H₂O			
Type of Flow		☐ Concurrent	☐ Countercurrent ☐ Crossflow		
Scrubber Geometry	Length in direction of gas flow	feet			
	Cross-sectional area	square i	inches		
Chemical Composition	of Scrubbing Liquid				
Scrubbing Liquid/Reage	ent Flow Rate	gpm			
Fresh Liquid Make-Up R	ate	gpm			
Scrubber Liquid/Reager	nt Circulation	☐ One Pass	Recirculated		
Scrubber Liquid/Reager	nt pH				
Gas Flow Rate		scfm			
Inlet Gas Temperature		°F			
Design Outlet Grain Loading		gr/dscf			
Pollutant(s) Controlled					
Collection Efficiency(s)	of Scrubber	%			
Control Efficiency(s) of	Scrubber	%			
Overall Control Efficien	cy(s)	%	3		

9. Other Control Equipment for Degreasing Equipr	nent
Name of Control Equipment:	
Control Equipment Number of Control Equipment:	
Unit Number of Unit which Uses Control Equipment: _	
Manufacturer and Model Number	
Construction Date	
Method of Control	☐ Refrigerator Chiller ☐ Water Spray ☐ Other (specify):
Pollutant(s) Controlled	
Collection Efficiency(s) of Control Equipment	%
Control Efficiency(s) of Control Equipment	%
Overall Control Efficiency(s)	%
Unit Number of Unit which Uses Control Equipment: C	TBD
Construction Date	2015
Pollutant(s) Controlled	NOx
Collection Efficiency(s) of Control Equipment	100 %
Control Efficiency(s) of Control Equipment	90 (estimate) %
Overall Control Efficiency(s)	90 (estimate) %
	ication that all applicable attachments have been submitted uments, please label the documents as indicated in this Part and be sure to include the applicant's name.

manufacturer's guarantees, etc. Label each document in this Attachment referencing the applicable air pollution control equipment number as indicated in Part I of this form using this format: Attachment E210(Control Equipment No.). **REQUIRED**

Attachment E211: Stack and Building Parameters Supplemental Application Form

Applicant Name:
Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-211) to ensure the proper handling of your application. Print or type unless otherwise noted.
Complete this supplemental application form to provide the stack and building parameter information for all units that are part of this application package.
Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Part I. Stack Parameters Summary

Stack	Unit	Control	Stack	Stack	Stack Ex	kit Temp F)		aust Flow ACFM)	Stack Exit Direction (H or V)	Rain Hat (Y or N)	Stack Lining Material	Stack Distance to Nearest Property Line (feet)
No.	No.(s)	Equipment No.(s)	Height (feet)	Diameter (feet)	Max	Min	Max	Min				

Part II. Building Parameters Summary

Complete this Part if a Stack Height Review or Screening Ambient Air Quality Analysis is required. This Part is not required for sources performing a Refined Modeling Analysis.

Building	Ruilding Description	Building Bu Height Le	Building Height	Building Description Height Length		ling Building gth Width	h				Building Distance to Nearest
No.	Building Description	(H) (feet)	(L) (feet)	(W) (feet)	Stack No.	Stack No.	Stack No.	Stack No.	Property Line (feet)		

2 of 3

☐ Check here if additional sheets are necessary, and label and attach them to this sheet.

Part III. Attachment

Please check the attachments being submitted as verification that all applicable attachments have been submitted with this application form. When
submitting such documents, please label the documents as indicated in this Part (e.g., Attachment E211-A, etc.) and be sure to include the applicant's
name.

Attachment E211-A: Plot Plan – Submit a detailed plot plan of the facility with all structures, stack locations, and property lines clearly delineated. In addition you may submit sketches, aerial photos, or other site plans to aid in the identification of buildings listed in Part II and their locations with respect to the stacks listed in Part I. **REQUIRED**

Attachment E212: Unit Emissions Supplemental Application Form

Applicant Name: CPV Towantic , LLC	DEEP USE ONLY
Unit No.: AB	App. No.:

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-212) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete a separate form for each unit.

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Part I: Unit Emission Information

Dallartout	Potential E	missions at Capacity	Proposed Allowable Emissions				
Pollutant	lb/hr	tpy	lb/hr	Other Units (specify)	tpy		
		Criteria Air	Pollutants				
PM	0.65	2.85		0.007 lb/MMBtu	1.29		
PM ₁₀	0.65	2.85		0.007 lb/MMBtu	1.29		
PM _{2.5} Total (filterable + condensable)	0.65	2.85		0.007 lb/MMBtu	1.29		
SO _x	0.14	0.61			0.28		
NO _x	1.01	4.42		0.011 lb/MMBtu	2.02		
СО	3.42	15.0		0.037 lb/MMBtu	6.83		
voc	0.38	1.64		0.0041 lb/MMBtu	0.75		
Pb	4.5E-05	1.96E-04			9.1E-05		
GHG	1.08E04	4.74E04			21,627		
	н	azardous or Otl	her Air Pollutar	its			
See Appendix A							

Potential Emissions Calculation Basis: Vendor Data

Proposed Allowable Emissions Calculation Basis: Vendor Data and 359,533,000 ft3/yr of gas			

Part II: Regulatory Standards

Enter the regulatory standard(s) and the proposed allowable emissions for each pollutant emitted by the unit using the same units (e.g., ppmvd, lb/MMBTU, lb/hour, lb/day, etc.). More than one regulatory standard will often apply to a unit for a particular pollutant, list all that apply. Enter the regulatory citation(s) for the standard(s).

NOTE: The applicant should be aware of any existing regulatory standard applicable to the unit and should not propose allowable emissions in excess of the regulatory standard(s).

Pollutant	Regulatory Standard(s) (specify units)	Proposed Allowable Emissions (specify units)	Regulatory Citation(s)
	Crite	eria Air Pollutants	
РМ			
PM ₁₀			
PM _{2.5} Total (filterable + condensable)			
SO _x			
NO _x			
СО			
VOC			
Pb			
GHG			
		s or Other Air Pollutants her than RCSA §22a-174-	

Part III: Attachments

Please check the attachment being submitted as verification that all applicable attachments have been submitted with this application form. When submitting such documents, please label the documents as indicated in this Part (e.g., Attachment E212-A, etc.) and be sure to include the applicant's name.

\boxtimes	Attachment E212-A:	Sample Calculations- Submit sample calculations used to determine all emissions rates, excluding GHG. See Attachment E212-C for GHG emissions. REQUIRED
	Attachment E212-B:	RCSA section 22a-174-29 Hazardous Air Pollutants Compliance – Submit a completed CTMASC spreadsheet, or equivalent, to demonstrate compliance with RCSA section 22a-174-29. REQUIRED
	Attachment E212-C:	Greenhouse Gas Emissions – Submit a completed CO ₂ Equivalents Calculator Spreadsheet, or equivalent, used to quantify Greenhouse Gas emissions, REQUIRED

Attachment E212: Unit Emissions Supplemental Application Form

Applicant Name: CPV Towantic, LLC	DEEP USE ONLY
Unit No.: CT1 & DB1	App. No.:

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-212) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete a separate form for each unit.

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Part I: Unit Emission Information

Dallartant	Potential E	missions at Capacity	Proposed Allowable Emissions		issions
Pollutant	lb/hr	tpy	lb/hr	Other Units (specify)	tpy
		Criteria Air	Pollutants		
PM	42.6	186.6		See Attached	76.7
PM ₁₀	42.6	186.6		Tables	76.7
PM _{2.5} Total (filterable + condensable)	42.6	186.6			76.7
SO _x	6.2	27.2			19.7
NO _x	52.0	227.8			94.7
СО	13.8	60.4			64.5
VOC	8.82	38.6			24.5
Pb	3.53E-02	0.155	3.53E-02		1.7E-02
GHG	415,048	1.82E06	415,048		1,328,009
	Н	azardous or Otl	her Air Pollutants	5	
See Appendx A					

Potential Emissions Calculation Basis: Vendor Data

Proposed Allowable Emissions Calculation Basis: Vendor Data/operating restrictions in Exec. Summary

Part II: Regulatory Standards

Enter the regulatory standard(s) and the proposed allowable emissions for each pollutant emitted by the unit using the same units (e.g., ppmvd, lb/MMBTU, lb/hour, lb/day, etc.). More than one regulatory standard will often apply to a unit for a particular pollutant, list all that apply. Enter the regulatory citation(s) for the standard(s).

NOTE: The applicant should be aware of any existing regulatory standard applicable to the unit and should not propose allowable emissions in excess of the regulatory standard(s).

Pollutant	Regulatory Standard(s) (specify units)	Proposed Allowable Emissions (specify units)	Regulatory Citation(s)
	Crite	eria Air Pollutants	
PM			
PM ₁₀			
PM _{2.5} Total (filterable + condensable)			
SO _x	0.06 lb/MMBtu	0.0015 lb/MMBtu	40 CFR 60.4320(a)
NO _x	15 ppmvd @ 15% O2	2.0 ppmvd @ 15% O2	40 CFR 60.4330(a)(2)
СО			
VOC			
Pb			
GHG			
		s or Other Air Pollutants her than RCSA §22a-174-	

Part III: Attachments

Please check the attachment being submitted as verification that all applicable attachments have been submitted with this application form. When submitting such documents, please label the documents as indicated in this Part (e.g., Attachment E212-A, etc.) and be sure to include the applicant's name.

\boxtimes	Attachment E212-A:	Sample Calculations- Submit sample calculations used to determine all emissions rates, excluding GHG. See Attachment E212-C for GHG emissions. REQUIRED
	Attachment E212-B:	RCSA section 22a-174-29 Hazardous Air Pollutants Compliance – Submit a completed CTMASC spreadsheet, or equivalent, to demonstrate compliance with RCSA section 22a-174-29. REQUIRED
	Attachment E212-C:	Greenhouse Gas Emissions – Submit a completed CO ₂ Equivalents Calculator Spreadsheet, or equivalent, used to quantify Greenhouse Gas emissions, REQUIRED

Attachment E212: Unit Emissions Supplemental Application Form

Applicant Name: CPV Towantic, LLC		DEEP USE ONLY
Unit No.: CT2 & DB2	A	App. No.:

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-212) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete a separate form for each unit.

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Part I: Unit Emission Information

Dellistant	Potential Emissions at Maximum Capacity		Proposed Allowable Emissions		issions
Pollutant	lb/hr	tpy	lb/hr	Other Units (specify)	tpy
		Criteria Aiı	Pollutants		
PM	42.6	186.6		See Attached	76.7
PM ₁₀	42.6	186.6		Table	76.7
PM _{2.5} Total (filterable + condensable)	42.6	186.6			76.7
SO _x	6.2	27.2			19.7
NO _x	52.0	227.8			94.7
СО	13.8	60.4			64.5
VOC	8.82	38.6			24.5
Pb	3.53E-02	0.155	3.53E-02		1.7E-02
GHG	415,048	1.82E06	415,048		1,328,009
	Н	azardous or Ot	her Air Pollutant	s	
See Appendx A					

Potential Emissions Calculation Basis: Vendor Data

Proposed Allowable Emissions Calculation Basis: Vendor Data/operating restrictions in Exec. Summary

Part II: Regulatory Standards

Enter the regulatory standard(s) and the proposed allowable emissions for each pollutant emitted by the unit using the same units (e.g., ppmvd, lb/MMBTU, lb/hour, lb/day, etc.). More than one regulatory standard will often apply to a unit for a particular pollutant, list all that apply. Enter the regulatory citation(s) for the standard(s).

NOTE: The applicant should be aware of any existing regulatory standard applicable to the unit and should not propose allowable emissions in excess of the regulatory standard(s).

Pollutant	Regulatory Standard(s) (specify units)	Proposed Allowable Emissions (specify units)	Regulatory Citation(s)
	Crite	eria Air Pollutants	
PM			
PM ₁₀			
PM _{2.5} Total (filterable + condensable)			
SO _x	0.06 lb/MMBtu	0.0015 lb/MMBtu	40 CFR 60.4320(a)
NO _x	15 ppmvd @ 15% O2	2.0 ppmvd @ 15% O2	40 CFR 60.4330(a)(2)
СО			
VOC			
Pb			
GHG			
		s or Other Air Pollutants her than RCSA §22a-174-	

Part III: Attachments

Please check the attachment being submitted as verification that all applicable attachments have been submitted with this application form. When submitting such documents, please label the documents as indicated in this Part (e.g., Attachment E212-A, etc.) and be sure to include the applicant's name.

\boxtimes	Attachment E212-A:	Sample Calculations- Submit sample calculations used to determine all emissions rates, excluding GHG. See Attachment E212-C for GHG emissions. REQUIRED
	Attachment E212-B:	RCSA section 22a-174-29 Hazardous Air Pollutants Compliance – Submit a completed CTMASC spreadsheet, or equivalent, to demonstrate compliance with RCSA section 22a-174-29. REQUIRED
	Attachment E212-C:	Greenhouse Gas Emissions – Submit a completed CO ₂ Equivalents Calculator Spreadsheet, or equivalent, used to quantify Greenhouse Gas emissions, REQUIRED

Attachment E212: Unit Emissions Supplemental Application Form

Applicant Name: CPV Towantic , LLC	DEEP USE ONLY
Unit No.: EG	App. No.:

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-212) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete a separate form for each unit.

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Part I: Unit Emission Information

Pallatant		missions at Capacity	Proposed Allowable Emissions				
Pollutant	lb/hr	tpy	lb/hr	Other Units (specify)	tpy		
		Criteria Air	Pollutants				
PM	0.195	0.85		0.03 g/bhp	0.02		
PM ₁₀	0.195	0.85		0.03 g/bhp	0.02		
PM _{2.5} Total (filterable + condensable)	0.195	0.85		0.03 g/bhp	0.02		
SO _x	0.022	0.095		15 ppmw S	0.003		
NO _x	29.62	129.7		4.08 g/bhp	2.98		
СО	3.89	17.0		0.44 g/bhp	0.32		
VOC	0.73	3.20		0.11 g/bhp	0.08		
Pb	1.1E-5	4.9E-05			1.7E-06		
GHG	2,362	1.035E04			354		
	Н	azardous or Otl	her Air Pollutant	S			

Potential Emissions Calculation Basis:	Vendor Data

Proposed Allowable Emissions Calculation Basis: Vendor Data and 300 hrs/yr

Part II: Regulatory Standards

Enter the regulatory standard(s) and the proposed allowable emissions for each pollutant emitted by the unit using the same units (e.g., ppmvd, lb/MMBTU, lb/hour, lb/day, etc.). More than one regulatory standard will often apply to a unit for a particular pollutant, list all that apply. Enter the regulatory citation(s) for the standard(s).

NOTE: The applicant should be aware of any existing regulatory standard applicable to the unit and should not propose allowable emissions in excess of the regulatory standard(s).

Pollutant	Regulatory Standard(s) (specify units)	Proposed Allowable Emissions (specify units)	Regulatory Citation(s)			
	Crite	eria Air Pollutants				
PM	0.15 g/bhp	0.03 g/bhp	40 CFR 60.4202(a)(2)			
PM ₁₀	0.15 g/bhp	0.03 g/bhp	40 CFR 60.4202(a)(2)			
PM _{2.5} Total (filterable + condensable)	0.15 g/bhp	0.03 g/bhp	40 CFR 60.4202(a)(2)			
SO _x						
NO _x	4.77 g/bhp	4.08 g/bhp	40 CFR 60.4202(a)(2)			
СО	2.61 g/bhp	0.44 g/bhp	40 CFR 60.4202(a)(2)			
VOC	0.97 g/bhp	0.11 g/bhp	40 CFR 60.4202(a)(2)			
Pb						
GHG						
		s or Other Air Pollutants her than RCSA §22a-174-	29)			

Part III: Attachments

Please check the attachment being submitted as verification that all applicable attachments have been submitted with this application form. When submitting such documents, please label the documents as indicated in this Part (e.g., Attachment E212-A, etc.) and be sure to include the applicant's name.

\boxtimes	Attachment E212-A:	Sample Calculations- Submit sample calculations used to determine all emissions rates, excluding GHG. See Attachment E212-C for GHG emissions. REQUIRED
\boxtimes	Attachment E212-B:	RCSA section 22a-174-29 Hazardous Air Pollutants Compliance – Submit a completed CTMASC spreadsheet , or equivalent, to demonstrate compliance with RCSA section 22a-174-29. REQUIRED
\boxtimes	Attachment E212-C:	Greenhouse Gas Emissions – Submit a completed CO ₂ Equivalents Calculator Spreadsheet, or equivalent, used to quantify Greenhouse Gas emissions, REQUIRED

Attachment E212: Unit Emissions Supplemental Application Form

Applicant Name: CPV Towantic , LLC	DEEP USE ONLY
Unit No.: FP	App. No.:

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-212) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete a separate form for each unit.

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152.

Part I: Unit Emission Information

Dallartant	Potential Emissions at Maximum Capacity		Proposed Allowable Emissions				
Pollutant	lb/hr	tpy	lb/hr	Other Units (specify)	tpy		
		Criteria Air	Pollutants				
PM	0.09	0.40		0.13 g/kW-hr	0.014		
PM ₁₀	0.09	0.40		0.13 g/kW-hr	0.014		
PM _{2.5} Total (filterable + condensable)	0.09	0.40		0.13 g/kW-hr	0.014		
SO _x	3.7E-03	0.016			0.0006		
NO _x	2.64	11.6		3.8 g/kW-hr	0.40		
СО	0.63	2.74		0.9 g/kW-hr	0.094		
VOC	0.069	0.30		0.1 g/kW-hr	0.010		
Pb	1.9E-06	8.3E-06			2.8E-07		
GHG	401	1,756			60		
	Н	azardous or Otl	her Air Pollutant	s			
		_	_				

Potential Emissions Calculation Basis:	Vendor Data

Proposed Allowable Emissions Calculation Basis: Vendor Data and 300 hrs/yr

Part II: Regulatory Standards

Enter the regulatory standard(s) and the proposed allowable emissions for each pollutant emitted by the unit using the same units (e.g., ppmvd, lb/MMBTU, lb/hour, lb/day, etc.). More than one regulatory standard will often apply to a unit for a particular pollutant, list all that apply. Enter the regulatory citation(s) for the standard(s).

NOTE: The applicant should be aware of any existing regulatory standard applicable to the unit and should not propose allowable emissions in excess of the regulatory standard(s).

Pollutant	Regulatory Standard(s)	Proposed Allowable Emissions	Regulatory Citation(s)			
	(specify units)	(specify units)				
	Crite	eria Air Pollutants				
PM	0.2 g/kW-hr	0.13 g/kW-hr	40 CFR 60.4205(c)			
PM ₁₀	0.2 g/kW-hr	0.13 g/kW-hr	40 CFR 60.4205(c)			
PM _{2.5} Total (filterable + condensable)	0.2 g/kW-hr	0.13 g/kW-hr	40 CFR 60.4205(c)			
SO _x						
NO _x	4.0 g/kW-hr (NOx + VOC)	3.8 g/kW-hr	40 CFR 60.4205(c)			
СО	3.5 g/kW-hr	0.9 g/kW-hr	40 CFR 60.4205(c)			
voc	4.0 g/kW-hr (NOx + VOC)	0.1 g/kW-hr	40 CFR 60.4205(c)			
Pb						
GHG						
	Hazardous	s or Other Air Pollutants				
	(Standards ot	her than RCSA §22a-174-	29)			

Part III: Attachments

Please check the attachment being submitted as verification that all applicable attachments have been submitted with this application form. When submitting such documents, please label the documents as indicated in this Part (e.g., Attachment E212-A, etc.) and be sure to include the applicant's name.

\boxtimes	Attachment E212-A:	Sample Calculations- Submit sample calculations used to determine all emissions rates, excluding GHG. See Attachment E212-C for GHG emissions. REQUIRED
	Attachment E212-B:	RCSA section 22a-174-29 Hazardous Air Pollutants Compliance – Submit a completed CTMASC spreadsheet, or equivalent, to demonstrate compliance with RCSA section 22a-174-29. REQUIRED
	Attachment E212-C:	Greenhouse Gas Emissions – Submit a completed CO ₂ Equivalents Calculator Spreadsheet, or equivalent, used to quantify Greenhouse Gas emissions, REQUIRED

ATTACHMENT F - PREMISES INFORMATION FORM

Provided on the following pages is a completed Premises Information form (DEEP-APP-217).



Attachment F: Premises Information Form

Applicant Name: CPV Towantic, LLC		DEEP USE ONLY
Applicant Hame: Of the Wanter, 220		DEEP OSE ONE
	App. No.:	
Complete this form in accordance with the instructions (DEED NCD INCT 217) to	Αρρ. Νο	
Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-217) to		
ensure the proper handling of your application. Print or type unless otherwise noted.		

Complete Parts I through VI of this form, as applicable, for only the equipment which is located at the premises prior to the submittal of this application package. Unit(s) or modifications that are the subject of this application package are addressed in Part VII of this form.

Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the Day at 860-424-4152

Note: This form is not required if you indicated in Part IV.8 of the *Permit Application for Stationary Sources of Air Pollution New Source Review Form (DEEP-NSR-APP-200) that* the premises is operating under the General Permit to Limit Potential to Emit.

Part I: Premises Information Summary

Answer each question unless directed to do otherwise. Complete the Part(s) indicated as well as Part VII.

	Question	Check One	If Yes
A.	Is this a new premises? (i.e. no air pollution emitting equipment on site)	⊠ Yes □ No	Skip Questions B through G and continue on to Part VII of this form.
В.	Is the premises operating under a Title V permit?	☐ Yes ☐ No	Permit Number: Issue Date: Skip Questions C through G and continue on to Part VII of this form.
C.	Is there any equipment operating under a New Source Review Permit (permit) or Air Registration (registration) at the premises?	☐ Yes ☐ No	Complete Part II of this form.
D.	Are there any external combustion units, automotive refinishing operations, nonmetallic mineral processing equipment, emergency engines or surface coating operations operating under RCSA section 22a-174-3b at the premises?	☐ Yes ☐ No	Complete Part III of this form.
E.	Are there any external combustion units, automotive refinishing operations, nonmetallic mineral processing equipment, emergency engines or surface coating operations operating under RCSA section 22a-174-3c at the premises?	☐ Yes ☐ No	Complete Part IV of this form.
F.	Are there any emissions units operating at the premises that have potential emissions of any air pollutant below the permitting thresholds of RCSA section 22a-174-3a which have not been captured in Question E?	☐ Yes ☐ No	Complete Part V of this form.
G.	Is the premises operating under a premises-wide annual limitation (other than GPLPE or RCSA section 22a-174-3c) for any air pollutant?	☐ Yes ☐ No	Complete Part VI of this form.

Part II: Permits and Registrations

Complete this part, if "Yes" was answered to Question C in Part I of this form. List each piece of equipment operating under a permit or registration located at this premises. Provide the potential emissions for each pollutant as limited by such permit or registration in tons per year for each unit. Calculate the total potential emissions from equipment operating under permits or registrations for the premises.

Permit / Registration	Equipment Description	Permit/Registration Issuance Date	ion Potential Emissions from Permit or Registration (tpy						ру)		
Number		issualice Date	PM	PM ₁₀	PM _{2.5} *	SO _x	NO _x	VOC	СО	Pb	GHG
Totals											

^{*} $PM_{2.5}$ should include filterable $PM_{2.5}$ plus condensable $PM_{2.5}$

Part III: Units Operating Under RCSA section 22a-174-3b

Complete this part, if "Yes" was answered to Question D in Part I of this form. Enter the following information for each unit operating under RCSA section 22a-174-3b. Such units may include external combustion units, automotive refinishing operations, nonmetallic mineral processing equipment, emergency engines or surface coating operations. Calculate the total potential emissions from the equipment as limited by RCSA section 22a-174-3b.

Equipment Type	Const. Date	Maximum Rated Capacity of Equipment	Potential Emissions as Limited by RCSA section 22a-174-3b (tpy)								
			PM	PM ₁₀	PM _{2.5} *	SO _x	NO _x	voc	СО	Pb	GHG
1	Γotals										

[^] PM _{2.5} should include filte	rable PM _{2.5} plus condensable PM _{2.5}	
Emissions Calculation Basis:		

Part IV: Units Operating Under RCSA section 22a-174-3c

Complete this part, if "Yes" was answered to Question E in Part I of this form. Check off the types of equipment that is operating at the premises under RCSA section 22a-174-3c. Check all that apply. Calculate the total potential emissions from the equipment limited by RCSA section 22a-174-3c for each pollutant.

Equipment Operating Under I 22a-174-3c (Check all that app	Fuels Used (Check all that apply)	Number of Fuels Used	Potential Emissions for Each Pollutant (tpy)	Total Potential Emissions for Each Pollutant (tpy)
External Combustion Unit	☐ Gaseous Fuel ☐ Distillate Oil or a blend of distillate oil and biodiesel fuel ☐ Residual Oil or a blend of residual oil		15	
Emergency Engine	and biodiesel fuel (boiler only) Propane			
Nonmetallic Mineral Processing Equipment	N/A	N/A	15	
Automotive Refinishing Operation	N/A	N/A	15	
Surface Coating Operation	N/A	N/A	15	
		Totals for Eac	h Pollutant (tpy)	

Potential emissions of any individual air pollutant for a stationary source operating under RCSA section 22a-174-3c is less than 15 tons per year unless otherwise determined by a permit or order. Please be aware that if different units are operating with the same fuel, the most stringent limitation for that fuel applies to the premises.

Part V: Other Equipment

Complete this part, if "Yes" was answered to Question F in Part I of this form. Only include units which have not been captured elsewhere on this form and have potential emissions between 5 and 15 tons per year of any individual pollutant. If it is determined that premises-wide annual emissions of a pollutant are within 90% of major source thresholds, include all units with potential emissions greater than one ton per year on this table. Calculate the total potential emissions.

Equipment Description	Const. Date	Maximum Rated Capacity of Equipment	Potential Emissions as Defined in RCSA section 22a-174-1(91) (tpy)								
			PM	PM ₁₀	PM _{2.5} *	SO _x	NO _x	voc	СО	Pb	GHG
1	Totals .										

* PM _{2.5} should include filterab	e PM _{2.5} plus condensable PM _{2.5}
Emissions Calculation Basis:	

Part VI: Premises-Wide Annual Limitations

Complete this part, if "Yes" was answered to Question G in Part I of this form. List all premises-wide annual limitations applicable to this premises that appear in a permit or order. **Do not include limitations under RCSA section 22a-174-3c.**

Permit or Order Number	Pollutant Limited	Enforceable Premises-Wide Limitation (tpy)

Part VII: Premises Summary

Ozone Non-Attainment Status:	\boxtimes	Serious	Severe
PM _{2.5} Attainment Status:	\boxtimes	Attainment	Non-Attainment

A. Current Premises Potential Emissions

List the applicable potential emissions totals from Parts II through VI, if required to complete those sections. Calculate the *Total Current Premises Potential Emissions* applying any applicable premise-wide limitations. A source that answered "Yes" to Question A or B in Part I of this form would only complete the last three rows of the table below.

Form Part	Part Description				Potent	tial Emission	ons (tpy)			
	J	PM	PM ₁₀	PM _{2.5} *	SO _x	NO _x	VOC	СО	Pb	GHG
Part II	Total Potential Emissions as Limited by Permit or Registration									
Part III	Total Potential Emissions as Limited by RCSA section 22a-174-3b									
Part IV	Total Potential Emissions as Limited by RCSA section 22a-174-3c									
Part V	Total Potential Emissions from Other Sources									
Part VI	Part VI Applicable Premises-Wide Annual Limitations									
Total Cu	rrent Premises Potential Emissions									
Major S	Major Source Thresholds (severe/serious)		100	100	100	25/50	25/50	100	100	100,000
Exis	Existing Major Stationary Source?									

 $^{^{\}star}$ PM_{2.5} should include filterable PM_{2.5} plus condensable PM_{2.5}

If any pollutant is checked above, this premises ${\it is}$ an existing major stationary source.

If no pollutants are checked above, this premises is not an existing major stationary source.

Go on to Part VII.B.

B. Proposed Project Allowable Emissions

List the proposed allowable emissions from the proposed project for the equipment or modifications included in this application package from *Attachment E: Unit Emissions (DEEP-AIR-APP-212)*.

Totals		Pollutant Emissions (tpy)									
	PM	PM ₁₀	PM _{2.5} *	SO _x	NO _x	VOC	СО	Pb	GHG		
Proposed Allowable Emissions	154.7	154.7	154.7	39.7	194.7	49.9	136.2	0.03	2,678,612		
Major Source Thresholds (severe/serious)	100	100	100	100	25/50	25/50	100	100	100,000		
Project Major Source?	\boxtimes	\boxtimes	\boxtimes		\boxtimes		\boxtimes				

^{*} PM_{2.5} should include filterable PM_{2.5} plus condensable PM_{2.5}

If any pollutant is checked above, the proposed project is major in and of itself.

If no pollutants are checked above, the project **is not** major in and of itself.

Go on to Part VII.C.

C. New Premises Total Emissions

List the Current Premises Potential Emissions and the Proposed Allowable Emissions values from Parts VII.A and B. Calculate the New Premises Total Emissions.

Totals		Pollutant Emissions (tpy)									
Totals	PM	PM ₁₀	PM _{2.5} *	SO _x	NO _x	VOC	СО	Pb	GHG		
Total Current Premises Potential Emissions (Part VII.A)	0	0	0	0	0	0	0	0	0		
Proposed Allowable Emissions (Part VII.B)	154.7	154.7	154.7	39.7	194.7	49.9	136.2	0.03	2,678,612		
New Premises Total Emissions	154.7	154.7	154.7	39.7	194.7	49.9	136.2	0.03	2,678,612		
Major Source Thresholds (severe/serious)	100	100	100	100	25/50	25/50	100	100	100,000		
Premises Major Source After Project?		\boxtimes	\boxtimes		\boxtimes		\boxtimes		\boxtimes		

^{*} PM_{2.5} should include filterable PM_{2.5} plus condensable PM_{2.5}

If any pollutant is checked above, the premises **will be** considered a major stationary source after the approval of the proposed project.

If no pollutants are checked above, the premises will not be considered a major stationary source after the approval of the proposed project.

Go on to Part VII.D.

D. Form Requirements

Based on the results in Parts VII.A through VII.C of this form the following forms are required to be completed for each pollutant:

Premises Major Stationary Source?	Stationary Major Stationary is Major		Forms Required to Be Completed
Part VII.A	Part VII.B	Part VII.C	
Yes	Yes		 Attachment H: Major Modification Determination Form Attachment I: Prevention of Significant Deterioration of Air Quality (PSD) Program Form Attachment J: Non-Attainment Review Form (for NOx, VOC or PM_{2.5} only)
Yes	No		Attachment H: Major Modification Determination Form (This form will direct you to complete Attachments I or J, if required.)
No	Yes		 Attachment I: Prevention of Significant Deterioration of Air Quality (PSD) Program Form Attachment J: Non-Attainment Review Form (for NOx, VOC or PM_{2.5} only)
No	No	1	Attachments H, I and J are not required.
		Yes	If not already operating under one, the applicant is required to apply for a Title V permit within 12 months of becoming a major stationary source or the applicant must limit premises potential emissions by obtaining an approval of registration to operate under the General Permit to Limit Potential to Emit (GPLPE).

ATTACHMENT G - BEST AVAILABLE CONTROL TECHNOLOGY ANALYSIS

The following supplemental BACT forms are provided with this application. Attachment G2, Cost/Economic Impact Analysis form DEEP-NSR-APP-214c, was only completed for those sources and pollutants for which the top-level of control was not selected.

- Attachment G Analysis of Best Available Control Technology (DEEP-NSR-APP-214a)
 - o AB CO Emissions
 - AB NO_x Emissions
 - o AB VOC Emissions
 - AB PM Emissions
 - AB SO₂ Emissions
 - AB GHGs Emissions
 - AB H₂SO₄ Emissions
 - CT#1 / DB#1 CO Emissions
 - CT#1 / DB#1 NO_x Emissions
 - CT#1 / DB#1 VOC Emissions
 - CT#1 / DB#1 PM Emissions
 - CT#1 / DB#1 SO₂ Emissions
 - O CT#1 / DB#1 GHGs Emissions
 - \circ CT#1 / DB#1 H₂SO₄ Emissions
 - CT#1 / DB#1 NH₃ Emissions
 - CT#2 / DB#2 CO Emissions
 - o CT#2 / DB#2 − NO_x Emissions
 - o CT#2 / DB#2 VOC Emissions
 - o CT#2 / DB#2 PM Emissions
 - CT#2 / DB#2 SO₂ Emissions
 - o CT#2 / DB#2 GHGs Emissions
 - \circ CT#2 / DB#2 H₂SO₄ Emissions
 - CT#2 / DB#2 NH₃ Emissions
- Attachment G1 Background Search Existing BACT Determinations (DEEP-NSR-APP-214b)
- Attachment G2 Cost/Economic Impact Analysis (DEEP-NSR-APP-214c)
 - Auxiliary Boiler CO Emissions
 - Auxiliary Boiler NO_x Emissions
 - Auxiliary Boiler VOC Emissions



- Combustion Turbine #1/ Duct Burner #1 / Combustion Turbine #2/Duct Burner #2 GHG Emissions
- Attachment G3 Summary of Best Available Control Technology Review (DEEP-NSR-APP-214d)

Also provided is a control technology analysis to satisfy both the LAER and BACT requirements of the Project.



LOWEST ACHIEVABLE EMISSION RATE ANALYSIS

The Project is located in an area designated as non-attainment for ozone (O_3) and has potential NO_x emissions above the new source major source threshold. Therefore, the Project must implement LAER controls to minimize NO_x emissions.

Definition of LAER

LAER is defined under 40 Code of Federal Regulations (CFR) 51.165(a)(1)(xiii) as the more stringent rate of emissions based on the following:

- The most stringent emissions limitation which is contained in the implementation plan of any State for such class or category of stationary source, unless the owner or operator of the proposed stationary source demonstrates that such limitations are not achievable; or
- The most stringent emissions limitation which is achieved in practice by such class or category of stationary sources. In no event shall the application of the term permit a proposed new or modified stationary source to emit any pollutant in excess of the amount allowable under an applicable new source standard of performance.

LAER Process

As noted above, LAER is the more stringent of any limitation in a state's approved implementation plan or an emissions limitation which is achieved in practice by such class or category of stationary sources. For combined-cycle combustion turbine projects, the most stringent NO_x emissions can be found in previously permitted projects subject to PSD or NNSR requirements. In order to identify the "most stringent emissions limitation which is achieved in practice" by a combined-cycle combustion turbine facility, numerous sources of information were evaluated. These sources included the following:

- USEPA's Reasonably Achievable Control Technology (RACT), BACT, LAER Clearinghouse (RBLC);
- The California Air Resources Board (CARB) BACT Clearinghouse;
- USEPA regional air permitting websites; and
- State environmental agency websites.

In addition to these sources of information, additional publicly available information obtained through Tetra Tech's experience, such as permits for individual projects not listed in the RBLC or agency websites, were also included in the analysis. This research was conducted for the Project's emission sources that emit NO_x including:

- Combined-cycle-combustion turbines and duct burners;
- Auxiliary boiler; and
- Emergency engines.

Following is a summary of the LAER determination for NO_x emissions for each of the above listed emission sources.

Combined-Cycle Combustion Turbines and Duct Burners

The LAER analysis for the combustion turbines and duct burners is combined, as the duct burners cannot operate without the combustion turbines in operation. Since the combustion turbines can operate with and without duct firing, LAER emission rates were reviewed for both of these operating scenarios. Provided in Table G-1 is a summary of recently permitted BACT and LAER NO_x emission limits for combined-cycle combustion turbine



projects larger than 100 MW firing natural gas and, to the extent available, ULSD backup. Projects with LAER permitted emission rates are noted as such in the table.

Table G-1: Combustion Turbine BACT and LAER NO_x Rate Emission Limits

Facility	Location	Permit Date	Turbine	NO _x ^{a,b} (ppm)
Green Energy Partners / Stonewall	Leesburg, VA	04/30/2013	GE 7FA	2.0 (w/ and w/o DF) LAER
Brunswick County Power	Freeman, VA	05/23/2012	Mitsubishi M501 GAC	2.0 (w/ and w/o DF)
Carroll County Energy	Washington Twp., OH	11/5/2013	GE 7FA	2.0 (w/ and w/o DF)
Renaissance Power	Carson City, MI	11/1/2013	Siemens 501 FD2	2.0 (w/ and w/o DF)
Langley Gulch Power	Payette, ID	08/14/2013	Siemens SGT6-5000F	2.0 (w/ and w/o DF)
Kleen Energy (gas firing)	Middletown, CT	02/25/2008	Siemens SGT6-5000F	2.0 (w/ and w/o DF)
Kleen Energy (ULSD firing)	Middletown, CT	02/25/2008	Siemens SGT6-5000F	5.9 (w/ and w/o DF)
Oregon Clean Energy	Oregon, OH	06/18/2013	Siemens SCC6-8000H	2.0 (w/ and w/o DF)
TECO Polk Power 2	Mulberry, FL	05/15/2013	GE 7FA	2.0 (w/ and w/o DF)
Hess Newark Energy	Newark, NJ	11/01/2012	GE 7FA.05	2.0 (w/ and w/o DF) LAER
Cricket Valley Energy Center	Dover, NY	09/27/2012	"F" Class	2.0 (w/ and w/o DF) LAER
Pioneer Valley Generation Company (gas firing)	Westfield, MA	04-12-2012	Mitsubishi 501G	2.0 (w/o DF) LAER
Pioneer Valley Generation Company (ULSD firing)	Westfield, MA	04-12-2012	Mitsubishi 501G	5.0 (w/o DF) LAER

^a Concentration in ppm is parts per million by volume, dry, at 15 percent O₂.

The permitted NO_x emission rate during natural gas firing for all of the projects in Table G-1 is 2.0 ppmvd at 15% O_2 including a wide range of turbine models and sizes. This emission rate has been achieved in practice at several facilities, including the Kleen Energy facility in Connecticut. For these reasons, LAER for NO_x emissions



^b DF refers to duct firing

from the two combined-cycle combustion turbines and duct burners was selected as 2.0 ppmvd at 15% O₂ during natural gas firing for all modes of operation.

For oil firing emission limits, there are far fewer recently permitted combined-cycle combustion turbine projects. The Pioneer Valley Generation project includes firing of ULSD as backup fuel and was required to meet LAER for NO $_x$ emissions. The permitted NO $_x$ emission rate for ULSD firing for the Pioneer Valley Generation project is 5.0 ppmvd at 15% O $_2$. The most recent Connecticut project (Kleen Energy) is permitted at 5.9 ppmvd during ULSD firing. The GE NO $_x$ emissions guarantee for the Model 7HA01 firing ULSD with installation of SCR and oxidation catalyst controls is 5.0 ppmvd at 15% O $_2$. This emission level is at or below the lowest permitted limits for oil firing and no additional control measures are available to reduce NO $_x$ emissions from the combined-cycle combustion turbines and duct burners. For these reasons, LAER for NO $_x$ emissions for ULSD firing was selected as 5.0 ppmvd at 15% O $_2$.

Auxiliary Boiler

Provided in Table G-2 is a summary of recently permitted BACT and LAER NO_x emission limits for auxiliary boilers rates less than 100 MMBtu/hr firing natural gas. Projects with LAER permitted emission rates are noted as such in the table.

Table G-2: Auxiliary Boiler BACT and LAER NO_x Rate Emission Limits

Facility	Location	Permit Date	Controls ^a	NO _x ^b (ppm)
Green Energy Partners / Stonewall	Leesburg, VA	04/30/2013	Ultra LNB	9.0 (LAER)
Brunswick County Power	Freeman, VA	05/23/2012	Ultra LNB	9.0
Carroll County Energy	Washington Twp., OH	11/5/2013	LNB	16.4
Renaissance Power	Carson City, MI	11/1/2013	LNB	30
Kleen Energy	Middletown, CT	02/25/2008	LNB	37
Oregon Clean Energy	Oregon, OH	06/18/2013	LNB	16.4
Hess Newark Energy	Newark, NJ	11/01/2012	Ultra LNB	9.0
Cricket Valley Energy Center	Dover, NY	09/27/2012	Ultra LNB	9.0

^aLNB = low NO_x burner.

The proposed auxiliary boiler will fire natural gas as the sole fuel and will be equipped with ultra low-NO_x burners; this is the most stringent level of control identified in Table G-2. The vendor guaranteed NO_x emission rate for this control scenario are 9.0 ppmvd at 3% O₂. The vendor guaranteed NO_x emission rate is equal to the lowest permitted emission rate in Table G-2. For these reasons, LAER for NO_x emissions from the auxiliary boiler was selected as 9.0 ppmvd at 3% O₂.

Emergency Engines

The Project will include a diesel-fired emergency generator engine and a diesel-fired fire pump engine. These engines are subject to the NO_x and non-methane hydrocarbon emission standards under New Source Performance Standard (NSPS) Subpart IIII. A review of previously permitted projects did not identify any



^b Concentration in ppm is parts per million by volume, dry, at 3 percent O₂.

emergency engines permitted below the NSPS Subpart IIII emission standards. To satisfy LAER for the emergency engines, the Project will install engines that meet the NSPS Subpart IIII emission standards. These engines will also be operated in accordance with Section 22a-174-3b(e) of the Connecticut regulations including firing ULSD and limiting operation to no more than 300 hours during any 12 month rolling period for each engine.

BEST AVAILABLE CONTROL TECHNOLOGY ANALYSIS

The Project must install PSD BACT controls for emissions of NO_x , VOC, CO, $PM/PM_{10}/PM_{2.5}$, H_2SO_4 , and GHGs. Additionally, DEEP BACT must be satisfied for SO_2 and NH_3 emissions. For NO_x emissions, LAER controls will be installed, which are by definition the top level of control available and, therefore, satisfy BACT requirements. The following control technology analysis satisfies the BACT requirements for VOC, CO, $PM/PM_{10}/PM_{2.5}$, H_2SO_4 , GHGs, SO_2 and NH_3 emissions for the Project.

Definition of BACT

The DEEP regulations define BACT under Section 22a-174-1 as:

"an emission limitation, including a limitation on visible emissions, based upon the maximum degree of reduction for each applicable air pollutant emitted from any proposed stationary source or modification which the commissioner, on a case-by-case basis, determines is achievable in accordance with section 22a- 174-3a of the Regulations of Connecticut State Agencies. BACT may include, without limitation, the application of production processes, work practice standards or available methods, systems, and techniques, including fuel cleaning or treatment, the use of clean fuels, or innovative techniques for the control of such air pollutant."

When determining whether or not an emission limitation is achievable, the DEEP must take into account the following factors in accordance with Section 22a-174-3a(j):

- 1. A previous BACT approval for a similar or a representative type of source;
- 2. Technological limitations; and
- 3. Energy, economic and environmental impacts.

In no event shall the application of BACT result in emissions of any pollutant greater than an emission standard pursuant to 40 CFR Parts 60 and 61 or any State Implementation Plan (SIP).

BACT Process

The USEPA provides guidance for conducting a BACT analysis in which all control technologies for a subject pollutant and emission source are identified and ranked from most to least efficient. An evaluation of each technology is then conducted to determine if it is technically feasible for the proposed project and if so, the resulting energy, environmental and economic impacts from its application. The most efficient technology that is determined to be technically feasible and does not result in adverse energy, environmental and/or economic impacts, is selected as BACT.

The BACT process is described in USEPA's draft document titled "New Source Review Workshop Manual: Prevention of Significant Deterioration and Nonattainment Area Permitting" (NSR Manual) (USEPA, 1990), which acts as a non-binding guidance document for USEPA, state permitting authorities and permit applicants during the permitting process. The process involves the following steps:

- Step 1: Identify all potential control technologies applicable to the pollutant and process.
- Step 2: Determine the technical feasibility of each control technology identified under Step 1 as applicable to the Project and eliminate those that are infeasible.



- Step 3: Rank the technically feasible control technologies based on overall control efficiency.
- Step 4: Evaluate the most effective control technology based on economic, energy, and environmental
 factors. If the most effective control technology causes unacceptable economic, energy, and/or
 environmental impacts, the next most effective technology is evaluated. This process continues
 until a technology is selected as BACT.
- Step 5: Select the most effective option not eliminated in Steps 2 4 above as BACT and determine the corresponding emission limit for the subject pollutant and emission source.

Per this guidance, if a project elects to implement the most efficient level of control that is technically feasible as identified in Steps 1 and 2, then no further analysis is required.

Sources Reviewed To Identify BACT

Steps 1 and 2 in the BACT process are the identification of all available control technologies and the top level of control for each subject pollutant from each source type for a given project. Per USEPA guidance, BACT may be achieved from a change in raw materials, a process modification, and/or add-on pollution controls. For the Project, the cleanest raw materials (natural gas and ULSD) and lowest emitting fossil-fuel generating process (combined-cycle combustion turbines) have been selected. Therefore, the identification of the top level of control focused on add-on pollution controls.

Per USEPA guidance, BACT is expressed as an emission rate and the top level of control is determined from the following:

- The most stringent emissions limitation which is contained in any SIP for such class or category of stationary source; or
- The most stringent emissions limitation which is achieved in practice by such class or category of stationary source.

In order to identify the "most stringent emissions limitation which is achieved in practice" by a combined-cycle combustion turbine facility, numerous sources of information were evaluated. These sources included the following:

- USEPA's RBLC;
- The CARB BACT Clearinghouse;
- · USEPA regional air permitting websites; and
- State environmental agency websites.

In addition to these sources of information, additional publicly available information obtained through Tetra Tech's experience, such as permits for individual projects not listed in the RBLC or agency websites, were also included in the analysis. This research was conducted for the Project's emission sources that emit VOC, CO, PM/PM₁₀/PM_{2.5}, H₂SO₄, GHGs, SO₂ and NH₃ including:

- Combined-cycle combustion turbines and duct burners;
- Auxiliary boiler;
- Emergency engines; and
- Fugitive GHG emissions.



Combined-Cycle Combustion Turbines and Duct Burners

The BACT analysis for the combustion turbines and duct burners is combined as the duct burners cannot operate without the combustion turbines in operation. Since the combustion turbines can operate with and without duct firing, BACT emission rates were reviewed for both of these operating scenarios. Provided in Table G-3 is a summary of recently permitted VOC, CO, PM/PM₁₀/PM_{2.5}, GHGs and NH₃ emission limits for combined-cycle combustion turbine projects larger than 100 MW. The emission limits provided in Table G-3 serve as the basis for determining the "most stringent emissions limitation which is achieved in practice" for large combined-cycle combustion turbines.

Volatile Organic Compounds

VOC is emitted from combustion turbines and duct burners as a result of incomplete oxidation of the fuel. VOC emissions can be minimized by the use of proper combustor design and good combustion practices. Additional reductions in VOC emissions may be achieved through application of an oxidiation catalyst. All of the permitted VOC emission rates are based upon the turbine vendor guaranteed emission rate with installation of an oxidation catalyst.

The GE guaranteed maximum VOC emission rate for their Model 7AH.01 equipped with an oxidation catalyst is 1.0 ppmvd at $15\% \text{ O}_2$ without duct firing and 2.0 ppmvd at $15\% \text{ O}_2$ with duct firing. These VOC emission rates are consistent with the recently permitted emission rates listed in Table G-3, including the VOC LAER for Green Energy Partners and Cricket Valley Energy. These emission rates represent the lowest vendor emission guarantees provided for the GE Model 7HA.01 and will be achieved through good combustion practices and an oxidation catalyst. No additional control measures are available to reduce VOC emissions from the combined-cycle combustion turbines and duct burners. For these reasons, BACT for VOC emissions from the two combined-cycle combustion turbines and duct burners was selected as 1.0 ppmvd at $15\% \text{ O}_2$ without duct firing and 2.0 ppmvd at $15\% \text{ O}_2$ with duct firing.

For oil firing emission limits, there are far fewer recently permitted combined-cycle combustion turbine projects. The Pioneer Valley Generation project includes firing of ULSD and was required to meet state BACT requirements for VOC emissions. The permitted VOC emission rate for oil firing of the Pioneer Valley Generation project is 6.0 ppmvd at 15% O_2 . The Kleen Energy project was permitted at a lower VOC emission rate for oil firing at 3.6 ppmvd at 15% O_2 . The GE VOC emission guarantee for the Model 7HA.01 firing ULSD with installation of an oxidation catalyst is 2.0 ppmvd at 15% O_2 . This emission level is below the lowest permitted limits for oil firing and no additional control measures are available to reduce VOC emissions from the combined-cycle combustion turbines and duct burners. For these reasons, BACT for VOC emissions for oil firing was selected as 2.0 ppmvd at 15% O_2 .

Carbon Monoxide

CO is emitted from combustion turbines and duct burners as a result of incomplete oxidation of the fuel. CO emissions can be minimized by the use of proper combustor design and good combustion practices. The most stringent CO add-on pollution control technology is an oxidation catalyst, which is a passive reactor containing a platinum catalyst that oxidizes the CO to CO₂.

With the exception of the TECO Polk Power project, all of the projects listed in Table G-3 have been permitted with an oxidation catalyst to achieve the permitted CO emission levels. Accordingly, the Project is proposing to use an oxidation catalyst to control CO emissions from the combustion turbines and duct burners.



Table G-3: Combustion Turbine Permitted CO, PM, GHG and NH₃ Emission Rate Limits

Facility	Location	Permit Date	Turbine	VOC ^a (ppm)	CO ^a (ppm)	PM ^b (lb/MMBtu)	GHG (lb/MW-hr)	GHG (Btu/kw-hr)	NH ₃ ^a (ppm)
Green Energy Partners / Stonewall	Leesburg, VA	04/30/2013	GE 7FA	1.0 (w/o DF ^c) 2.4 (w/ DF) LAER	2.0 (w/ & w/o DF)	0.00334 (w/ & w/o DF)	903	7,340 ^d (gross w/o DF) 7,780 ^d (gross w/ DF)	5.0 (w/ & w/o DF)
Brunswick County Power	Freeman, VA	05/23/2012	Mitsubishi M501 GAC	0.7 (w/o DF) 1.6 (w/ DF)	1.5 (w/o DF) 2.4 (w/ DF)	0.0033 (w/o DF) 0.0047 (w/ DF)	920	7,500 ^d (net w/o DF)	N/A
Carroll County Energy	Washington Twp., OH	11/5/2013	GE 7FA	1.0 (w/o DF) 2.0 (w/ DF)	2.0 (w/ & w/o DF)	0.0108 (w/o DF) 0.0078 (w/ DF)	859	7,350 ^d (net w/o DF)	N/A
Renaissance Power	Carson City, MI	11/1/2013	Siemens 501 FD2	2.0 (w/ and w/o DF)	2.0 (w/ & w/o DF)	0.0042 (w/ & w/o DF)	1,000	N/A	N/A
Langley Gulch Power	Payette, ID	08/14/2013	Siemens SGT6-5000F	2.0 (w/ and w/o DF)	2.0 (w/ & w/o DF)	0.0053 (w/ & w/o DF)	N/A	N/A	5.0 (w/ & w/o DF)
Kleen Energy (gas firing)	Middletown, CT	02/25/2008	Siemens SGT6-5000F	5.0 (w/ and w/o DF)	0.9 (w/o DF) 1.7 (w/ DF)	0.0051 (w/o DF) 0.0059 (w/ DF)	N/A	N/A	2.0 (w/ & w/o DF)
Kleen Energy (ULSD firing)	Middletown, CT	02/25/2008	Siemens SGT6-5000F	3.6 (w/ and w/o DF)	1.8	0.0269	N/A	N/A	5.0 (w/ & w/o DF)
Oregon Clean Energy	Oregon, OH	06/18/2013	Siemens SCC6-8000H	1.0 (w/o DF) 1.9 (w/ DF)	2.0 (w/ & w/o DF)	0.0047 (w/o DF) 0.0055 (w/ DF)	833	7,227 ^d (net w/o DF)	N/A
TECO Polk Power 2	Mulberry, FL	05/15/2013	GE 7FA	1.4 (no ox. cat)	4.1 (no ox. cat)	N/A	877	N/A	5.0 (w/ & w/o DF)
Hess Newark Energy	Newark, NJ	11/01/2012	GE 7FA.05	1.0 (w/o DF) 2.0 (w/ DF)	2.0 (w/ & w/o DF)	0.0047 (w/o DF) 0.0058 (w/ DF)	887	7,522 ^d (net w/o DF)	5.0 (w/ & w/o DF)
Cricket Valley Energy Center	Dover, NY	09/27/2012	"F" Class	1.0 (w/o DF) 2.0 (w/ DF) LAER	2.0 (w/ & w/o DF)	0.005 (w/o DF) 0.006 (w/ DF)	910	7,605 ^d (net w/o DF)	5.0 (w/ & w/o DF)

Facility	Location	Permit Date	Turbine	VOC ^a (ppm)	CO ^a (ppm)	PM ^b (lb/MMBtu)	GHG (lb/MW-hr)	GHG (Btu/kw-hr)	NH ₃ ^a (ppm)
Pioneer Valley Generation Company (gas firing)	Westfield, MA	04/12/2012	Mitsubishi 501G	1.0 (w/o DF) (state BACT)	2.0 (w/ & w/o DF)	0.0040 (w/ & w/o DF)	895 (all fuels)	N/A	2.0 (w/ & w/o DF)
Pioneer Valley Generation Company (ULSD firing)	Westfield, MA	04/12/2012	Mitsubishi 501G	6.0 (w/o DF) (state BACT)	6.0	0.014			2.0

^a Concentration in ppm is parts per million by volume, dry, at 15 percent O₂.



^b Concentration in pounds per million Btu heat input (HHV), except as noted, including front (filterable) and back-half (condensable) PM. All PM is considered to be PM_{2.5}.

^c DF = duct firing.

^d At full load and corrected to ISO conditions (59°F, absolute pressure of 14.696 kPa and 60% relative humidity)

A review of recently permitted projects shows that during natural gas firing, most are permitted at an emission rate at or above 2.0 ppmvd corrected to 15% O₂ on a 1-hour averaging basis during all operating periods. A few projects have marginally lower permitted limits without duct firing and one project has a lower limit with duct firing, but these projects have a different combustion turbine than the GE 7HA.01. The Kleen Energy project's lower CO BACT limit comes at the expense of VOC, for which its BACT limit is considerably higher than most limits in the RBLC database. Based upon GE guarantees, the proposed CO BACT emission rate during gas firing is 0.9 ppmvd at 15% O₂ without duct firing and 1.7 ppmvd at 15% O₂ with duct firing. Although this emission rate is marginally higher than a couple of recently permitted projects, the USEPA's Environmental Appeals Board (EAB) decision² on March 14, 2014 regarding the appeal of the La Paloma Energy Center, LLC PSD permit makes clear that minor differences in permitted PSD emission rates are allowable to account for different technologies, and that turbine model selection cannot be taken into account when determining BACT for a project. The proposed CO BACT emission rate during natural gas firing represents the vendor guarantee with an oxidation catalyst and is consistent with the majority of recently permitted projects.

Two CO BACT determinations for oil firing are provided in Table G-3. The Pioneer Valley Generation project is limited to 6.0 ppmvd at 15% O_2 and the Kleen Energy project is limited to 1.8 ppmvd at 15% O_2 . The GE guaranteed CO emission rate for oil firing with an oxidation catalyst is 2.0 ppmvd at 15% O_2 . The GE guarantee is marginally higher than the Kleen Energy CO limit which, as discussed for natural gas firing, is associated with a much higher VOC limit. Therefore, CO BACT for oil firing is proposed to be 2.0 ppmvd at 15% O_2 .

SO₂ and H₂SO₄ Emissions

The most stringent level of control for SO_2 and H_2SO_4 emissions from combustion sources is the firing of pipeline quality natural gas. The USEPA defines pipeline quality natural gas in the Acid Rain regulations under 40 CFR 72.2 as natural gas that contains 0.5 grains or less of total sulfur per 100 standard cubic feet (gr S/100 scf). Therefore, BACT for SO_2 emissions from the combustion turbines is utilizing pipeline quality natural gas as the primary fuel. ULSD is proposed as backup fuel for the combustion turbines to ensure fuel availability at all times. ULSD will be fired in the emergency engines so that these emergency safety devices have a standalone source of fuel during an emergency. The sulfur content of ULSD is limited to no greater than 15 parts per million (ppm) by weight, which is nearly equivalent to the sulfur content of pipeline quality natural gas. Therefore, the selection of these fuels results in the greatest level of SO_2 reduction and represents the top level of control.

During combustion, a small percentage of SO_2 is further oxidized to sulfur trioxide (SO_3) that subsequently reacts with moisture in the exhaust to form H_2SO_4 . Implementing the top level of control for SO_2 emissions is, therefore, also the top level of control for H_2SO_4 emissions.

Particulate Matter

Emissions of particulate matter result from trace quantities of ash (non-combustibles) in the fuel, products of incomplete combustion and conversion of SO_2 in the exhaust to condensable salts. Conservatively, all PM emissions from the Project are presumed to be less than 2.5 microns in size ($PM_{2.5}$) and, therefore, emissions of PM, PM_{10} and $PM_{2.5}$ are presumed to be equal for the Project. Particulate emissions are minimized by utilizing state-of-the-art combustion turbines firing fuels with the lowest sulfur and ash content. Pipeline quality natural gas has the lowest ash and sulfur content of all fossil fuels. As shown previously, the sulfur content of ULSD is nearly equivalent to that of pipeline quality natural gas and has a maximum allowable ash content of only 100 ppm by weight. ULSD firing will be limited to no more than 720 hours per 12-month period.

² http://yosemite.epa.gov/oa/EAB_Web_Docket.nsf/PSD%20Permit%20Appeals%20(CAA)/687C700F9FD042F585257C9B006369CE/\$File/La%20Paloma.pdf



A review of the permitted emission limits in Table G-3 shows a wide range of values on a lb/MMBtu basis. Similar to VOC emissions, the permitted PM emission limit for a combustion turbine project are dependent upon the make and model of the combustion turbine selected and the vendor guaranteed emission rate. Furthermore, turbine vendors typically have higher emissions guarantees at lower operating loads even though the emissions on a pound per hour basis are lower at the lower operating loads. A comparison of the recently permitted Green Energy Partners project in Virginia to the Carroll County project in Ohio shows a permitted PM emission rate difference of a factor of three (on a lb/MMBtu basis) for the same model GE turbine. This difference results from the Green Energy Partners permitted emission rate being at full operating load while the Carroll County limit is at minimum operating load. For purposes of establishing PM BACT for the Project, lb/MMBtu emission levels at full load will be proposed to be consistent with the majority of recently permitted projects. Higher emission levels will occur at reduced operating loads, as presented in the calculations in Appendix A.

BACT for PM emissions from the Project is proposed to be good combustion practices, the use of natural gas as the primary fuel with a maximum sulfur content of 0.5 gr S/100 scf, limited firing of ULSD and the guaranteed emission rates from GE. GE's guaranteed PM emissions on a lb/MMBtu basis change depending upon operating load and ambient conditions. In order to establish BACT as an emission rate, the following limits at full operating load are proposed for the Project, including filterable and condensable PM. The pound per hour limits are absolute maximum values while the lb/MMBtu limit represents all scenarios at full operating load, including duct firing. Therefore, higher emissions at reduced operating loads may occur in terms of lb/MMBtu but no increase in hourly mass emissions will result.

- 20.4 lbs/hr with duct firing on natural gas;
- 9.7 lbs/hr without duct firing on natural gas;
- 0.0081 lb/MMBtu at full load with duct firing on natural gas;
- 0.0041 lb/MMBtu at full load without duct firing on natural gas;
- 42.6 lbs/hr on ULSD; and
- 0.020 lb/MMBtu at full load on ULSD;

Full operating load limits are proposed to establish BACT since performance emissions testing will be conducted at full operating load. Emissions at reduced operating load will be lower on a pound per hour basis but higher on a lb/MMBtu basis. Further reductions in PM emissions from the combustion turbines are not technically feasible as there are no known combustion turbines equipped with add-on PM pollution controls.

Ammonia

 NH_3 is injected into the exhaust of the combustion turbines prior to the SCR to facilitate the conversion of NO_x to nitrogen and water. A small portion of the injected NH_3 does not react with NO_x and is exhausted to the atmosphere; this unreacted NH_3 is called "ammonia slip." A review of the recently permitted emission rates in Table G-3 for ammonia show that all of the projects are permitted at 5.0 ppmvd corrected to 15% O_2 with the exception of the Pioneer Valley and Kleen Energy projects. Based upon the great majority of recently approved projects, the Project proposes BACT for NH_3 emissions from the combustion turbines to be limited to 5.0 ppm corrected to 15% O_2 during normal operation. Ammonia will not be injected until the SCR catalyst reaches the vendor recommended minimum operating temperature to ensure a high reaction efficiency and minimize ammonia slip.



Greenhouse Gases

USEPA issued a 2011 guidance document for completing GHG BACT analyses titled "PSD and Title V Permitting Guidance for Greenhouse Gases." This guidance is in addition to the 1990 USEPA BACT guidance document. Although the 2011 guidance document refers to the same top-down methodology described in the 1990 document, the 2011 guidance provides additional clarification and detail with regard to some aspects of the analysis. The following analysis has been conducted in accordance with both the 1990 and 2011 guidance documents.

Step 1: Identify Potentially Feasible GHG Control Options

In Step 1, the applicant must identify all "available" control options which have the potential for practical application to the emission unit and regulated pollutant under evaluation, including lower-emitting process and practices. In assessing available GHG control measures, the sources of information reviewed for all of the BACT analyses were reviewed with regard to GHG controls and emissions. For a combined-cycle combustion turbine project, potential GHG controls include the following:

- 1. low carbon-emitting fuels;
- 2. energy efficiency and heat rate; and
- 3. carbon capture and storage (CCS).

Each of these GHG control measures is evaluated in Step 2 of this analysis.

Step 2: Technical Feasibility of Potential GHG Control Options

Low Carbon-Emitting Fuels

Natural gas combustion generates significantly lower GHG emissions on a per unit of heat throughput than distillate oil (approximately 27% less) and coal (approximately 50% less). Use of biofuels, such as biodiesel, would reduce fossil-based carbon dioxide emissions, since biofuels are produced from recently harvested plant material rather than ancient plant material that has transformed into fossil fuel. However, biofuels are not readily available on a commercial scale. In addition, combined-cycle turbines have technical issues with biofuels that have yet to be resolved and, as a result, there are no known permitted or proposed combustion turbine projects firing biofuel. For this reason, biofuels were eliminated from consideration as BACT. Therefore, natural gas as the primary fuel represents the lowest carbon-emitting fuel commercially available for the Project. Firing of ULSD as backup fuel will be limited to no more than 720 hours per year.

Energy Efficiency and Heat Rate

USEPA's 2011 GHG permitting guidance states:

"Evaluation of [energy efficiency options] need not include an assessment of each and every conceivable improvement that could marginally improve the energy efficiency of [a] new facility as a whole (e.g., installing more efficient light bulbs in the facility's cafeteria), since the burden of this level of review would likely outweigh any gain in emissions reductions achieved. USEPA instead recommends that the BACT analyses for units at a new facility concentrate on the energy efficiency of equipment that uses the largest amounts of energy, since energy efficient options for such units and equipment (e.g., induced draft fans, electric water pumps) will have a larger impact on reducing the facility's emissions..."

³ http://www.epa.gov/nsr/ghgdocs/ghgpermittingguidance.pdf



USEPA also recommends that permit applicants:

"propose options that are defined as an overall category or suite of techniques to yield levels of energy utilization that could then be evaluated and judged by the permitting authority and the public against established benchmarks...which represent a high level of performance within an industry."

With regard to electric generation from combustion sources, the combined-cycle combustion turbine is considered to be the most efficient technology available. GHG emissions from electricity production are primarily a function of the amount of fuel burned.

Therefore, the Project's proposal to use advanced combined-cycle combustion turbine technology is the most efficient process technically available to minimize GHG emissions.

Carbon Capture and Storage

USEPA has specifically stated that carbon capture and storage (CCS) is technically achievable and must be considered in a GHG PSD BACT analysis. CCS is composed of three main components: carbon dioxide (CO₂) capture and compression, transport, and storage. While CCS is a promising technology and may be technically achievable for a specific project, USEPA has also stated that at this time, CCS will be a technically feasible BACT option only in certain limited cases.

CCS can theoretically be applied as a pre-combustion or post combustion control option. The application of CCS technology for pre-combustion control is applicable if the fuel contains significant concentrations of CO or CO₂. Potential application of pre-combustion CCS would be an Integrated Gasification Combined Cycle (IGCC) power plant or other type of gasification process. As the Project will fire pipeline quality natural gas with minimal amounts of CO and CO₂, pre-combustion CCS is not applicable to the Project.

As stated in the August 2010 Report of the Interagency Task Force on Carbon Capture and Storage⁴, co-chaired by USEPA and the United States Department of Energy, while amine- or ammonia-based CO2 capture technologies are commercially available, they have only been implemented in non-combustion applications (i.e., separating CO₂ from field natural gas) or relatively small-scale combustion applications (e.g., slip streams from power plants with exhaust volumes that would correspond to approximately one MW of generating capacity). Scaling up these small-scale carbon capture systems for post combustion control of a nominal 805-MW combustion turbine generating plant such as this Project would represent a very significant technical challenge. In addition, integration of these technologies with the power cycle at generating plants present significant cost and operating issues that would need to be addressed prior to widespread, cost-effective deployment of CO₂ capture. Current technologies are not ready for widespread commercial implementation primarily because they have not been demonstrated at the scale necessary to establish confidence for power plant applications. To date, United States power generating projects under consideration for using CCS technology have required significant government funding and have been targeted for coal-fired boiler plants that have exhaust with higher CO2 concentrations and lower exhaust volume as compared to a combustion turbine project. Furthermore, these proposed projects have experienced significant delays due to technical issues and dramatic increases in costs beyond original projections.

The Interagency Task Force report also showed that the costs to implement CCS technology on a natural gas combined-cycle combustion turbine generating project were excessive. The Interagency Task Force report provided an estimated capital cost for carbon capture equipment for a 550 MW natural gas-fired combined-cycle facility of \$340 million, an 80 percent increase in the capital cost of the plant. Scaling these costs up to nominal

⁴ http://www.epa.gov/climatechange/Downloads/ccs/CCS-Task-Force-Report-2010.pdf



_

805-MW for the Project yields an estimated capital cost for carbon capture equipment of approximately \$498 million dollars. These costs are excessive and would make the Project economically unviable.

In addition, the Interagency Task Force report states that CCS technology would result in an energy penalty of 15 percent, meaning that 15 percent more fuel would be required to meet the design criteria of 805 MW. This would result in a 15 percent increase in emissions of all other PSD subject pollutants for the Project.

After the CO_2 is captured it must be transported to a storage facility, but a nearby pipeline does not exist to transport the captured CO_2 to a storage facility. The nearest CO_2 pipeline to the Project is in southern Mississippi; more than 1,000 miles from the Project in a straight line distance (see Figure 1). The cost to construct a pipeline from the Project to Mississippi would more than double the cost of the Project.




Figure G-1: CO₂ Pipelines in the United States

The nearest geological formation that is capable of storing CO₂ is located in western New York,⁵ more than 100 miles from the Project. However, a carbon storage facility does not exist at this location. Costing procedures provided by the National Energy Technology Laboratory (NETL) in *Carbon Dioxide Transport and Storage Costs in NETL Studies*⁶ (March 2013) shows that the cost to construct a 100-mile pipeline to western New York would cost \$112 million dollars. Furthermore, the time necessary to acquire all required property rights, obtain regulatory approvals and construct the pipeline would take many years.

With regard to storage for CCS, the Interagency Task Force concluded that, while there is currently estimated to be a large volume of potential storage sites, "to enable widespread, safe, and effective CCS, CO₂ storage should continue to be field-demonstrated for a variety of geologic reservoir classes" and that "scale-up from a limited number of demonstration projects to wide scale commercial deployment may necessitate the consideration of basin-scale factors (e.g., brine displacement, overlap of pressure fronts, spatial variation in depositional environments, etc.)."

Based on the abovementioned USEPA guidance regarding technical feasibility, the distance to the nearest CO_2 pipeline and/or geologically suitable storage site and the conclusions of the Interagency Task Force for the CO_2 capture component alone, CCS has been determined to be not technically feasible for the Project. Furthermore, the capital costs for capture and transport equipment are estimated to be close to \$600 million dollars, which would nearly double the cost of the Project and, therefore, is not cost effective.

Step 3: Ranking of Technically Feasible GHG Control Options by Effectiveness

Based on the results of Step 2, the low carbon-emitting fuels, energy efficiency and CCS are all technically feasible. However, due to the cost for carbon capture systems and the lack of suitable sequestration facilities near the Project, CCS was eliminated form further consideration as a BACT option.

Step 4: Evaluation of Low Carbon-Emitting Fuels and Energy Efficiency

The Project will utilize the lowest carbon-emitting fuel available, pipeline quality natural gas.

Improvements to energy efficiency and "heat rate" are important GHG control measures that can be employed to mitigate GHG emissions. The Project is proposing advanced combustion turbine combined-cycle technology, which is recognized as the most efficient commercially available technology for producing electric power from fossil fuels.

The driving factor in the evaluation of energy efficiency is the core efficiency of the selected combustion turbine. However, in the EAB's recent decision in the La Paloma Energy Center case it was concluded that "combined-cycle combustion turbines with efficient turbine design is the most energy efficient way to generate electricity" and that minor differences in efficiency and GHG emission rates between different combustion turbine models are acceptable. The Project is proposing to install two "H" Class turbines in combined-cycle configuration, which are the most efficient class of combustion turbines commercially available.

With regard to energy efficiency considerations in combined-cycle combustion turbine facilities, the activity with the greatest effect on overall plant efficiency is the method of condenser cooling. As with all steam-based electric generation, combined-cycle plants can use either dry cooling or wet cooling for condenser cooling. Dry cooling uses large fans to condense steam directly inside a series of pipes, similar in concept to the radiator of a car. Wet cooling can either be closed-cycle evaporative cooling (using cooling towers), or "once-through" cooling using very large volumes of water. Wet cooling performance increases overall efficiency as it produces colder water as



_

⁵ http://www.epa.gov/climatechange/ccs/

⁶http://www.netl.doe.gov/File%20Library/Research/Energy%20Analysis/Publications/QGESS_CO2T-S_Rev2_20130408.pdf

compared to dry cooling. Additionally, dry cooling requires more electricity than wet cooling, resulting in a higher parasitic load. As a result, operation of a dry cooling system requires approximately 1 to 5% more energy than a wet cooling system, depending on ambient conditions.

However, wet cooling systems utilize considerably more water than dry systems, which may not be suitable for all projects. Once-through cooling uses large quantities of water that is returned to the receiving water body at a higher temperature. Wet mechanical draft cooling towers also require a significant quantity of water, mostly due to evaporation to the atmosphere. The higher water demand of a wet cooling system is not suitable to the Project due to regional focus on minimizing water consumption. For this reason, a dry cooling system with an ACC was selected for the Project.

Step 5: GHG BACT

GHG BACT for the Project is the selection of advanced combined-cycle combustion turbine technology utilizing natural gas as the primary fuel with limited firing of ULSD.

The permitted GHG emission rates in Table G-3 take into account degradation in turbine performance over its expected lifetime. The majority of the GHG BACT decisions in Table G-3 apply several degradation factors initially established by the Bay Area Air Quality Management District for the permitting of the Russell City Energy Center. These degradation factors have been approved by the USEPA in several recent PSD permits issued by USEPA. As these degradation factors have been approved by the USEPA, they are proposed to be applied for the Project to establish the GHG BACT emission rate. Following is a discussion of these factors and the proposed GHG BACT emission rate.

The first factor accounts for design margin to reflect the likelihood that the equipment as constructed and installed may not fully achieve the optimal vendor specified design performance. A design margin of 3.3% is taken into account for this purpose.

The second factor accounts for performance margin to reflect normal wear and tear of the combustion turbine over its useful life. A performance margin of 6.0% is taken into account for this purpose.

The third factor accounts for degradation of auxiliary plant equipment to reflect normal wear and tear. An auxiliary equipment degradation margin of 3.0% is taken into account for this purpose.

These three factors are expected to compound upon each preceding factor such that the overall degradation in plant performance is estimated to be 12.8% over the useful life of the combustion turbines.

The CT DEEP has indicated that their preference is to establish GHG BACT in terms of a net heat rate. Several of the projects identified in Table G-3 have been permitted with a heat rate limit; the great majority of these limits have been established on a net output basis. Additionally, most of these limits have been established solely for a gas fired operating condition, without duct firing, at ISO conditions. The proposed GE 7HA.01 CTG has a new and clean designed heat rate of 6,241 Btu/kw-hr on a gross output basis when firing natural gas at ISO conditions without duct firing. Taking into account a parasitic load of 2.5%, the new and clean designed heat rate is 6,401 Btu/kw-hr on a net output basis when firing natural gas at ISO conditions without duct firing. Applying the 12.8% performance degradation and margin factor discussed above, yields a net heat rate of 7,220 Btu/kw-hr when firing natural gas at ISO conditions without duct firing. This net heat rate is lower than any heat rate limit identified in Table G-3 and is proposed as GHG BACT for the Project.

Compliance with the proposed net heat rate limit shall be demonstrated in accordance with ASME Performance Test Code on Overall Plant Performance (ASME PTC 46-1996), or equivalent method approved by the CT DEEP. CPV Towantic proposes to complete this test with the initial performance testing and once every five years thereafter to verify compliance with the proposed net heat rate limit.

The operating data used to determine the GHG BACT emission rate are provided in Appendix A.



Start-up/Shutdown Emissions

Combustion turbines experience increased VOC, CO and NO_x emissions during SU/SD operation. In addition, initial low operating temperatures during start-up preclude the use of the SCR and limit the efficiency of the oxidation catalyst. BACT for start-up and shutdown is good operating practices by following the manufacturer's recommendations during start-up, and limiting the start-up time. The GE 7HA.01 combustion turbines proposed for the project are "fast start" units that can achieve compliance operation within one hour of start-up for all start types.

During SU/SD operation, VOC, CO and NO_x emissions will be minimized during these short transitional periods by proper operational practices in accordance with manufacturer specifications. Furthermore, the proposed GE 7HA.01 combustion turbines are "fast start" units that can achieve compliance operation within one-hour of start-up for all start types, minimizing periods of increased emissions. The vendor specified SU/SD emissions for the combustion turbines are provided in Table G-4. Any increase in emissions during SU/SD operation is included in the potential annual emissions provided in Table E-3; detailed emission calculations are provided in Appendix A.

Pollutant	Cold Start		Warm	Start	Hot	Start	Shutdown		
Pollutant	Gas	ULSD	Gas	ULSD	Gas	ULSD	Gas	ULSD	
NO _x	93	104	93	104	70	102	19	34	
СО	242	230	242	230	238	231	121	18	
VOC	37	87	37	87	36	90	60	23	

Table G-4: Start-up/Shutdown Emission Rates (lbs/hr)

For the purposes of Table G-4, the following definitions are applied:

- Cold Start-up refers to restarts made at least 72 hours or more after shutdown and shall not last longer than 60 minutes per occurrence.
- Warm Start-up refers to restarts made between 8 and 72 hours after shutdown and shall not last longer than 60 minutes per occurrence.
- Hot Start-up refers to restarts made between 0 and 8 hours after shutdown and shall not last longer than 60 minutes per occurrence.
- Shutdown refers to the period between the time the turbine load drops below 50 percent operating load and the fuel supply to the turbine is cut. Shutdown operation shall not last longer than 60 minutes per occurrence.

Auxiliary Boiler

The Project will include an auxiliary boiler rated at 92.4 MMBtu/hr fired solely with natural gas. The auxiliary boiler will provide steam to warm up the steam turbine to minimize the duration of plant start-ups. Annual operation of the auxiliary boiler will be limited to a full-load equivalent of 4,000 hours per year. Emissions from the boiler are subject to BACT requirements and a review was conducted of recently permitted emission rates from natural gas fired boilers; the results of this review are provided in Table G-5. The emission limits provided in Table G-5 serve as the basis for determining the "most stringent emissions limitation which is achieved in practice" for natural gasfired auxiliary boilers.



Volatile Organic Compounds

VOC is emitted from the auxiliary boiler as a result of incomplete oxidation of the fuel. VOC emissions can be minimized by the use of proper combustor design and good combustion practices. For the Auxiliary Boiler, the most advanced level of control identified in Table G-5 is good combustion practices achieved through state-of-the-art Ultra LNB. Ultra LNB can minimize VOC emissions and achieve an emission rate of 9.6 ppm corrected to 3% O₂, equivalent to 0.004 lb/MMBtu.

The vendor guaranteed VOC emission rate is at or below all of the permitted VOC limits with the exception of the Green Energy Partners and Cricket Valley Generation projects. Further reductions in VOC emissions might be achieved through installation of an oxidation catalyst. However, VOC emissions from the natural gas fired auxiliary boiler are expected to be straight chain alkanes, which are not efficiently controlled by an oxidation catalyst. Based upon speciated organic compound emission factors provided in AP-42 Section 1.4, Table 1.4-3, non-straight chain alkanes would be expected to contribute 0.00008 lb/MMBtu of the organic compound emissions, which is equal to 2% of the total VOC emissions. Therefore, an oxidation catalyst is not expected to measurably lower the VOC emissions below the vendor guaranteed emission rate.

Table G-5: Summary of Recent PSD BACT Determinations for Natural Gas-Fired Auxiliary Boilers

Facility	Location	Permit Date	Controls	CO ^a (ppm)	VOC ^a (lb/MMBtu)	PM ₁₀ /PM _{2.5} ^b (lb/MMBtu)
Green Energy Partners / Stonewall	Leesburg, VA	04/30/2013	Ultra LNB	50	0.002 (LAER)	0.002
Brunswick County Power	Freeman, VA	05/23/2012	Ultra LNB	50	0.006	0.0075
Dominion Warren County	Front Royal, VA	12/21/2010	Ultra LNB	50	0.0053	0.005
Carroll County Energy	Washington Twp., OH	11/5/2013	Ultra LNB	75	0.006	0.008
Renaissance Power	Carson City, MI	11/1/2013	LNB	50	0.005	0.005
Kleen Energy	Middletown, CT	07/2/2013	LNB	100	0.004	0.006
Oregon Clean Energy	Oregon, OH	06/18/2013	Ultra LNB	75	0.006	0.008
Sunbury Generation	Sunbury, PA	04/01/2013	LNB	100	0.005	0.008
Hess Newark Energy	Newark, NJ	11/01/2012	Ultra LNB	50	0.004	0.005
Cricket Valley Energy Center	Dover, NY	09/27/2012	Ultra LNB	50	0.0015 (LAER)	0.005
Pioneer Valley Generation Company	Westfield, MA	04-12-2012	LNB	50	0.003	0.0048

^a Concentration in ppm is parts per million by volume, dry, at 3 percent O₂.

Carbon Monoxide

CO is emitted from the auxiliary boiler as a result of incomplete oxidation of the fuel. CO emissions can be minimized by the use of proper combustor design and good combustion practices. For the auxiliary boiler, the most advanced level of control identified in Table G-5 is good combustion practices achieved through state-of-the-



^b Concentration in pounds per million Btu heat input (HHV), except as noted, including front (filterable) and back-half (condensable) PM.

art Ultra LNB. Ultra LNB can minimize CO emissions and achieve an emission rate of 50 ppm corrected to 3% O₂, equivalent to 0.037 lb/MMBtu.

Further reductions in CO emissions could be achieved through installation of an oxidation catalyst. However, the installation of an oxidation catalyst on the auxiliary boiler would not be cost effective due to the already low CO emissions from the boiler. Potential CO emissions from the boiler are only 3.4 lbs/hr and limited to 6.8 tpy due to the proposed operating restriction of 4,000 hrs/yr. The cost to control analysis in Attachment G2 shows a cost to control of over \$7,400 per ton of CO removed for an oxidation catalyst on the auxiliary boiler. This cost to control is not economical and an oxidation catalyst was eliminated as a BACT option for this reason.

Based on a review of recently permitted projects, 50 ppm corrected to $3\% O_2$ was determined to be the most stringent emission limit achieved in practice and is selected as BACT for the auxiliary boiler.

SO₂ and H₂SO₄ Emissions

The most stringent level of control for SO_2 and H_2SO_4 emissions from combustion sources is the firing of pipeline quality natural gas. The USEPA defines pipeline quality natural gas in the Acid Rain regulations under 40 CFR 72.2 as "pipeline natural gas contains 0.5 grains or less of total sulfur per 100 standard cubic feet." Therefore, BACT for SO_2 emissions from the auxiliary boiler is utilizing pipeline quality natural gas as the primary fuel. Therefore, the selection of this fuel results in the greatest level of SO_2 reduction and represents the top level of control.

During combustion, a small percentage of SO_2 is further oxidized to SO_3 that subsequently reacts with moisture in the exhaust to form H_2SO_4 . Implementing the top level of control for SO_2 emissions is, therefore also the top level of control for H_2SO_4 emissions.

Particulate Matter

Emissions of particulate matter result from trace quantities of ash (non-combustibles) in the fuel, products of incomplete combustion and conversion of SO_2 in the exhaust to condensable salts. Particulate emissions from a combustion source are minimized by utilizing state-of-the-art combustion technology while firing natural gas since natural gas has the lowest ash and sulfur content available. The permitted PM emission rates in Table G-5 range from 0.002 to 0.008 lb/MMBtu. The reason for the difference in permitted PM emission from the auxiliary boiler is most likely due to differences in vendor specified emission rates.

Based upon recent PSD BACT determinations, 0.007 lb/MMBtu was selected as BACT for the auxiliary boiler based upon the boiler vendor emission guarantee.

Greenhouse Gases

As discussed for the CTGs/DBs, there are three control mechanisms for reducing GHG emissions from combustion processes: (1) low carbon-emitting fuels; (2) energy efficiency; and (3) CCS. The combined-cycle combustion turbines account for 99% of the facility's GHG emissions. As previously discussed, CCS is not technically or economically feasible for the GHG emissions from the combustion turbines. Since CCS becomes more feasible at larger scales, it is concluded that it is not feasible for the auxiliary boiler as it is not feasible for the combined-cycle combustion turbines. BACT for the auxiliary boiler is proposed to be firing natural gas as the sole fuel and efficient boiler design.

Emergency Generator and Fire Pump Engines

The Project will include an emergency diesel generator engine and a diesel fire pump engine. Both engines will be fired with ULSD fuel. Both engines will be used only during emergency situations, with the exception of periodic maintenance/readiness testing, and will be limited to a maximum of 300 operating hours per rolling 12 month period.



No post-combustion controls have been demonstrated in practice for emergency internal combustion engines. In order to satisfy BACT requirements, CPV Towantic proposes that the engines meet NSPS 40 CFR 60 Subpart IIII requirements. Under 40 CFR 60 Subpart IIII, the emergency generator engine must meet the Tier 2 standards and the fire pump engine must meet the emission standards for fire pump engines in Table 4 of 40 CFR 60. Emissions will be controlled through the use of ULSD, engine design, good combustion practices and limited annual operation. In accordance with NSPS Subpart IIII, operation of the engines for maintenance and readiness testing purposes shall be limited to no more than 100 hours per year. The engines will also be operated in accordance with Section 22a-174-3b(e) with total operating hours for all conditions of no more than 300 hours per year.

The Project has received vendor emission guarantees that are below the standards under NSPS Subpart IIII and proposes these emission guarantees as BACT. The emission guarantees are provided in Table G-6.

Pollutant	Emergency Generator Engine (g/bhp)	Fire Pump Engine (g/kW-hr)
NO _x	4.08	3.80
СО	0.44	0.90
VOC	0.11	0.10
PM/PM ₁₀ /PM _{2.5}	0.03	0.13
SO ₂ ^a	N/A	N/A

Table G-6: Emergency Engine Emission Guarantees

Fugitive GHG Emission Sources

The Project will include natural gas handling systems and circuit breakers that contain sulfur hexafluoride (SF₆). Fugitive losses of natural gas and SF₆ will contribute to GHG emissions from the Project. Provided in Appendix A is an estimate of fugitive GHG emissions totaling 554 tpy, which represents less than 0.1% of the total GHG emissions for the Project. In order to minimize fugitive GHG emissions, the Project will implement current BACT operating standards for these emission sources, including the following:

- Implement an auditory/visual/olfactory leak detection program for the natural gas piping components and make daily observations.
- Equip each circuit breaker with a low pressure alarm and low pressure lockout. SF₆ emissions from each circuit breaker will be calculated annually (calendar year) in accordance with the mass balance approach in Equation DD-1 of 40 CFR Part 98, Subpart DD. The maximum annual leakage rate for SF₆ will not exceed 0.5% of the total SF₆ storage capacity of the plant's circuit breakers.
- Maintain records of all measurements and reports related to the fugitive emission sources including those related to maintenance as well as compliance with the Monitoring and QA/QC procedures defined under 40 CFR 98.304 Subpart DD.



^a SO₂ emissions will be limited based upon a maximum fuel sulfur content of 15 ppmw (0.0015 lb/MMBtu).

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: AB	
Unit Description: Auxiliary Boiler	
Pollutant: CO	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
N/A	None	Oxidation Catalyst	RBLC, CT DEEP BACT Database, permits
Auxiliary Boiler	Several. See Attachment G1.	Good combustion practices	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 6.8

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Oxidation Catalyst	Yes	1.4	5.4	80	Top level of control. Not installed on any known gas fired auxiliary boilers
Good combustion practices	Yes	6.8	0	0	Highest level of control installed in practice

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top control option	☐ Yes ⊠ No	If Yes, g	o to Part IV	
Complete Attachment G2: Cost/Economic Impacted before find the considered b	-	APP-214c for ea	ach technically fea	sible BACT options listed in Part II for whic
Provide the following economic information for e APP-214c.	ach of the BACT options	s with completed	d Attachment G2:	Cost/Economic Impact Analysis, DEEP-NS
	Total	Cost Effecti	veness (\$/ton)	
BACT Option	Annualized Cost (TAC, \$/year)	Average	Incremental (optional)	Comments/Rationale
Oxidation Catalyst	40,872	7,480		Cost to control not economically feasible.
Good combustion practices	0	N/A	N/A	No increase in costs above baseline

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Outlan	Toxics Impact Adve		Advers	se Impact	O
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Oxidation Catalyst	No	N/A	Yes	0.007	Increased conversion of SO2 to SO3 from 5% to 30% resulting in increased H2SO4 emissions.
Good combustion practices	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Oxidation Catalyst	<0.5%	Marginal reduction in boiler efficiency
Good combustion practices	0	No change in energy impacts

Part VI. BACT Recommendation

BACT Option Recommended: Good combustion practices meeting an emission rate of no greater than 50 ppmvd at 3% O2.

Justification: An oxidiation catalyst is not cost effective. The selected controls are the top level of control used in practice for a gas-fired auxiliary boiler rated less than 100 MMBtu/hr.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
11	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
1	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: AB	
Unit Description: Auxiliary Boiler	
Pollutant: NOx	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
N/A	None	Selective Catalytic Reduction (SCR)	RBLC, CT DEEP BACT Database, permits
Auxiliary Boiler	Several. See Attachment G1.	Ultra-Low-NOx Burners (ULNB)	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 2.0

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Selective Catalytic Reduction (SCR)	Yes	0.45	1.57	78	Top level of control. Not installed on any known gas-fired auxiliary boilers. Reduction from 9 to 2 ppm
Ultra-Low-NOx Burners (ULNB)	Yes	2.02	0	0	Highest level of control installed in practice

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top control opti	on	If Yes, o	jo to Part IV	
Complete Attachment G2: Cost/Economic Imeconomic impacts are to be considered before Provide the following economic information for APP-214c.	pact Analysis, DEEP-NSR- e filling this Part.	APP-214c for e	ach technically fea	·
	Total	Cost Effecti	veness (\$/ton)	
BACT Option	Annualized Cost (TAC, \$/year)	Average	Incremental (optional)	Comments/Rationale
Selective Catalytic Reduction (SCR)	\$55,087	\$35,062		Cost to control not economically feasible.
Ultra Low-NOx Burners (ULNB)	0	N/A	N/A	No increase in costs above baseline

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

BACT Option	Toxics Impact		Adverse Impact		Commonto/Detionals
	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Selective Catalytic Reduction (SCR)	No	N/A	Yes	0.26	Ammonia emissions. NH3/ton based upon 5 ppm NH3 slip and NOx reduction from 9 ppm to 2 ppm
Ultra-Low-NOx Burners (ULNB)	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Selective Catalytic Reduction (SCR)	<0.5%	Marginal reduction in boiler efficiency
Ultra-Low-NOx Burners (ULNB)	0	No change in energy impacts

Part VI. BACT Recommendation

BACT Option Recommended: Ultra-Low-NOx Burners meeting an emission rate of no greater than 9 ppmvd at 3% O2.

Justification: An SCR is not cost effective. The selected controls are the top level of control used in practice for a gas-fired auxiliary boiler rated at less than 100 MMBtu/hr.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
8	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
1	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: AB	
Unit Description: Auxiliary Boiler	
Pollutant: VOC	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
N/A	None	Oxidation Catalyst	RBLC, CT DEEP BACT Database, permits
Auxiliary Boiler	Several. See Attachment G1.	Good combustion practices	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 1.0

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Oxidation Catalyst	Yes	0.5	0.5	33	Top level of control. Not installed on any known gas-fired auxiliary boilers. Reduction from allowable emission rate
Good combustion practices	Yes	0.75	0.2	25	Highest level of control installed in practice

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top control opt	ion 🗌 Yes 🔀 No	If Yes, g	o to Part IV	
Complete Attachment G2: Cost/Economic In economic impacts are to be considered befo	•	APP-214c for ea	ach technically fea	sible BACT options listed in Part II for whic
Provide the following economic information f APP-214c.	or each of the BACT options	with completed	d Attachment G2:	Cost/Economic Impact Analysis, DEEP-NS
	Total	Cost Effecti	veness (\$/ton)	
BACT Option	Annualized Cost (TAC, \$/year)	Average	Incremental (optional)	Comments/Rationale
Oxidation Catalyst	\$40,872	\$163,487	N/A	Cost to control not economically feasible.
Good combustion practices	0	N/A	N/A	No increase in costs above baseline

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

BACT Option	Toxics Impact Advers		se Impact	O	
	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Oxidation Catalyst	No	N/A	Yes	0.19	Increased conversion of SO2 to SO3 from 5% to 30% resulting in increased H2SO4 emissions.
Good combustion practices	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Oxidation Catalyst	<0.5%	Marginal reduction in boiler efficiency
Good combustion practices	0	No change in energy impacts

Part VI. BACT Recommendation

BACT Option Recommended: Good combustion practices meeting an emission rate of no greater than 9.6 ppmvd at 3% O2.

Justification: An oxidation catalyst is not cost effective. The selected controls are the top level of control used in practice for a gas-fired auxiliary boiler rated at less than 100 MMBtu/hr.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
10	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
1	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments:

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: PM, PM10, and PM2.5 (all PM is expected to be PM2.5)

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
Auxiliary Boiler	Several. See Attachment G1.	Pipeline quality natural gas as the sole fuel	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 1.3

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Pipeline quality natural gas as the sole fuel	Yes	1.3	0	0	Top level of control. No reduction expected from natural gas fired unit

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top co	ontrol option ⊠ Yes [□ No	If Yes, g	o to Part IV	
Complete Attachment G2: Cost/Ec economic impacts are to be considered.		EP-NSR-A	PP-214c for ea	ach technically fea	sible BACT options listed in Part II for which
Provide the following economic info APP-214c.	ormation for each of the BAC	T options v	with completed	Attachment G2:	Cost/Economic Impact Analysis, DEEP-NSF
	Tota		Cost Effective	veness (\$/ton)	
BACT Option	Annualize (TAC, \$/		Average	Incremental (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Outlan	Toxic	s Impact	Adverse Impact		Comments/Detionals
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Pipeline quality natural gas as the sole fuel	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Pipeline quality natural gas as the sole fuel	0	No energy impact

Part VI. BACT Recommendation

BACT Option Recommended: Pipeline quality natural gas as the sole fuel meeting an emission limit of 0.007 lb/MMBtu.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
11	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: AB	
Unit Description: Auxiliary Boiler	
Pollutant: SO2	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
Auxiliary Boiler	Several. See Attachment G1.	Pipeline quality natural gas as the sole fuel	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 0.3

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Pipeline quality natural gas as the sole fuel	Yes	0.3	0	0	Top level of control. No reduction expected from natural gas fired unit

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top co	ontrol option ⊠ Yes [□ No	If Yes, g	o to Part IV	
Complete Attachment G2: Cost/Ec economic impacts are to be considered.		EP-NSR-A	PP-214c for ea	ach technically fea	sible BACT options listed in Part II for which
Provide the following economic info APP-214c.	ormation for each of the BAC	T options v	with completed	Attachment G2:	Cost/Economic Impact Analysis, DEEP-NSF
	Tota		Cost Effective	veness (\$/ton)	
BACT Option	Annualize (TAC, \$/		Average	Incremental (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Outlan	Toxic	s Impact	Adverse Impact		Comments/Detionals
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Pipeline quality natural gas as the sole fuel	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Pipeline quality natural gas as the sole fuel	0	No energy impact

Part VI. BACT Recommendation

BACT Option Recommended: Pipeline quality natural gas as the sole fuel. The natural gas will have a maximum sulfur content of 0.5 grains per 100 cubic feet of gas.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
3	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: AB	
Unit Description: Auxiliary Boiler	
Pollutant: GHG	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
Auxiliary Boiler	Several. See Attachment G1.	Pipeline quality natural gas as the sole fuel	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 21,627

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Pipeline quality natural gas as the sole fuel	Yes	21,627	0	0	Top level of control. No reduction expected from natural gas-fired unit

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top co	ontrol option ⊠ Yes [□ No	If Yes, g	o to Part IV	
Complete Attachment G2: Cost/Ec economic impacts are to be considered.		EP-NSR-A	PP-214c for ea	ach technically fea	sible BACT options listed in Part II for which
Provide the following economic info APP-214c.	ormation for each of the BAC	T options v	with completed	Attachment G2:	Cost/Economic Impact Analysis, DEEP-NSF
	Tota		Cost Effective	veness (\$/ton)	
BACT Option	Annualize (TAC, \$/		Average	Incremental (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Outlan	Toxic	s Impact	Adverse Impact		Comments (Detionals
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Pipeline quality natural gas as the sole fuel	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Pipeline quality natural gas as the sole fuel	0	No energy impact

Part VI. BACT Recommendation

BACT Option Recommended: Pipeline quality natural gas as the sole fuel.

Justification: Natural gas is the lowest GHG emitting fossil fuel. The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
5	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: AB	
Unit Description: Auxiliary Boiler	
Pollutant: H2SO4	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
Auxiliary Boiler	Several. See Attachment G1.	Pipeline quality natural gas as the sole fuel	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 0.02

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Pipeline quality natural gas as the sole fuel	Yes	0.02	0	0	Top level of control. No reduction expected from natural gas-fired unit

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top co	ontrol option ⊠ Yes [□ No	If Yes, g	o to Part IV	
Complete Attachment G2: Cost/Ec economic impacts are to be considered.		EP-NSR-A	PP-214c for ea	ach technically fea	sible BACT options listed in Part II for which
Provide the following economic info APP-214c.	ormation for each of the BAC	T options v	with completed	Attachment G2:	Cost/Economic Impact Analysis, DEEP-NSF
	Tota		Cost Effective	veness (\$/ton)	
BACT Option	Annualize (TAC, \$/		Average	Incremental (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Outlan	Toxic	s Impact	Adverse Impact		Comments (Detionals
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Pipeline quality natural gas as the sole fuel	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Pipeline quality natural gas as the sole fuel	0	No energy impact

Part VI. BACT Recommendation

BACT Option Recommended: Pipeline quality natural gas as the sole fuel. The natural gas will have a maximum sulfur content of 0.5 grains per 100 cubic feet of gas.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
2	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: CT1/DB1	
Unit Description: Combined-Cycle Combustion Turbine #1	
Pollutant: CO	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
Combined-Cycle CT	Several. See Attachment G1.	Oxidation Catalyst	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 871

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Oxidation Catalyst	Yes	64.5	836	96	Top level of control. Reduction is from steady state operation excluding impact of startup and shutdown emissions.

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top co	ntrol option ⊠ Yes □	No If	Yes, go to Part IV	
economic impacts are to be consid	ered before filling this Part.			feasible BACT options listed in Part II for whice feasible BACT options listed in Part II for wh
APP-214c.				
BACT Option	Total Annualized (TAC, \$/ye	Cost	Effectiveness (\$/ton Incrementage (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Outlon	Toxics Impact		Adverse Impact		Comments/Rationale
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Oxidation Catalyst	No	N/A	Yes	0.012	Increased conversion of SO2 to SO3 from 5% to 35% resulting in increased H2SO4 emissions. H2SO4/ton reflects ratio of 85.7% of the H2SO4 emissions to CO reduction from baseline in Part II.

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Oxidation Catalyst	0	Marginal increase in net heat rate

Part VI. BACT Recommendation

BACT Option Recommended: Oxidation catalyst. CO emissions will be no greater than 0.9 ppmvd at 15% O2 during gas firing without duct firing, 1.7 ppmvd at 15% O2 during gas firing with duct firing, and 2.0 ppmvd at 15% O2 during ULSD firing.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
11	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: CT1/DB1	
Unit Description: Combined-Cycle Combustion Turbine #1	
Pollutant: NOx	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
Combined-Cycle CT	Several. See Attachment G1.	Low-NOx Combustors	RBLC, CT DEEP BACT Database, permits
Combined-Cycle CT	Several. See Attachment G1.	Selective Catalytic Reduction	RBLC, CT DEEP BACT Database, permits
Combustion Turbine	Several. See Attachment G1.	Water Injection	RBLC, CT DEEP BACT Database, permits
Combustion Turbine	Several. See Attachment G1.	Lean Pre-Mix Combustion	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 3,400

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Selective Catalytic Reduction (SCR)	Yes	94.7	3,305	97	Top level of control, LNB, SCR, LPC, and WI will be employed, reduction is for all three technologies combined excluding startup/shutdown emissions.
Lean-Premix Combustion (LPC)	Yes	94.7	3,305	97	Top level of control, LNB, SCR, LPC, and WI will be employed, reduction is for all three technologies combined excluding startup/shutdown emissions.
Low-NOx Combustors (LNB)	Yes	94.7	3,305	97	Top level of control, LNB, SCR, LPC, and WI will be employed, reduction is for all three technologies combined excluding startup/shutdown emissions.
Water Injection (WI) [oil firing only]	Yes	94.7	3,305	97	Top level of control, LNB, SCR, LPC, and WI will be employed, reduction is for all three technologies combined excluding startup/shutdown emissions.

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top co	ntrol option ⊠ Yes □] No	If Yes, go	to Part IV	
Complete Attachment G2: Cost/Ecc economic impacts are to be consider		P-NSR-APP	-214c for ead	ch technically fea	sible BACT options listed in Part II for which
Provide the following economic info APP-214c.	mation for each of the BACT	options with	completed	Attachment G2:	Cost/Economic Impact Analysis, DEEP-NSF
	Total		ost Effectiv	eness (\$/ton)	
BACT Option	Annualized (TAC, \$/y		verage	Incremental (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

PACT Ontion	Toxics Impact		Adverse Impact		Commonte/Detionals
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Low-NOx Combustors (LNB)	No	N/A	No	N/A	
Selective Catalytic Reduction (SCR)	No	N/A	Yes	0.023	Ammonia emissions. NH3/ton reflects ratio of NH3 emissions to NOx reduction from baseline in Part II.
Water Injection (WI)	No	N/A	Yes	N/A	Increased water usage. No impact on air pollutant emissons
Lean-Premix Combustion (LPC)	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Low-NOx Combustors (LNB)	0	No incremental change in energy usage
Selective Catalytic Reduction (SCR)	0	Marginal increase in net heat rate
Water Injection (WI)	0	Marginal increase in parasitic load
Lean-Premix Combustion (LPC)	0	No incremental change in energy usage

Part VI. BACT Recommendation

BACT Option Recommended: Lean pre-mix combustion, low-NOx combustors with SCR during all operating conditions. Water injection during distillate oil firing. NOx emissions will be 2 ppmvd at 15% O2 during natural gas firing and 5.0 ppmvd at 15% O2 during distillate oil firing.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
11	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC
Init No.: CT1/DB1
Init Description: Combined-Cycle Combustion Turbine #1
Pollutant: VOC

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
Combined-Cycle CT	Several. See Attachment G1.	Oxidation Catalyst	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 22.3

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Oxidation Catalyst	Yes	18.2	4.1	18	Top level of control. Reduction is for steady state operation excluding startup/shutdown emissions. With startup/shutdown emissions, allowable emissions are 24.5

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top c	ontrol option ⊠ Yes □ N	lo If Yes,	go to Part IV	
economic impacts are to be considered	dered before filling this Part.			sible BACT options listed in Part II for which
	Total	Cost Effec	tiveness (\$/ton)	
BACT Option	Annualized C (TAC, \$/yea	·	Incremental (optional)	Comments/Rationale
L				

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

BACT Option	Toxics Impact		Adverse Impact		Comments/Rationale	
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale	
Oxidation Catalyst	No	N/A	Yes	6.3	Increased conversion of SO2 to SO3 from 5% to 35% resulting in increased H2SO4 emissions. H2SO4/ton reflects ratio of 85.7% of the H2SO4 emissions to VOC reduction from baseline in Part II.	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Oxidation Catalyst		Marginal increase in net heat rate

Part VI. BACT Recommendation

BACT Option Recommended: Oxidation catalyst. VOC emissions will be no greater than 1 ppmvd at 15% O2 during natural gas firing without duct firing, 2 ppmvd at 15% O2 during natural gas firing with duct firing, and 2 ppmvd at 15% O2 during distillate oil firing.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
11	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1
Unit Description: Combined-Cycle Combustion Turbine #1
Pollutant: PM, PM10 and PM2.5 (all PM is expected to be PM2.5)

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Facility	Control Technology	Reference
Several. See Attachme nt G1.	Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	RBLC, CT DEEP BACT Database, permits
		primary fuel with limited firing of

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 76.7

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Pipeline quality natural gas as primary fuel			_	_	Top level of control. No reduction
with limited firing of ultra-low sulfur diesel as	Yes	76.7	0	0	expected from uncontrolled natural gas-
backup					fired unit

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top c	ontrol option ⊠ Yes □	No If Ye	s, go to Part IV	
economic impacts are to be consider	dered before filling this Part.		•	ole BACT options listed in Part II for v
PP-214c.	ormation for each of the BACT (options with compl	eted Aπacnment G2: Co	st/Economic Impact Analysis, DEEP-
	Total		ectiveness (\$/ton)	
BACT Option	Annualized (TAC, \$/ye		Incremental (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DAOT Outland	Toxics Impact		Adverse Impact		O
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	0	No energy impact

Part VI. BACT Recommendation

BACT Option Recommended: Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel (ULSD) as backup. Emissions will not exceed 0.0041 lb/MMBtu for natural gas firing without duct firing at full operating load; 0.0081 lb/MMBtu for natural gas firing with duct firing at full operating load; and 0.020 lb/MMBtu for ULSD firing at full operating load.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
11	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: CT1/DB1	
Unit Description: Combined-Cycle Combustion Turbine #1	
Pollutant: SO2	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
Combined-Cycle CT	Several. See Attachment G1.	Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 19.7

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	Yes	19.7	0	0	Top level of control

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top co	ntrol option ⊠ Yes □	No If	Yes, go to Part IV	
economic impacts are to be consid	ered before filling this Part.			feasible BACT options listed in Part II for whice the state of the sta
APP-214c.				
BACT Option	Total Annualized (TAC, \$/ye	Cost	Effectiveness (\$/ton Incrementation (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Outlan	Toxics Impact		Adverse Impact		O a manufa / Dationala
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	0	No energy impact

Part VI. BACT Recommendation

BACT Option Recommended: Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel (ULSD) as backup. The natural gas will have a maximum sulfur content of 0.5 grains per 100 cubic feet of gas. ULSD fuel, which will be used as backup, will have a maximum sulfur content of 15 ppm by weight. ULSD firing will be limited to no more than 720 hours per rolling 12-month period.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
7	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

pplicant Name: CPV Towantic, LLC
nit No.: CT1/DB1
nit Description: Combined-Cycle Combustion Turbine #1
ollutant: GHGs

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
None	None	Carbon Capture & Sequestration	RBLC, CT DEEP BACT Database, EPA GHG BACT guidance

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 2,032,758

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Carbon Capture & Sequestration	Yes	265,602	1,062,407	80	Top level of control. Has never been implemented on a utility scale, privately financed project. Reduction is from proposed allowable emissions.
Advanced Combined-Cycle Combustion Turbine Technology	Yes	1,328,009	704,749	35	Top level of control demonstrated in practice.

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top control opti	ion 🗌 Yes 🔀 No	If Yes, g	o to Part IV			
Complete Attachment G2: Cost/Economic Impact Analysis, DEEP-NSR-APP-214c for each technically feasible BACT options listed in Part II for which economic impacts are to be considered before filling this Part.						
Provide the following economic information for APP-214c.	or each of the BACT options	with completed	d Attachment G2:	Cost/Economic Impact Analysis, DEEP-NSR		
	Total	Cost Effecti	veness (\$/ton)			
BACT Option	Annualized Cost (TAC, \$/year)	Average	Incremental (optional)	Comments/Rationale		
Carbon Capture & Sequestration	\$151,217,981	142	N/A	TAC based upon annualized cost of \$44/MWh from the Interagency Task Force. Costs are not economically feasible.		

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Outlon	Toxics Impact		Adverse Impact		Commonto/Dationale
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Carbon Capture & Sequestration (CCS)	No	N/A	Yes	See Comment	CCS results in an estimated increase in net heat rate resulting in a direct increase of 15% for all pollutants on a lb/MWh basis.
Advanced Combined-Cycle Combustion Turbine Technlogy	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Carbon Capture & Sequestration	15% increase in net heat rate over baseline	Based upon Interagency Task Force
Advanced Combined-Cycle Combustion Turbine Technlogy	0	This is the baseline technology

Part VI. BACT Recommendation

BACT Option Recommended: Advanced Combined-Cycle Combustion Turbine Technlogy. The project will meet an annual gross heat rate of 7,120 Btu/kWh. This heat rate takes into account a 12.8% performance degradation over the life of the unit to account for design margin, wear and tear, and degradation of plant auxiliaries.

Justification: The selected controls are the top level of control demonstrated in practice.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
9	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
1	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1
Unit Description: Combined-Cycle Combustion Turbine #1
Pollutant: Sulfuric Acid Mist (H2SO4)

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
Combined-Cycle CT	Several. See Attachment G1.	Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 12.7

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	Yes	12.7	0	0	Top level of control

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top co	ntrol option ⊠ Yes □	No If	Yes, go to Part IV	
economic impacts are to be consid	ered before filling this Part.			feasible BACT options listed in Part II for whice feasible BACT options listed in Part II for wh
APP-214c.				
BACT Option	Total Annualized (TAC, \$/ye	Cost	Effectiveness (\$/ton Incrementage (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Outlan	Toxics Impact		Adverse Impact		O company to /Dational a
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	0	No energy impact.

Part VI. BACT Recommendation

BACT Option Recommended: Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel (ULSD) as backup. The natural gas will have a maximum sulfur content of 0.5 grains per 100 cubic feet of gas. ULSD, which will be used as backup, will have a maximum sulfur content of 15 ppm by weight. ULSD firing will be limited to no more than 720 hours per rolling 12-month period.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
4	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: CT1/DB1	
Unit Description: Combined-Cycle Combustion Turbine #1	
Pollutant: NH3	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
Combined-Cycle CT	Several. See Attachment G1.	NH3 Injection Control System	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 77.7

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
NH3 Injection Control System	Yes	77.7	0	N/A	Top level of control

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top co	ontrol option ⊠ Yes [□ No	If Yes, g	o to Part IV	
Complete Attachment G2: Cost/Ec economic impacts are to be considered.		EP-NSR-A	PP-214c for ea	ach technically fea	sible BACT options listed in Part II for which
Provide the following economic info APP-214c.	ormation for each of the BAC	T options v	with completed	Attachment G2:	Cost/Economic Impact Analysis, DEEP-NSF
	Tota		Cost Effective	veness (\$/ton)	
BACT Option	Annualize (TAC, \$/		Average	Incremental (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Ontion	Toxics Impact		Adverse Impact		O a manufa / Dationala
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
NH3 Injection Control System	No	N/A	No	N/A	Impacts associated with SCR provided on Attachment G for NOx.

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
NH3 Injection Control System	0	Marginal increase in parasitic load

Part VI. BACT Recommendation

BACT Option Recommended: NH3 slip emissions will be limited to no greater than 5.0 ppmvd at 15% O2 during gas firing and 5.0 ppmvd at 15% O2 during ULSD firing.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
7	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: CT2/DB2	
Unit Description: Combined-Cycle Combustion Turbine #2	
Pollutant: <u>CO</u>	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
Combined-Cycle CT	Several. See Attachment G1.	Oxidation Catalyst	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 871

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Oxidation Catalyst	Yes	64.5	836	96	Top level of control. Reduction is from steady state operation excluding impact of startup and shutdown emissions.

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top co	ntrol option ⊠ Yes □	No If	Yes, go to Part IV	
economic impacts are to be consid	ered before filling this Part.			feasible BACT options listed in Part II for whice the state of the sta
APP-214c.				
BACT Option	Total Annualized (TAC, \$/ye	Cost	Effectiveness (\$/ton Incrementation (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Outlon	Toxics Impact		Adverse Impact		Comments/Rationale
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Oxidation Catalyst	No	N/A	Yes	0.012	Increased conversion of SO2 to SO3 from 5% to 35% resulting in increased H2SO4 emissions. H2SO4/ton reflects ratio of 85.7% of the H2SO4 emissions to CO reduction from baseline in Part II.

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Oxidation Catalyst	0	Marginal increase in net heat rate

Part VI. BACT Recommendation

BACT Option Recommended: Oxidation catalyst. CO emissions will be no greater than 0.9 ppmvd at 15% O2 during gas firing without duct firing, 1.7 ppmvd at 15% O2 during gas firing with duct firing, and 2.0 ppmvd at 15% O2 during ULSD firing.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
11	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: CT2/DB2	
Unit Description: Combined-Cycle Combustion Turbine #2	
Pollutant: NOx	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
Combined-Cycle CT	Several. See Attachment G1	Low-NOx Combustors	RBLC, CT DEEP BACT Database, permits
Combined-Cycle CT	Several. See Attachment G1.	Selective Catalytic Reduction	RBLC, CT DEEP BACT Database, permits
Combustion Turbine	Several. See Attachment G1.	Water Injection	RBLC, CT DEEP BACT Database, permits
Combustion Turbine	Several. See Attachment G1.	Lean Pre-Mix Combustion	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 3,400

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Selective Catalytic Reduction (SCR)	Yes	94.7	3,305	97	Top level of control, LNB, SCR, LPC, and WI will be employed, reduction is for all three technologies combined excluding startup/shutdown emissions.
Lean-Premix Combustion (LPC)	Yes	94.7	3,305	97	Top level of control, LNB, SCR, LPC, and WI will be employed, reduction is for all three technologies combined excluding startup/shutdown emissions.
Low-NOx Combustors (LNB)	Yes	94.7	3,305	97	Top level of control, LNB, SCR, LPC, and WI will be employed, reduction is for all three technologies combined excluding startup/shutdown emissions.
Water Injection (WI) [oil firing only]	Yes	94.7	3,305	97	Top level of control, LNB, SCR, LPC, and WI will be employed, reduction is for all three technologies combined excluding startup/shutdown emissions.

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top co	ntrol option ⊠ Yes □	No If	Yes, go to Part IV	
economic impacts are to be consid	ered before filling this Part.			feasible BACT options listed in Part II for whice the state of the sta
APP-214c.				
BACT Option	Total Annualized (TAC, \$/ye	Cost	Effectiveness (\$/ton Incrementation (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

PACT Ontion	Toxics Impact		Adverse Impact		Commonto/Dationala
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Low-NOx Combustors (LNB)	No	N/A	No	N/A	
Selective Catalytic Reduction (SCR)	No	N/A	Yes	0.023	Ammonia emissions. NH3/ton reflects ratio of NH3 emissions to NOx reduction from baseline in Part II.
Water Injection (WI)	No	N/A	Yes	N/A	Increased water usage. No impact on air pollutant emissons
Lean-Premix Combustion (LPC)	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Low-NOx Combustors (LNB)	0	No incremental change in energy usage
Selective Catalytic Reduction (SCR)	0	Marginal increase in net heat rate
Water Injection (WI)	0	Marginal increase in parasitic load
Lean-Premix Combustion (LPC)	0	No incremental change in energy usage

Part VI. BACT Recommendation

BACT Option Recommended: Lean pre-mix combustion, low-NOx combustors with SCR during all operating conditions. Water injection during distillate oil firing. NOx emissions will be 2 ppmvd at 15% O2 during natural gas firing and 5.0 ppmvd at 15% O2 during distillate oil firing.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
11	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: CT2/DB2	
Unit Description: Combined-Cycle Combustion Turbine #2	
Pollutant: VOC	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Facility	Control Technology	Reference
Several. See Attachment G1.	Oxidation Catalyst	RBLC, CT DEEP BACT Database, permits
	Several.	Several. Ovidation Catalyst

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 22.3

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Oxidation Catalyst	Yes	18.2	4.1	18	Top level of control. Reduction is for steady state operation excluding startup/shutdown emissions. With startup/shutdown emissions, allowable emissions are 24.5

Part III. Economic Impacts/Cost Effectiveness

s the proposed BACT the top co	ontrol option ⊠ Yes □] No	If Yes, go	to Part IV	
economic impacts are to be consid	lered before filling this Part.				ible BACT options listed in Part II for v
APP-214c.	Total	· .	ost Effective	eness (\$/ton)	
BACT Option	Annualized (TAC, \$/y	Cost	Average	Incremental (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Option	Toxic	s Impact	Adverse Impact		Comments/Rationale
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Oxidation Catalyst	No	N/A	Yes	6.3	Increased conversion of SO2 to SO3 from 5% to 35% resulting in increased H2SO4 emissions. H2SO4/ton reflects ratio of 85.7% of the H2SO4 emissions to VOC reduction from baseline in Part II.

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Oxidation Catalyst		Marginal increase in net heat rate

Part VI. BACT Recommendation

BACT Option Recommended: Oxidation catalyst. VOC emissions will be no greater than 1 ppmvd at 15% O2 during natural gas firing without duct firing, 2 ppmvd at 15% O2 during natural gas firing with duct firing, and 2 ppmvd at 15% O2 during distillate oil firing.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
11	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: CT2/DB2	
Unit Description: Combined-Cycle Combustion Turbine #2	
Pollutant: PM, PM10 and PM2.5 (all PM is expected to be PM2.5)	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
Combined-Cycle CT	Several. See Attachment G1.	Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 76.7

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	Yes	76.7	0	0	Top level of control. No reduction expected from uncontrolled natural gasfired unit

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top co	ntrol option ⊠ Yes □	No If	Yes, go to Part IV	
economic impacts are to be consid	ered before filling this Part.			feasible BACT options listed in Part II for whice the state of the sta
APP-214c.				
BACT Option	Total Annualized (TAC, \$/ye	Cost	Effectiveness (\$/ton Incrementation (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Outlan	Toxics Impact		Adverse Impact		O manage de l'Oction de
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	0	No energy impact

Part VI. BACT Recommendation

BACT Option Recommended: Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel (ULSD) as backup. Emissions will not exceed 0.0041 lb/MMBtu for natural gas firing without duct firing at full operating load; 0.0081 lb/MMBtu for natural gas firing with duct firing at full operating load; and 0.020 lb/MMBtu for ULSD firing at full operating load.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
11	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: CT2/DB2	
Unit Description: Combined-Cycle Combustion Turbine #2	
Pollutant: SO2	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

To ensure a sufficiently broad and comprehensive search of control alternatives, references other than the RBLC data should be investigated and documented. These references include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Source	Facility	Control Technology	Reference
Combined-Cycle CT	Several. See Attachment G1.	Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 19.7

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	Yes	19.7	0	0	Top level of control

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top co	ntrol option ⊠ Yes □	No If	Yes, go to Part IV	
economic impacts are to be consid	ered before filling this Part.			feasible BACT options listed in Part II for whice feasible BACT options listed in Part II for wh
APP-214c.				
BACT Option	Total Annualized (TAC, \$/ye	Cost	Effectiveness (\$/ton Incrementa (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Outlan	Toxics Impact		Adverse Impact		O company to /Dational to
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	0	No energy impact

Part VI. BACT Recommendation

BACT Option Recommended: Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel (ULSD) as backup. The natural gas will have a maximum sulfur content of 0.5 grains per 100 cubic feet of gas. ULSD fuel, which will be used as backup, will have a maximum sulfur content of 15 ppm by weight. ULSD firing will be limited to no more than 720 hours per rolling 12-month period.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
7	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC	
Unit No.: CT2/DB2	
Unit Description: Combined-Cycle Combustion Turbine #2	
Pollutant: GHGs	

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

Source	Facility	Control Technology	Reference
None	None	Carbon Capture & Sequestration	RBLC, CT DEEP BACT Database, EPA GHG BACT guidance

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 2,032,758

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Carbon Capture & Sequestration	Yes	265,602	1,062,407	80	Top level of control. Has never been implemented on a utility scale, privately financed project. Reduction is from proposed allowable emissions.
Advanced Combined-Cycle Combustion Turbine Technology	Yes	1,328,009	704,749	35	Top level of control demonstrated in practice.

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top control opti	ion 🗌 Yes 🔀 No	If Yes, g	o to Part IV	
Complete Attachment G2: Cost/Economic Imeconomic impacts are to be considered before	•	APP-214c for ea	ach technically fea	sible BACT options listed in Part II for which
Provide the following economic information for APP-214c.	or each of the BACT options	with completed	d Attachment G2:	Cost/Economic Impact Analysis, DEEP-NSR
	Total	Cost Effecti	veness (\$/ton)	
BACT Option	Annualized Cost (TAC, \$/year)	Average	Incremental (optional)	Comments/Rationale
Carbon Capture & Sequestration	\$151,217,981	142	N/A	TAC based upon annualized cost of \$44/MWh from the Interagency Task Force. Costs are not economically feasible.

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Outlon	Toxics Impact		Adverse Impact		O a manage de l'Oction e la
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Carbon Capture & Sequestration (CCS)	No	N/A	Yes	See Comment	CCS results in an estimated increase in net heat rate resulting in a direct increase of 15% for all pollutants on a lb/MWh basis.
Advanced Combined-Cycle Combustion Turbine Technlogy	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Carbon Capture & Sequestration	15% increase in net heat rate over baseline	Based upon Interagency Task Force
Advanced Combined-Cycle Combustion Turbine Technlogy	0	This is the baseline technology

Part VI. BACT Recommendation

BACT Option Recommended: Advanced Combined-Cycle Combustion Turbine Technlogy. The project will meet an annual gross heat rate of 7,120 Btu/kWh. This heat rate takes into account a 12.8% performance degradation over the life of the unit to account for design margin, wear and tear, and degradation of plant auxiliaries.

Justification: The selected controls are the top level of control demonstrated in practice.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
9	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
1	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC
Unit No.: CT2/DB2
Unit Description: Combined-Cycle Combustion Turbine #2
Pollutant: Sulfuric Acid Mist (H2SO4)

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

Source	Facility	Control Technology	Reference
Combined-Cycle CT	Several. See Attachment G1.	Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 12.7

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	Yes	12.7	0	0	Top level of control

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top co	ntrol option ⊠ Yes □	No If	Yes, go to Part IV	
economic impacts are to be consid	ered before filling this Part.			feasible BACT options listed in Part II for whice the state of the sta
APP-214c.				
BACT Option	Total Annualized (TAC, \$/ye	Cost	Effectiveness (\$/ton Incrementation (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Outlan	Toxics Impact		Adverse Impact		O a manufa / Dational a
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	No	N/A	No	N/A	

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel as backup	0	No energy impact.

Part VI. BACT Recommendation

BACT Option Recommended: Pipeline quality natural gas as primary fuel with limited firing of ultra-low sulfur diesel (ULSD) as backup. The natural gas will have a maximum sulfur content of 0.5 grains per 100 cubic feet of gas. ULSD, which will be used as backup, will have a maximum sulfur content of 15 ppm by weight. ULSD firing will be limited to no more than 720 hours per rolling 12-month period.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
4	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Attachment G: Analysis of Best Available Control Technology (BACT)

(Complete this form for each pollutant for which BACT must be incorporated. Duplicate this form as necessary.)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Applicant Name: CPV Towantic, LLC
Unit No.: CT2/DB2
Unit Description: Combined-Cycle Combustion Turbine #2
Pollutant: NH3

Part I. Identify All Control Technologies/ Options

List all available control systems that have practical potential for application to this type of unit.

Source	Facility	Control Technology	Reference
Combined-Cycle CT	Several. See Attachment G1.	NH3 Injection Control System	RBLC, CT DEEP BACT Database, permits

Part II. Rank All Control Options by Technical Feasibility and Control Effectiveness

List all Control Options considered in Part I and identify which options are technically feasible. First list the technically feasible control options in descending order of Overall Pollution Reduction Efficiency and then list the technically infeasible options. If a control option is determined to be technically infeasible, specify the reason in the Comments/Rationale column. DO NOT list the Post-BACT Emissions Rate, Emissions Reduction, and the Overall Pollution Reduction Efficiency (%) for technically infeasible control options. Technically infeasibility should be based on physical, chemical, and engineering principles that would preclude the successful use of the control option on the emissions unit under review. In addition, complete Attachment G1: Background Search – Existing BACT determinations (DEEP-NSR-APP-214b) to provide more detailed information regarding each of the technically feasible options listed below. (Duplicate this page as necessary)

Baseline Emissions Rate (tpy): 77.7

BACT Option	Technically Feasible? (Yes/No)	Allowable Emissions Rate	Emissions Reduction (tpy)	Overall Pollution Reduction Efficiency (%)	Comments/Rationale
NH3 Injection Control System	Yes	77.7	0	N/A	Top level of control

Part III. Economic Impacts/Cost Effectiveness

Is the proposed BACT the top co	ontrol option ⊠ Yes [□ No	If Yes, g	o to Part IV	
Complete Attachment G2: Cost/Ec economic impacts are to be considered.		EP-NSR-A	PP-214c for ea	ach technically fea	sible BACT options listed in Part II for which
Provide the following economic info APP-214c.	ormation for each of the BAC	T options v	with completed	Attachment G2:	Cost/Economic Impact Analysis, DEEP-NSF
	Tota		Cost Effective	veness (\$/ton)	
BACT Option	Annualize (TAC, \$/		Average	Incremental (optional)	Comments/Rationale

Part IV. Environmental Impact Analysis

Provide the following information regarding environmental impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the environmental impact analysis should be done for that option only.

DACT Ontion	Toxics Impact		Adverse Impact		Commente/Dationals
BACT Option	Yes/No	amount/ton	Yes/No	amount/ton	Comments/Rationale
NH3 Injection Control System	No	N/A	No	N/A	Impacts associated with SCR provided on Attachment G for NOx.

Part V. Energy Impact Analysis

Provide the following information regarding energy impacts for each of the technically feasible BACT options listed in Part II. If the BACT option chosen is the top control option, the energy impact analysis should be done for that option only.

Baseline (specify units): N/A

BACT Option	Incremental Increase Over Baseline (specify units)	Comments/Rationale
NH3 Injection Control System	0	Marginal increase in parasitic load

Part VI. BACT Recommendation

BACT Option Recommended: NH3 slip emissions will be limited to no greater than 5.0 ppmvd at 15% O2 during gas firing and 5.0 ppmvd at 15% O2 during ULSD firing.

Justification: The selected controls are the top level of control.

Part VII. Additional Forms/Attachments

Indicate the number of each type of form included as part of this BACT analysis.

Number of Forms	Form Number	Form Name	Mandatory?
7	DEEP-NSR-APP-214b	Attachment G1: Background Search – Existing BACT Determinations	Yes
0	DEEP-NSR-APP-214c	Attachment G2: Cost/Economic Impact Analysis	Yes, for each economic consideration
1	DEEP-NSR-APP-214d	Attachment G3: Summary of Best Available Control Technology	Yes

Additional Attachments: 0

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: CO
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER	
Source	Auxiliary Boile	Auxiliary Boiler	
Facility/Location	Virginia Elect	ric and Power Company / Brunswick Co., Freeman, VA	
Permitting Authority	Virginia Depa	rtment of Environmental Quality	
Permit No.	52404		
Capacity (specify units)	66.7 MMBtu/h	nr heat input	
BACT/LAER Determination	Good combus	Good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Initial performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		50 ppmvd; 2.5 lb/hr	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference	Significant Dete	of Virginia Department of Environmental Quality, Prevention of erioration Permit, Virginia Electric and Power Company - Brunswick Station, Registration Number 52404, March 12, 2013.	

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: CO
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER	
Source	Auxiliary Boile	Auxiliary Boiler	
Facility/Location	Carroll Count	Carroll County Energy LLC / Washington Township, OH	
Permitting Authority	Ohio Environ	mental Protection Agency	
Permit No.	P0113762		
Capacity (specify units)	99 MMBtu/hr	heat input	
BACT/LAER Determination	Good combus	Good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		0.055 lb/MMBtu of heat input; 5.45 lb/hr	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference		ental Protection Agency, Final, Division of Air Pollution Control, Permit-to-loculus Energy LLC, Facility ID 0210002025, Permit Number P0113762, 013.	

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: CO
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER	
Source	Auxiliary Boile	Auxiliary Boiler	
Facility/Location	Cricket Valley	Cricket Valley Energy Center LLC / Dover Plains, NY	
Permitting Authority	New York Sta	ate Department of Environmental Conservation	
Permit No.	3-1326-0027	3-1326-00275/00004	
Capacity (specify units)	60 MMBtu/hr	60 MMBtu/hr heat input	
BACT/LAER Determination	Good combus	Good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Initial performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		0.0375 lbs/MMBtu	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference	a Major Station	Department of Environmental Conservation; Preconstruction Permit for eary Source; Cricket Valley Energy Center, Dover Plains, NY; Air State ID 3-1326-00275/00004; September 27, 2012.	

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: CO
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER	
Source	Auxiliary Boil	Auxiliary Boiler	
Facility/Location	Dominion Wa	arren County Power Station / Warren County, VA	
Permitting Authority	Virginia Depa	rtment of Environmental Quality	
Permit No.	81391		
Capacity (specify units)	88.1 MMBtu/l	nr heat input	
BACT/LAER Determination	Good combu	Good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Initial performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		0.037 lbs/MMBtu	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference Significant Dete Virginia Electric		of Virginia Department of Environmental Quality, Prevention of erioration Permit Stationary Source Permit To Construct and Operate, and Power Company - Warren County Power Station, Registration December 17, 2010.	

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: CO
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER	
Source	Auxiliary Boil	er	
Facility/Location	Green Energ	Green Energy Partners/Stonewall LLC / Leesburg, VA	
Permitting Authority	Virginia Depa	artment of Environmental Quality	
Permit No.	73826	73826	
Capacity (specify units)	75 MMBtu/hr	75 MMBtu/hr heat input per unit	
BACT/LAER Determination	Good combu	Good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Initial performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		50 ppmv; 2.78 lb/hr	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference	Environmental New Source Re	Partners/Stonewall LLC, Commonwealth of Virginia Quality, Prevention of Significant Deterioration Perreview Permit, Stationary Source Permit to Constructumber 73826, April 30, 2013.	mit, Non-Attainment

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boilers
Pollutant: CO
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER	
Source	Auxiliary Boile	er	
Facility/Location	Hess Newark	Energy Center / Newark, NJ	
Permitting Authority	New Jersey [Department of Environmental Protection	
Permit No.	BOP110001		
Capacity (specify units)	66.2 MMBtu/l	hr heat input	
BACT/LAER Determination	Good combus	Good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Initial performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		50 ppmvd @ 7% O2; 2.45 lb/hr	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference Bureau of Air Po Operating Perm		ersey Department of Environmental Protection; Division of Air Quality, ermits; Air Pollution Control Operating Permit PSD Permit and Initial nit for a PSD Affected Facility; Permit Activity Number: BOP110001 st Number: 08857; Hess Newark Energy Center, Newark, NJ; 11/1/2012	

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: CO
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER	
Source	Auxiliary Boil	Auxiliary Boiler	
Facility/Location	Kleen Energy	Kleen Energy Systems LLV / Middletown, CT	
Permitting Authority	Connecticut [Department of Energy & Environmental Protection	
Permit No.	0134		
Capacity (specify units)	73.5 MMBtu/l	nr heat input per unit	
BACT/LAER Determination	Good combu	Good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Engineering calculations	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		5.3 lb/hr	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference	Management, N Source, Kleen	Popertment of Energy & Environmental Protection, Bureau of Air New Source Review Permit to Construct and Operate a Stationary Energy Systems LLC, Middletown, CT, Town-Permit Numbers 104-0134, per 246, May 22, 2012.	

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: CO
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER	
Source	Auxiliary Boile	Auxiliary Boiler	
Facility/Location	Oregon Clear	Oregon Clean Energy Center / Oregon, OH	
Permitting Authority	Ohio Environ	mental Protection Agency	
Permit No.	P0110840	P0110840	
Capacity (specify units)	99 MMBtu/hr	99 MMBtu/hr heat input per unit	
BACT/LAER Determination	Good combus	Good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		0.055 lb/MMBtu of heat input; 5.45 lbs/hr	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference		ental Protection Agency, Final, Division of Air Pollution Control, Permit-to- on Clean Energy Center, Facility ID 0448020102, Permit Number e 18, 2013.	

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: CO
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER	
Source	Auxiliary Boile	Auxiliary Boiler	
Facility/Location		Westfield Land Development Company, LLC - Pioneer Valley Energy Center / Westfield, MA	
Permitting Authority	Massachuset	Massachusetts Department of Environmental Protection	
Permit No.	Plan #: 1-B-0	Plan #: 1-B-08-037; Trans. #: X223780	
Capacity (specify units)	21 MMBtu/hr heat input		
BACT/LAER Determination	Good combus	Good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Initial performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		0.037 lbs/MMBtu; 0.74 lbs/hr	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference Department of E to Construct, W		th of Massachusetts, Executive Office of Energy & Environmental Affairs, f Environmental Protection Western Regional Office; Conditional Approval Westfield Land Development Company, LLC - Pioneer Valley Energy #: 1-B-08-037; Trans. #: X223780; December 31, 2010.	

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: CO
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER	
Source	2 - Auxiliary E	2 - Auxiliary Boilers	
Facility/Location	Renaissance	Renaissance Power LLC / Carson City, Michigan	
Permitting Authority	Michigan Dep	Michigan Department of Environmental Quality	
Permit No.	51-13		
Capacity (specify units)	40 MMBtu/hr	heat input per unit	
BACT/LAER Determination	Good combus	Good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		0.036 lb/MMBtu (each unit)	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference	•	rtment of Environmental Quality, Air Quality Division, Permit to Install 51- enaissance Power LLC, State Registration Number N6873, November 1,	

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: CO
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER	
Source	Auxiliary Boile	Auxiliary Boiler	
Facility/Location	Sunbury Gen	Sunbury Generation LP / Snyder, PA	
Permitting Authority	Pennsylvania	Department of Environmental Protection	
Permit No.	55-00001E	55-00001E	
Capacity (specify units)	106 MMBtu/h	106 MMBtu/hr heat input	
BACT/LAER Determination	Good combus	Good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Initial performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		0.074 lbs/MMBtu	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference		Comprehensive Report, 11/07/2013; for Sunbury Generation LP facility, rmit ID 55-00001E, 4/1/2013.	

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: NOx
BACT Option: Ultra Low-NOx burners and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER	
Source	Auxiliary Boile	Auxiliary Boiler	
Facility/Location	Virginia Elect	Virginia Electric and Power Company / Brunswick Co., Freeman, VA	
Permitting Authority	Virginia Depa	rtment of Environmental Quality	
Permit No.	52404	52404	
Capacity (specify units)	66.7 MMBtu/h	66.7 MMBtu/hr heat input	
BACT/LAER Determination	Low-NOx bur	Low-NOx burners and good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Initial performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		9 ppmvd; 0.8 lb/hr	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference	Significant Dete	of Virginia Department of Environmental Quality, Prevention of erioration Permit, Virginia Electric and Power Company - Brunswick Station, Registration Number 52404, March 12, 2013.	

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: NOx
BACT Option: Ultra Low-NOx burners and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Carroll Count	Carroll County Energy LLC / Washington Township, OH		
Permitting Authority	Ohio Environ	Ohio Environmental Protection Agency		
Permit No.	P0113762	P0113762		
Capacity (specify units)	99 MMBtu/hr	99 MMBtu/hr heat input		
BACT/LAER Determination	Low-NOx bur	Low-NOx burners, flue gas re-circulation and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.020 lb/MMBtu of heat input; 1.98 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Ohio Environmental Protection Agency, Final, Division of Air Pollution Control, Permit-to- nstall for Caroll County Energy LLC, Facility ID 0210002025, Permit Number P0113762, November 5, 2013.			

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: NOx
BACT Option: Ultra Low-NOx burners and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Cricket Valley	Cricket Valley Energy Center LLC / Dover Plains, NY		
Permitting Authority	New York Sta	New York State Department of Environmental Conservation		
Permit No.	3-1326-0027	3-1326-00275/00004		
Capacity (specify units)	60 MMBtu/hr	60 MMBtu/hr heat input		
BACT/LAER Determination	Low-NOx bur	Low-NOx burners and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Initial performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.011 lbs/MMBtu; 9 ppmvd		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	New York State Department of Environmental Conservation; Preconstruction Permit for a Major Stationary Source; Cricket Valley Energy Center, Dover Plains, NY; Air State Facility Permit ID 3-1326-00275/00004; September 27, 2012.			

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: NOx
BACT Option: Ultra-Low-NOx burners and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	rmination:	⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Green Energy	Green Energy Partners/Stonewall LLC / Leesburg, VA		
Permitting Authority	Virginia Depa	Virginia Department of Environmental Quality		
Permit No.	73826	73826		
Capacity (specify units)	75 MMBtu/hr	75 MMBtu/hr heat input per unit		
BACT/LAER Determination	Ultra-Low-NC	Ultra-Low-NOx burners and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Initial performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		9 ppmv; 0.83 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Green Energy Partners/Stonewall LLC, Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit, Non-Attainment New Source Review Permit, Stationary Source Permit to Construction and Operate, Registration Number 73826, April 30, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boilers
Pollutant: NOx
BACT Option: Ultra Low-NOx burners and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Hess Newark	Hess Newark Energy Center / Newark, NJ		
Permitting Authority	New Jersey [New Jersey Department of Environmental Protection		
Permit No.	BOP110001	BOP110001		
Capacity (specify units)	66.2 MMBtu/l	66.2 MMBtu/hr heat input		
BACT/LAER Determination	Ultra Low-NC	Ultra Low-NOx burners and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Initial performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		9 ppmvd; 0.66 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	State of New Jersey Department of Environmental Protection; Division of Air Quality, Bureau of Air Permits; Air Pollution Control Operating Permit PSD Permit and Initial Operating Permit for a PSD Affected Facility; Permit Activity Number: BOP110001 Program Interest Number: 08857; Hess Newark Energy Center, Newark, NJ; 11/1/2012			

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: NOx
BACT Option: Ultra-Low-NOx burners and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Kleen Energy	Systems LLV / Middletown, CT		
Permitting Authority	Connecticut [Department of Energy & Environmental Protection		
Permit No.	0134			
Capacity (specify units)	73.5 MMBtu/l	73.5 MMBtu/hr heat input per unit		
BACT/LAER Determination	Ultra-low-NO	Ultra-low-NOx burners and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.045 lb/MMBtu; 3.31 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Connecticut Department of Energy & Environmental Protection, Bureau of Air Management, New Source Review Permit to Construct and Operate a Stationary Source, Kleen Energy Systems LLC, Middletown, CT, Town-Permit Numbers 104-0134, Premises Number 246, May 22, 2012.			

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: NOx
BACT Option: Ultra-Low-NOx burners and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Oregon Clear	n Energy Center / Oregon, OH		
Permitting Authority	Ohio Environ	mental Protection Agency		
Permit No.	P0110840			
Capacity (specify units)	99 MMBtu/hr	99 MMBtu/hr heat input per unit		
BACT/LAER Determination	Ultra-Low-NC	Ultra-Low-NOx burners, flue gas re-circulation, and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.020 lb/MMBtu of heat input; 1.98 lbs/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Ohio Environmental Protection Agency, Final, Division of Air Pollution Control, Permit-to- Install for Oregon Clean Energy Center, Facility ID 0448020102, Permit Number P0110840, June 18, 2013.			

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: NOx
BACT Option: Ultra-Low-NOx burners and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT	LAER	
Source	2 - Auxiliary E	2 - Auxiliary Boilers		
Facility/Location	Renaissance	Power LLC / Carson City, N	/lichigan	
Permitting Authority	Michigan Der	partment of Environmental C	Quality	
Permit No.	51-13	51-13		
Capacity (specify units)	40 MMBtu/hr	40 MMBtu/hr heat input per unit		
BACT/LAER Determination	Ultra-Low-NC	Ultra-Low-NOx burners and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.035 lb/MMBtu (each unit)		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference			ality, Air Quality Division, Permit to Install 51- te Registration Number N6873, November 1,	

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: VOC
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Virginia Elect	ric and Power Company / Brunswick Co., Freeman, VA		
Permitting Authority	Virginia Depa	rtment of Environmental Quality		
Permit No.	52404	52404		
Capacity (specify units)	66.7 MMBtu/l	nr heat input		
BACT/LAER Determination	Good combus	stion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Initial performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.4 lb/hr; 0.006 lb/MMBtu		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit, Virginia Electric and Power Company - Brunswick County Power Station, Registration Number 52404, March 12, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: VOC
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Carroll Count	y Energy LLC / Washington Township, OH		
Permitting Authority	Ohio Environ	mental Protection Agency		
Permit No.	P0113762	P0113762		
Capacity (specify units)	99 MMBtu/hr	heat input		
BACT/LAER Determination	Good combus	Good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering Calculations		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.006 lb/MMBtu of heat input; 0.59 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Ohio Environmental Protection Agency, Final, Division of Air Pollution Control, Permit-to-Install for Caroll County Energy LLC, Facility ID 0210002025, Permit Number P0113762, November 5, 2013.			

pplicant Name: CPV Towantic, LLC	_
nit No.: AB	
nit Description: Auxiliary Boiler	
ollutant: VOC	
ACT Option: Good combustion practices	

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT ⊠ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Cricket Valley	Energy Center LLC / Dover Plains, NY		
Permitting Authority	New York Sta	ate Department of Environmental Conservation		
Permit No.	3-1326-00275	5/0004		
Capacity (specify units)	60 MMBtu/hr	heat input		
BACT/LAER Determination	Good combus	Good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Initial performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.0015 lbs/MMBtu		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	New York State Department of Environmental Conservation; Preconstruction Permit for a Major Stationary Source; Cricket Valley Energy Center, Dover Plains, NY; Air State Facility Permit ID 3-1326-00275/00004; September 27, 2012.			

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: VOC
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Auxiliary Boil	Auxiliary Boiler		
Facility/Location	Dominion Wa	arren County Power Station / Warren County, VA		
Permitting Authority	Virginia Depa	artment of Environmental Quality		
Permit No.	81391			
Capacity (specify units)	88.1 MMBtu/l	88.1 MMBtu/hr heat input		
BACT/LAER Determination	Good combu	Good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering Calculations		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.47 lbs/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit Stationary Source Permit To Construct and Operate, Virginia Electric and Power Company - Warren County Power Station, Registration Number 81391, December 17, 2010.			

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: VOC
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT	LAER	
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Green Energy	y Partners/Stonewall LLC / Lees	sburg, VA	
Permitting Authority	Virginia Depa	rtment of Environmental Quality	у	
Permit No.	73826	73826		
Capacity (specify units)	75 MMBtu/hr	75 MMBtu/hr heat input per unit		
BACT/LAER Determination	Good combus	Good combustion practices		
Compliance Achieved? (Yes/N	lo)	No		
Method of Compliance Determination		NA		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.002 lb/MMBtu; 0.15 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Environmental New Source Re	Quality, Prevention of Significar	onwealth of Virginia Department of nt Deterioration Permit, Non-Attainment e Permit to Construction and Operate,	

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boilers
Pollutant: VOC
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	Auxiliary Boil	Auxiliary Boiler		
Facility/Location	Hess Newark	Energy Center / Newark, NJ		
Permitting Authority	New Jersey [Department of Environmental Protection		
Permit No.	BOP110001			
Capacity (specify units)	66.2 MMBtu/l	hr heat input		
BACT/LAER Determination	Good combu	Good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Initial performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.27 lb/hr; 0.004 lb/MMBtu		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	State of New Jersey Department of Environmental Protection; Division of Air Quality, Bureau of Air Permits; Air Pollution Control Operating Permit PSD Permit and Initial Operating Permit for a PSD Affected Facility; Permit Activity Number: BOP110001 Program Interest Number: 08857; Hess Newark Energy Center, Newark, NJ; 11/1/2012			

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: VOC
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Kleen Energy	Systems LLV / Middletown, CT		
Permitting Authority	Connecticut [Department of Energy & Environmental Protection		
Permit No.	0134	0134		
Capacity (specify units)	73.5 MMBtu/l	73.5 MMBtu/hr heat input per unit		
BACT/LAER Determination	Good combus	Good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering calculations		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.28 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Connecticut Department of Energy & Environmental Protection, Bureau of Air Management, New Source Review Permit to Construct and Operate a Stationary Source, Kleen Energy Systems LLC, Middletown, CT, Town-Permit Numbers 104-0134, Premises Number 246, May 22, 2012.			

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: VOC
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination: ⊠ BACT □ LAER				
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Oregon Clear	Oregon Clean Energy Center / Oregon, OH		
Permitting Authority	Ohio Environ	Ohio Environmental Protection Agency		
Permit No.	P0110840	P0110840		
Capacity (specify units)	99 MMBtu/hr	99 MMBtu/hr heat input per unit		
BACT/LAER Determination	Good combus	Good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering Calculations		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.006 lb/MMBtu of heat input; 0.59 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Ohio Environmental Protection Agency, Final, Division of Air Pollution Control, Permit-to- Install for Oregon Clean Energy Center, Facility ID 0448020102, Permit Number P0110840, June 18, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: VOC
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	2 - Auxiliary E	2 - Auxiliary Boilers		
Facility/Location	Renaissance	Renaissance Power LLC / Carson City, Michigan		
Permitting Authority	Michigan Dep	Michigan Department of Environmental Quality		
Permit No.	51-13	51-13		
Capacity (specify units)	40 MMBtu/hr	40 MMBtu/hr heat input per unit		
BACT/LAER Determination	Good combus	Good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.005 lb/MMBtu (each unit)		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Michigan Department of Environmental Quality, Air Quality Division, Permit to Install 51-13, Issued to Renaissance Power LLC, State Registration Number N6873, November 1, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: VOC
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:				
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Sunbury Gen	Sunbury Generation LP / Snyder, PA		
Permitting Authority	Pennsylvania	Pennsylvania Department of Environmental Protection		
Permit No.	55-00001E	55-00001E		
Capacity (specify units)	106 MMBtu/h	106 MMBtu/hr heat input		
BACT/LAER Determination	Good combus	Good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Initial performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.005 lbs/MMBtu		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference		Comprehensive Report, 11/07/2013; for Sunbury Generation LP facility, rmit ID 55-00001E, 4/1/2013.		

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: PM10/PM2.5
BACT Option: Good combustion practices and pipeline-quality natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:				
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Virginia Elect	Virginia Electric and Power Company / Brunswick Co., Freeman, VA		
Permitting Authority	Virginia Depa	Virginia Department of Environmental Quality		
Permit No.	52404	52404		
Capacity (specify units)	66.7 MMBtu/l	66.7 MMBtu/hr heat input		
BACT/LAER Determination	Good combus	Good combustion practices and pipeline-quality natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering Calculations		
Actions Taken for Noncompliance		NA NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.5 lb/hr; 0.0075 lb/MMBtu		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Significant Dete	h of Virginia Department of Environmental Quality, Prevention of erioration Permit, Virginia Electric and Power Company - Brunswick Station, Registration Number 52404, March 12, 2013.		

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: PM10/PM2.5
BACT Option: Good combustion practices and pipeline-quality natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:				
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Carroll Count	Carroll County Energy LLC / Washington Township, OH		
Permitting Authority	Ohio Environ	Ohio Environmental Protection Agency		
Permit No.	P0113762	P0113762		
Capacity (specify units)	99 MMBtu/hr	99 MMBtu/hr heat input		
BACT/LAER Determination	Good combus	Good combustion practices and pipeline-quality natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering Calculations		
Actions Taken for Noncomplia	ince	NA		
Baseline Emissions Rate (spe	cify units)	Not Available		
Allowable Emissions Rate (specify units)		0.008 lb/MMBtu of heat input; 0.79 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Ohio Environmental Protection Agency, Final, Division of Air Pollution Control, Permit-to-Install for Caroll County Energy LLC, Facility ID 0210002025, Permit Number P0113762, November 5, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: PM10/PM2.5
BACT Option: Good combustion practices and pipeline-quality natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:				
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Cricket Valley	Cricket Valley Energy Center LLC / Dover Plains, NY		
Permitting Authority	New York Sta	New York State Department of Environmental Conservation		
Permit No.	3-1326-00275	3-1326-00275/00004		
Capacity (specify units)	60 MMBtu/hr	60 MMBtu/hr heat input		
BACT/LAER Determination	Good combus	Good combustion practices and pipeline-quality natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Initial performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.005 lbs/MMBtu		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	New York State Department of Environmental Conservation; Preconstruction Permit for a Major Stationary Source; Cricket Valley Energy Center, Dover Plains, NY; Air State Facility Permit ID 3-1326-00275/00004; September 27, 2012.			

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: PM10/PM2.5
BACT Option: Good combustion practices and pipeline-quality natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:				
Source	Auxiliary Boil	Auxiliary Boiler		
Facility/Location	Dominion Wa	Dominion Warren County Power Station / Warren County, VA		
Permitting Authority	Virginia Depa	artment of Environmental Quality		
Permit No.	81391	81391		
Capacity (specify units)	88.1 MMBtu/l	88.1 MMBtu/hr heat input		
BACT/LAER Determination	Good combu	Good combustion practices and pipeline-quality natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering Calculations		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.44 lbs/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit Stationary Source Permit To Construct and Operate, Virginia Electric and Power Company - Warren County Power Station, Registration Number 81391, December 17, 2010.			

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: PM10/PM2.5
BACT Option: Good combustion practices and pipeline-quality natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	Auxiliary Boil	Auxiliary Boiler		
Facility/Location	Green Energ	y Partners/Stonewall LLC / Leesburg, VA		
Permitting Authority	Virginia Depa	rtment of Environmental Quality		
Permit No.	73826			
Capacity (specify units)	75 MMBtu/hr	heat input per unit		
BACT/LAER Determination	Good combu	stion practices and pipeline-quality natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		NA		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.002 lb/MMBtu; 0.15 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Green Energy Partners/Stonewall LLC, Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit, Non-Attain New Source Review Permit, Stationary Source Permit to Construction and Operation Registration Number 73826, April 30, 2013.			

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boilers
Pollutant: PM10/PM2.5
BACT Option: Good combustion practices and pipeline-quality natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	Auxiliary Boil	Auxiliary Boiler		
Facility/Location	Hess Newark	Hess Newark Energy Center / Newark, NJ		
Permitting Authority	New Jersey [New Jersey Department of Environmental Protection		
Permit No.	BOP110001			
Capacity (specify units)	66.2 MMBtu/l	66.2 MMBtu/hr heat input		
BACT/LAER Determination	Good combu	Good combustion practices and pipeline-quality natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Initial performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.33 lb/hr; 0.005 lb/MMBtu		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	State of New Jersey Department of Environmental Protection; Division of Air Quality, Bureau of Air Permits; Air Pollution Control Operating Permit PSD Permit and Initial Operating Permit for a PSD Affected Facility; Permit Activity Number: BOP110001 Program Interest Number: 08857; Hess Newark Energy Center, Newark, NJ; 11/1/2012			

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: PM10/PM2.5
BACT Option: Good combustion practices and pipeline-quality natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Kleen Energy	Kleen Energy Systems LLV / Middletown, CT		
Permitting Authority	Connecticut [Department of Energy & Environmental Protection		
Permit No.	0134			
Capacity (specify units)	73.5 MMBtu/l	73.5 MMBtu/hr heat input per unit		
BACT/LAER Determination	Good combus	Good combustion practices and pipeline-quality natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering calculations		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.46 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Connecticut Department of Energy & Environmental Protection, Bureau of Air Management, New Source Review Permit to Construct and Operate a Stationary Source, Kleen Energy Systems LLC, Middletown, CT, Town-Permit Numbers 104-0134, Premises Number 246, May 22, 2012.			

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: PM10/PM2.5
BACT Option: Good combustion practices and pipeline-quality natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Oregon Clear	Oregon Clean Energy Center / Oregon, OH		
Permitting Authority	Ohio Environ	Ohio Environmental Protection Agency		
Permit No.	P0110840	P0110840		
Capacity (specify units)	99 MMBtu/hr	99 MMBtu/hr heat input per unit		
BACT/LAER Determination	Good combus	Good combustion practices and pipeline-quality natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering Calculations		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.008 lb/MMBtu of heat input; 0.79 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference		ental Protection Agency, Final, Division of Air Pollution Control, Permit-to- on Clean Energy Center, Facility ID 0448020102, Permit Number e 18, 2013.		

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: PM10/PM2.5
BACT Option: Good combustion practices and pipeline-quality natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location		Westfield Land Development Company, LLC - Pioneer Valley Energy Center / Westfield, MA		
Permitting Authority	Massachuset	etts Department of Environmental Protection		
Permit No.	Plan #: 1-B-0	08-037; Trans. #: X223780		
Capacity (specify units)	21 MMBtu/hr	21 MMBtu/hr heat input		
BACT/LAER Determination	Good combus	ustion practices and pipeline-quality natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Initial performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.0048 lbs/MMBtu; 0.10 lbs/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Commonwealth of Massachusetts, Executive Office of Energy & Environmental Affairs, Department of Environmental Protection Western Regional Office; Conditional Approval to Construct, Westfield Land Development Company, LLC - Pioneer Valley Energy Center, Plan #: 1-B-08-037; Trans. #: X223780; December 31, 2010.			

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: PM10/PM2.5
BACT Option: Good combustion practices and pipeline-quality natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	2 - Auxiliary E	2 - Auxiliary Boilers		
Facility/Location	Renaissance	Renaissance Power LLC / Carson City, Michigan		
Permitting Authority	Michigan Dep	Michigan Department of Environmental Quality		
Permit No.	51-13			
Capacity (specify units)	40 MMBtu/hr	40 MMBtu/hr heat input per unit		
BACT/LAER Determination	Good combus	Good combustion practices and pipeline-quality natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.005 lb/MMBtu (each unit)		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Michigan Department of Environmental Quality, Air Quality Division, Permit to Install 51-13, Issued to Renaissance Power LLC, State Registration Number N6873, November 1, 2013.			

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: PM10/PM2.5
BACT Option: Good combustion practices and pipeline-quality natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Sunbury Gen	Sunbury Generation LP / Snyder, PA		
Permitting Authority	Pennsylvania	Pennsylvania Department of Environmental Protection		
Permit No.	55-00001E	55-00001E		
Capacity (specify units)	106 MMBtu/h	106 MMBtu/hr heat input		
BACT/LAER Determination	Good combus	Good combustion practices and pipeline-quality natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Initial performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.008 lbs/MMBtu		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton rem	oved)	Not Available		
Reference		Comprehensive Report, 11/07/2013; for Sunbury Generation LP facility, rmit ID 55-00001E, 4/1/2013.		

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: SO2
BACT Option: Use of low sulfur fuels - pipeline natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:				
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Carroll Count	Carroll County Energy LLC / Washington Township, OH		
Permitting Authority	Ohio Environ	Ohio Environmental Protection Agency		
Permit No.	P0113762	P0113762		
Capacity (specify units)	99 MMBtu/hr	99 MMBtu/hr heat input		
BACT/LAER Determination	Use of low su	Use of low sulfur fuels - pipeline natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering Calculations		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.0029 lb/MMBtu of heat input; 0.65 tons/yr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference		ental Protection Agency, Final, Division of Air Pollution Control, Permit-to-I County Energy LLC, Facility ID 0210002025, Permit Number P0113762, 013.		

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: SO2
BACT Option: Use of low sulfur fuels - pipeline natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Kleen Energy	Kleen Energy Systems LLV / Middletown, CT		
Permitting Authority	Connecticut [Department of Energy & Environmental Protection		
Permit No.	0134	0134		
Capacity (specify units)	73.5 MMBtu/l	73.5 MMBtu/hr heat input per unit		
BACT/LAER Determination	Use of low sulfur fuels - pipeline natural gas			
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering calculations		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.16 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Connecticut Department of Energy & Environmental Protection, Bureau of Air Management, New Source Review Permit to Construct and Operate a Stationary Source, Kleen Energy Systems LLC, Middletown, CT, Town-Permit Numbers 104-013-Premises Number 246, May 22, 2012.			

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: SO2
BACT Option: Use of low sulfur fuels - pipeline natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Oregon Clear	Oregon Clean Energy Center / Oregon, OH		
Permitting Authority	Ohio Environ	Ohio Environmental Protection Agency		
Permit No.	P0110840	P0110840		
Capacity (specify units)	99 MMBtu/hr	99 MMBtu/hr heat input per unit		
BACT/LAER Determination	Use of low su	Use of low sulfur fuels - pipeline natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering Calculations		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.0014 lb/MMBtu of heat input; 0.14 tons/yr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Ohio Environmental Protection Agency, Final, Division of Air Pollution Control, Permit-to Install for Oregon Clean Energy Center, Facility ID 0448020102, Permit Number P0110840, June 18, 2013.			

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: GHG
BACT Option: Good combustion practices and use of low carbon fuels (natural das)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Virginia Elect	Virginia Electric and Power Company / Brunswick Co., Freeman, VA		
Permitting Authority	Virginia Depa	Virginia Department of Environmental Quality		
Permit No.	52404	52404		
Capacity (specify units)	66.7 MMBtu/h	66.7 MMBtu/hr heat input		
BACT/LAER Determination	High efficience	High efficiency design and operation and use of low carbon fuels (natural gas)		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering Calcuations		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		34,182 tons/year		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Significant Dete	of Virginia Department of Environmental Quality, Prevention of erioration Permit, Virginia Electric and Power Company - Brunswick Station, Registration Number 52404, March 12, 2013.		

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: GHG / CO2e
BACT Ontion: Good combustion practices and use of low carbon fuels (natural das)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Carroll Count	Carroll County Energy LLC / Washington Township, OH		
Permitting Authority	Ohio Environ	Ohio Environmental Protection Agency		
Permit No.	P0113762	P0113762		
Capacity (specify units)	99 MMBtu/hr	99 MMBtu/hr heat input		
BACT/LAER Determination	Good combus	Good combustion practices and use of low carbon fuels (natural gas)		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering Calculations		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		26,259.76 tons/yr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference		mental Protection Agency, Final, Division of Air Pollution Control, Permit-to- oll County Energy LLC, Facility ID 0210002025, Permit Number P0113762, 2013.		

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: GHG
BACT Option: Good combustion practices and use of low carbon fuels (natural gas)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Auxiliary Boil	Auxiliary Boiler		
Facility/Location	Green Energ	Green Energy Partners/Stonewall LLC / Leesburg, VA		
Permitting Authority	Virginia Depa	artment of Environmental Quality		
Permit No.	73826			
Capacity (specify units)	75 MMBtu/hr	75 MMBtu/hr heat input per unit		
BACT/LAER Determination	Pipeline-quality natural gas and high efficiency design and operation			
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		NA		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		8,873 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference Environmental (New Source Re		Partners/Stonewall LLC, Commonwealth of Virginia Department of Quality, Prevention of Significant Deterioration Permit, Non-Attainment eview Permit, Stationary Source Permit to Construction and Operate, umber 73826, April 30, 2013.		

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: GHG / CO2e
BACT Ontion: Good combustion practices and use of low carbon fuels (natural das)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Oregon Clear	Oregon Clean Energy Center / Oregon, OH		
Permitting Authority	Ohio Environ	mental Protection Agency		
Permit No.	P0110840			
Capacity (specify units)	99 MMBtu/hr	99 MMBtu/hr heat input per unit		
BACT/LAER Determination	Good combus	Good combustion practices and use of low carbon fuels (natural gas)		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		11,671 tons/year		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference		ental Protection Agency, Final, Division of Air Pollution Control, Permit-to- on Clean Energy Center, Facility ID 0448020102, Permit Number e 18, 2013.		

Applicant Name: CPV Towantic, LLC
Unit No.: AB
Unit Description: Auxiliary Boiler
Pollutant: GHG
BACT Ontion: Good combustion practices and use of low carbon fuels (natural das)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	2 - Auxiliary E	2 - Auxiliary Boilers		
Facility/Location	Renaissance	Renaissance Power LLC / Carson City, Michigan		
Permitting Authority	Michigan Dep	Michigan Department of Environmental Quality		
Permit No.	51-13			
Capacity (specify units)	40 MMBtu/hr	heat input per unit		
BACT/LAER Determination	Good combus	Good combustion practices and use of low carbon fuels (natural gas)		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering calculation		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		11,503.7 tons per year (each unit)		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Michigan Department of Environmental Quality, Air Quality Division, Permit to Install 51 13, Issued to Renaissance Power LLC, State Registration Number N6873, November 1 2013.			

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: H2SO4
BACT Option: Use of low sulfur fuels - pipeline natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Carroll Count	Carroll County Energy LLC / Washington Township, OH		
Permitting Authority	Ohio Environ	Ohio Environmental Protection Agency		
Permit No.	P0113762	P0113762		
Capacity (specify units)	99 MMBtu/hr	99 MMBtu/hr heat input		
BACT/LAER Determination	Use of low su	Use of low sulfur fuels - pipeline natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering Calculations		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.00022 lb/MMBtu of heat input; 0.02 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference		ental Protection Agency, Final, Division of Air Pollution Control, Permit-to-loculus Energy LLC, Facility ID 0210002025, Permit Number P0113762, 013.		

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Jnit Description: Auxiliary Boiler
Pollutant: H2SO4
BACT Option: Use of low sulfur fuels - pipeline natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Auxiliary Boile	Auxiliary Boiler		
Facility/Location	Oregon Clear	Oregon Clean Energy Center / Oregon, OH		
Permitting Authority	Ohio Environ	mental Protection Agency		
Permit No.	P0110840			
Capacity (specify units)	99 MMBtu/hr	99 MMBtu/hr heat input per unit		
BACT/LAER Determination	Use of low su	Use of low sulfur fuels - pipeline natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering Calculations		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.00011 lb/MMBtu of heat input; 0.011 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference		ental Protection Agency, Final, Division of Air Pollution Control, Permit-to- on Clean Energy Center, Facility ID 0448020102, Permit Number e 18, 2013.		

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: CO
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	3 - Combined	3 - Combined-cycle combustion turbine units with duct-fired HRSG		
Facility/Location	Virginia Elect	Virginia Electric and Power Company / Brunswick Co., Freeman, VA		
Permitting Authority	Virginia Depa	Virginia Department of Environmental Quality		
Permit No.	52404	52404		
Capacity (specify units)	3,442 MMBtu	u/hr heat input per turbine		
BACT/LAER Determination	Oxidation cat	Oxidation catalyst system and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS and performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		1.5 ppmvd without DB burning; 2.4 ppmvd with DB firing (each unit)		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference Significant Dete		h of Virginia Department of Environmental Quality, Prevention of erioration Permit, Virginia Electric and Power Company - Brunswick Station, Registration Number 52404, March 12, 2013.		

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: CO
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	2 - Combined	2 - Combined-cycle combustion turbine units with duct burner / GE 7FA		
Facility/Location	Carroll Count	Carroll County Energy LLC / Washington Township, OH		
Permitting Authority	Ohio Environ	Ohio Environmental Protection Agency		
Permit No.	P0113762	P0113762		
Capacity (specify units)	2,045 MMBtu	/hr heat input per turbine		
BACT/LAER Determination	Catalytic oxid	lizer and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS and performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2 ppmv with & without DB firing; 12.5 lb/hr with DB firing; 9.9 lb/hr without DB firing		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference		ental Protection Agency, Final, Division of Air Pollution Control, Permit-to-I County Energy LLC, Facility ID 0210002025, Permit Number P0113762, 013.		

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: CO
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	3 - Combined	3 - Combined-cycle combustion turbine units with HRSG		
Facility/Location	Cricket Valley	y Energy Center LLC / Dover Plains, NY		
Permitting Authority	New York Sta	ate Department of Environmental Conservation		
Permit No.	3-1326-0027	5/00004		
Capacity (specify units)	2,061 MMBtu	2,061 MMBtu/hr heat input		
BACT/LAER Determination	Catalytic oxid	Catalytic oxidation system and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2.0 ppmvd with and without DB burning		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	New York State Department of Environmental Conservation; Preconstruction Permit for a Major Stationary Source; Cricket Valley Energy Center, Dover Plains, NY; Air State Facility Permit ID 3-1326-00275/00004; September 27, 2012.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: CO
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT	LAER	
Source	2 - Combined	2 - Combined-cycle combustion turbine units / GE 7FA		
Facility/Location	Green Energ	y Partners/Stonewall LLC / Lee	sburg, VA	
Permitting Authority	Virginia Depa	artment of Environmental Qualit	у	
Permit No.	73826	73826		
Capacity (specify units)	2,230 MMBtu	2,230 MMBtu/hr heat input per unit		
BACT/LAER Determination	Oxidation cat	Oxidation catalyst system and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS and performance testir	ng	
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2.0 ppmv with & without duct I 9.9 lb//hr without HRSG DB fir	ourning; 12.7 lb/hr with HRSG DB firing; ring (for each unit)	
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Green Energy Partners/Stonewall LLC, Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit, Non-Attainment New Source Review Permit, Stationary Source Permit to Construction and Operate, Registration Number 73826, April 30, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combine-Cycle Combustion Turbines #1 and #2
Pollutant: CO
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:				
Source	2 - Combined burner	2 - Combined-cycle combustion turbine units (GE 207FA.05) with HRSG and duct burner		
Facility/Location	Hess Newark	Energy Center / Newark, NJ		
Permitting Authority	New Jersey [New Jersey Department of Environmental Protection		
Permit No.	BOP110001	BOP110001		
Capacity (specify units)	2,320 MMBtu	2,320 MMBtu/hr heat input per unit		
BACT/LAER Determination	Catalytic oxid	Catalytic oxidation system and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS and Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2.0 ppmvd with and without DB; 0.0044 lb/MMBtu		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	State of New Jersey Department of Environmental Protection; Division of Air Quality, Bureau of Air Permits; Air Pollution Control Operating Permit PSD Permit and Initial Operating Permit for a PSD Affected Facility; Permit Activity Number: BOP110001 Program Interest Number: 08857; Hess Newark Energy Center, Newark, NJ; 11/1/2012			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: CO
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	2 - Combined	2 - Combined-cycle combustion turbine units with duct-fire HRSG		
Facility/Location	Kleen Energy	y Systems LLC / Middletown, CT		
Permitting Authority	Connecticut I	Department of Energy & Environmental Protection		
Permit No.	0131 & 0133			
Capacity (specify units)	2,136 MMBtu	2,136 MMBtu/hr heat input per unit		
BACT/LAER Determination	Oxidation cat	Oxidation catalyst system and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS and performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.9 ppmv & 4.3 lb/hr without DB firing; 1.7 ppmv & 8.4 lb/hr with DB firing, 1.8 ppm firing ULSD		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Connecticut Department of Energy & Environmental Protection, Bureau of Air Management, New Source Review Permit to Construct and Operate a Stationary Source, Kleen Energy Systems LLC, Middletown, CT, Town-Permit Numbers 104-0131 & 104-0133, Premises Number 246, July, 2, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: CO
BACT Option: Good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:				
Source	Combined-cy	Combined-cycle combustion turbine with duct burner / Siemens SGT6-5000F		
Facility/Location	Idaho Power	Idaho Power Company - Langley Gulch Power Plant / New Plymouth, ID		
Permitting Authority	Idaho Depart	ment of Environmental Quality		
Permit No.	P-2009.0092	P-2009.0092		
Capacity (specify units)	2,134 MMBtu	2,134 MMBtu/hr heat input		
BACT/LAER Determination	Good combus	Good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS monitoring		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2.0 ppmv		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	IDEQ, Air Quality Permit to Construct, Idaho Power Company - Langley Gulch Power Plant, Permit Nunber P-2009.0092, Project ID 61199, Facility ID 075-00012, Issued August 14, 2013			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: CO
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT	LAER	
Source	2 - Combined	2 - Combined-cycle combustion turbine units with duct burner (Siemens)		
Facility/Location	Oregon Clear	Oregon Clean Energy Center / Oregon, OH		
Permitting Authority	Ohio Environ	Ohio Environmental Protection Agency		
Permit No.	P0110840	P0110840		
Capacity (specify units)	2,932 MMBtu	2,932 MMBtu/hr heat input per unit		
BACT/LAER Determination	Catalytic oxid	Catalytic oxidizer and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS and performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2 ppmv and 13.0 lbs/hr with an	d without DB firing;	
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Ohio Environmental Protection Agency, Final, Division of Air Pollution Control, Permit-to- Install for Oregon Clean Energy Center, Facility ID 0448020102, Permit Number P0110840, June 18, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: CO
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT	LAER	
Source	Combined-cy	Combined-cycle combustion turbine units with HRSG		
Facility/Location		Westfield Land Development Company, LLC - Pioneer Valley Energy Center / Westfield, MA		
Permitting Authority	Massachuset	ts Department of Environme	ental Protection	
Permit No.	Plan #: 1-B-0	8-037; Trans. #: X223780		
Capacity (specify units)	2,542 MMBtu	/hr heat input		
BACT/LAER Determination	Use of clean burning fuels, state-of-the-art combustion technology, oxidation catalyst system and establishing minimum load restrictions.			
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS and performance tes	sting	
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2.0 ppmvd (0.0049 lb/MMB 6.0 ppmvd (0.016 lb/MMBtu	tu) with and without DB burning firing gas; u) firing ULSD	
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference Department of E to Construct, W		Environmental Protection We	ve Office of Energy & Environmental Affairs, estern Regional Office; Conditional Approval Company, LLC - Pioneer Valley Energy 780; December 31, 2010.	

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: CO
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT	LAER	
Source	4 - Combined	4 - Combined-cycle combustion turbine units with duct burner		
Facility/Location	Renaissance	Renaissance Power LLC / Carson City, Michigan		
Permitting Authority	Michigan Der	partment of Environmental Quality		
Permit No.	51-13			
Capacity (specify units)	2,147 MMBtu	/hr heat input per unit		
BACT/LAER Determination	Catalytic oxid	Catalytic oxidation system and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2 ppmv 3-hr rolling average; 11.4 l	bs/hr 24-hr rolling average	
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Michigan Department of Environmental Quality, Air Quality Division, Permit to Install 51-13, Issued to Renaissance Power LLC, State Registration Number N6873, November 1, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: CO
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT	LAER	
Source	4 - Combined	4 - Combined-cycle combustion turbine units with duct-fire HRSG		
Facility/Location	Tampa Electr	ic Company - Polk Power Stat	ion / Mulberry, FL	
Permitting Authority	Florida Depar	rtment of Environmental Protect	ction	
Permit No.	PSD-FL-421			
Capacity (specify units)	1,951 MMBtu	1,951 MMBtu/hr heat input per unit		
BACT/LAER Determination	Dry low-NOx practices	Dry low-NOx combusters with automated control system and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		4.1 ppmv		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Florida Department of Environmental Protection, Final Permit, Tampa Electric Compa Polk Power Station, Polk County, Mulberry, FL, Project No. 1050233-034-AC, Permit PSD-FL-421, May 15, 2013.			

Applicant Name: CPV Towantic, LLC	
Jnit No.: CT1/DB1 and CT2/DB2	
Jnit Description: Combined-Cycle Combustion Turbines #1 and #2	
Pollutant: NOx	
BACT Option: Dry low NOx combustors, Selective Catalytic Reduction, and good combus	stion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT ☐ LAER		
Source	3 - Combined	3 - Combined-cycle combustion turbine units with duct-fired HRSG		
Facility/Location	Virginia Elect	ctric and Power Company / Brunswick Co., Freeman, VA		
Permitting Authority	Virginia Depa	partment of Environmental Quality		
Permit No.	52404			
Capacity (specify units)	3,442 MMBtu	tu/hr heat input per turbine		
BACT/LAER Determination	Dry low-NOx practices	Dry low-NOx combustors, Selective Catalytic Reduction, and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS and performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2 ppmvd with & without DB firing (each unit)		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit, Virginia Electric and Power Company - Brunswick County Power Station, Registration Number 52404, March 12, 2013.			

Applicant Name: CPV Towantic, LLC	
Jnit No.: CT1/DB1 and CT2/DB2	
Jnit Description: Combined-Cycle Combustion Turbines #1 and #2	
Pollutant: NOx	
BACT Option: Dry low-NOx combustors, Selective Catalytic Reduction, and good combus	stion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination: ⊠ BACT □ LAER				
Source	2 - Combined	2 - Combined-cycle combustion turbine units with duct burner / GE 7FA		
Facility/Location	Carroll Count	y Energy LLC / Washington Township, OH		
Permitting Authority	Ohio Environ	mental Protection Agency		
Permit No.	P0113762			
Capacity (specify units)	2,045 MMBtu	/hr heat input per turbine		
BACT/LAER Determination	Dry low-NOx practices	combustors, Selective Catalytic Reduction, and good combustion		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS and performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2 ppmv with & without DB firing; 20.5 lb/hr with DB firing; 16.3 lb/hr without DB firing		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
		ental Protection Agency, Final, Division of Air Pollution Control, Permit-to-I County Energy LLC, Facility ID 0210002025, Permit Number P0113762, 013.		

Applicant Name: CPV Towantic, LLC	
Jnit No.: CT1/DB1 and CT2/DB2	
Jnit Description: Combined-Cycle Combustion Turbines #1 and #2	
Pollutant: NOx	
BACT Option: Dry low-NOx combustors, Selective Catalytic Reduction, and good combus	stion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		☐ BACT ⊠ LAER		
Source	3 - Combined	3 - Combined-cycle combustion turbine units with HRSG		
Facility/Location	Cricket Valley	y Energy Center LLC / Dover Plains, NY		
Permitting Authority	New York Sta	ate Department of Environmental Conservation		
Permit No.	3-1326-0027	5/00004		
Capacity (specify units)	2,061 MMBtu	2,061 MMBtu/hr heat input		
BACT/LAER Determination	Dry low-NOx practices	Dry low-NOx combustors, Selective Catalytic Reduction, and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS and performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2.0 ppmvd gas firing with and without DB		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
		e Department of Environmental Conservation; Preconstruction Permit for eary Source; Cricket Valley Energy Center, Dover Plains, NY; Air State ID 3-1326-00275/00004; September 27, 2012.		

Applicant Name: <u>CPV Towantic, LLC</u>	
Jnit No.: CT1/DB1 and CT2/DB2	
Jnit Description: Combined-Cycle Combustion Turbines #1 and #2	
Pollutant: NOx	
BACT Option: Dry low-NOx combustors, Selective Catalytic Reduction, and good combus	tion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT	□ LAER
Source	2 - Combined	l-cycle combustion turbine unit	s / GE 7FA
Facility/Location	Green Energ	y Partners/Stonewall LLC / Lee	esburg, VA
Permitting Authority	Virginia Depa	rtment of Environmental Quali	ty
Permit No.	73826		
Capacity (specify units)	2,230 MMBtu	2,230 MMBtu/hr heat input per unit	
BACT/LAER Determination	Dry low-NOx combustors, Selective Catalytic Reduction, and good combustion practices		ic Reduction, and good combustion
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		CEMS and performance testi	ng
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		2 parts per million by volume each unit with DB firing; 16.2	(ppmv) with & without DB firing; 21 lb/hr without DB firing
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference Environmental (New Source Re		Quality, Prevention of Significa	nonwealth of Virginia Department of ant Deterioration Permit, Non-Attainment e Permit to Construction and Operate,

Applicant Name: CPV Towantic, LLC	
Jnit No.: CT1/DB1 and CT2/DB2	
Jnit Description: Combined-Cycle Combustion Turbines #1 and #2	
Pollutant: NOx	
BACT Option: Dry low-NOx combustors, Selective Catalytic Reduction, and good combus	stion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination: ☐ BACT ☐ LAER			
Source	2 - Combined burner	2 - Combined-cycle combustion turbine units (GE 207FA.05) with HRSG and duct burner	
Facility/Location	Hess Newark	Energy Center / Newark, NJ	
Permitting Authority	New Jersey [Department of Environmental Protection	
Permit No.	BOP110001		
Capacity (specify units)	2,320 MMBtu	2,320 MMBtu/hr heat input per unit	
BACT/LAER Determination	Dry low-NOx combustors, Selective Catalytic Reduction, and good combustion practices		
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		CEMS and performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		2.0 ppmvd gas firing with and without DB	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference Bureau of Air Po Operating Perm		ersey Department of Environmental Protection; Division of Air Quality, ermits; Air Pollution Control Operating Permit PSD Permit and Initial hit for a PSD Affected Facility; Permit Activity Number: BOP110001 st Number: 08857; Hess Newark Energy Center, Newark, NJ; 11/1/2012	

Applicant Name: <u>CPV Towantic, LLC</u>	
Jnit No.: CT1/DB1 and CT2/DB2	
Jnit Description: Combined-Cycle Combustion Turbines #1 and #2	
Pollutant: NOx	
BACT Option: Dry low-NOx combustors, Selective Catalytic Reduction, and good combus	tion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER	
Source	2 - Combined	d-cycle combustion turbine units with duct-fire HRSG	
Facility/Location	Kleen Energy	y Systems LLC / Middletown, CT	
Permitting Authority	Connecticut [Department of Energy & Environmental Protection	
Permit No.	0131 & 0133		
Capacity (specify units)	2,136 MMBtu	u/hr heat input per unit	
BACT/LAER Determination	Dry low-NOx practices	Dry low-NOx combustors, Selective Catalytic Reduction, and good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		CEMS and performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		2 ppmvd on gas with and without DB firing; 15.5 lb/hr with DB firing; 16.2 lb/hr without DB firing; and 5.9 ppmvd firing ULSD	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference Management, N Source, Kleen B		Pepartment of Energy & Environmental Protection, Bureau of Air New Source Review Permit to Construct and Operate a Stationary Energy Systems LLC, Middletown, CT, Town-Permit Numbers 104-0131 remises Number 246, July, 2, 2013.	

Applicant Name: CPV Towantic, LLC	
Unit No.: CT1/DB1 and CT2/DB2	
Unit Description: Combined-Cycle Combustion Turbines #1 and #2	
Pollutant: NOx	
BACT Option: Dry low-NOx combustors, Selective Catalytic Reduction, and good combus	stion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:			
Source	Combined-cy	cle combustion turbine with duct burner / Siemens SGT6-5000F	
Facility/Location	Idaho Power	Company - Langley Gulch Power Plant / New Plymouth, ID	
Permitting Authority	Idaho Depart	ment of Environmental Quality	
Permit No.	P-2009.0092		
Capacity (specify units)	2,134 MMBtu	2,134 MMBtu/hr heat input	
BACT/LAER Determination	Dry low-NOx practices	Dry low-NOx combustors, Selective Catalytic Reduction, and good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		CEMS monitoring	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		2.0 ppmv	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton rem	oved)	NA	
		ty Permit to Construct, Idaho Power Company - Langley Gulch Power unber P-2009.0092, Project ID 61199, Facility ID 075-00012, Issued	

Applicant Name: <u>CPV Towantic, LLC</u>	
Jnit No.: CT1/DB1 and CT2/DB2	
Jnit Description: Combined-Cycle Combustion Turbines #1 and #2	
Pollutant: NOx	
BACT Option: Dry low-NOx combustors, Selective Catalytic Reduction, and good combus	tion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:			
Source	2 - Combined	d-cycle combustion turbine units with duct burner (Siemens)	
Facility/Location	Oregon Clear	n Energy Center / Oregon, OH	
Permitting Authority	Ohio Environ	mental Protection Agency	
Permit No.	P0110840		
Capacity (specify units)	2,932 MMBtu	ı/hr heat input per unit	
BACT/LAER Determination	Dry low-NOx practices	Dry low-NOx combustors, Selective Catalytic Reduction, and good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		CEMS and performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		2 ppmv; 21 lbs/hr with DB firing; 22 lbs/hr without DB firing	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton rem	oved)	Not Available	
		ental Protection Agency, Final, Division of Air Pollution Control, Permit-to- on Clean Energy Center, Facility ID 0448020102, Permit Number te 18, 2013.	

Applicant Name: CPV Towantic, LLC	
Jnit No.: CT1/DB1 and CT2/DB2	
Jnit Description: Combined-Cycle Combustion Turbines #1 and #2	
Pollutant: NOx	
BACT Option: Dry low-NOx combustors, Selective Catalytic Reduction, and good combus	stion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination: ☐ BACT ☐ LAER			
Source	Combined-cy	Combined-cycle combustion turbine unit with HRSG	
Facility/Location	Westfield Lar Westfield, MA	nd Development Company, LLC - Pioneer Valley Energy Center /	
Permitting Authority	Massachuset	ts Department of Environmental Protection	
Permit No.	Plan #: 1-B-0	8-037; Trans. #: X223780	
Capacity (specify units)	2,542 MMBtu	2,542 MMBtu/hr heat input	
BACT/LAER Determination	Dry low-NOx combustors, Selective Catalytic Reduction, water injection during ULSD/Biodiesel firing and good combustion practices		
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		CEMS and performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		2.0 ppmvd firing natural gas & 5.0 ppmvd firing ULSD	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference Department of I to Construct, W		of Massachusetts, Executive Office of Energy & Environmental Affairs, Environmental Protection Western Regional Office; Conditional Approval Vestfield Land Development Company, LLC - Pioneer Valley Energy 1-B-08-037; Trans. #: X223780; December 31, 2010.	

Applicant Name: CPV Towantic, LLC	
Jnit No.: CT1/DB1 and CT2/DB2	
Jnit Description: Combined-Cycle Combustion Turbines #1 and #2	
Pollutant: NOx	
BACT Ontion: Dry low-NOx combustors. Selective Catalytic Reduction, and good combus	stion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT	LAER	
Source	4 - Combined	4 - Combined-cycle combustion turbine units with duct burner		
Facility/Location	Renaissance	Power LLC / Carson City, Mi	chigan	
Permitting Authority	Michigan Der	partment of Environmental Qu	uality	
Permit No.	51-13			
Capacity (specify units)	2,147 MMBtu	2,147 MMBtu/hr heat input per unit		
BACT/LAER Determination	Dry low-NOx practices	Dry low-NOx combustors, Selective Catalytic Reduction, and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2 ppmv		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Michigan Department of Environmental Quality, Air Quality Division, Permit to Install 51-13, Issued to Renaissance Power LLC, State Registration Number N6873, November 1, 2013.			

Applicant Name: CPV Towantic, LLC	
Unit No.: CT1/DB1 and CT2/DB2	
Unit Description: Combined-Cycle Combustion Turbines #1 and #2	
Pollutant: NOx	
BACT Option: Dry low-NOx combustors, Selective Catalytic Reduction, and good combus	stion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT ☐ LAER	_	
Source	4 - Combined	4 - Combined-cycle combustion turbine units with duct-fire HRSG		
Facility/Location	Tampa Electr	ctric Company - Polk Power Station / Mulberry, FL		
Permitting Authority	Florida Depar	partment of Environmental Protection		
Permit No.	PSD-FL-421	PSD-FL-421		
Capacity (specify units)	1,951 MMBtu	1,951 MMBtu/hr heat input per unit		
BACT/LAER Determination	Dry low-NOx practices	Dry low-NOx combustors, Selective Catalytic Reduction, and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS and performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2 ppmv with and without DB firing		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Florida Department of Environmental Protection, Final Permit, Tampa Electric Company Polk Power Station, Polk County, Mulberry, FL, Project No. 1050233-034-AC, Permit No. PSD-FL-421, May 15, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: VOC
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	3 - Combined	d-cycle combustion turbine units with duct-fired HRSG		
Facility/Location	Virginia Elect	Virginia Electric and Power Company / Brunswick Co., Freeman, VA		
Permitting Authority	Virginia Depa	artment of Environmental Quality		
Permit No.	52404			
Capacity (specify units)	3,442 MMBtu	3,442 MMBtu/hr heat input per turbine		
BACT/LAER Determination	Oxidation cat	Oxidation catalyst system and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.7 ppmvd without DB burning; 1.6 ppmvd with DB firing (each unit)		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference Significant Dete		h of Virginia Department of Environmental Quality, Prevention of erioration Permit, Virginia Electric and Power Company - Brunswick Station, Registration Number 52404, March 12, 2013.		

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: VOC
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT	LAER
Source	2 - Combined	I-cycle combustion turbine units	with duct burner / GE 7FA
Facility/Location	Carroll Count	y Energy LLC / Washington Tov	vnship, OH
Permitting Authority	Ohio Environ	mental Protection Agency	
Permit No.	P0113762	P0113762	
Capacity (specify units)	2,045 MMBtu	2,045 MMBtu/hr heat input per turbine	
BACT/LAER Determination	Catalytic oxid	lizer and good combustion pract	ices
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		0.0026 lb/MMBtu and 7.1 lb/hr lb/hr without DB firing;	with DB Firing; 0.0013 lb/MMBtu and 2.8
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
		I County Energy LLC, Facility ID	Division of Air Pollution Control, Permit-to- 0 0210002025, Permit Number P0113762,

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: VOC
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER	
Source	3 - Combined	3 - Combined-cycle combustion turbine units with HRSG	
Facility/Location	Cricket Valley	y Energy Center LLC / Dover Plains, NY	
Permitting Authority	New York Sta	ate Department of Environmental Conservation	
Permit No.	3-1326-0027	5/00004	
Capacity (specify units)	2,061 MMBtu	ı/hr heat input	
BACT/LAER Determination	Catalytic oxid	Catalytic oxidation system and good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		1.0 ppmvd without DB and 2.0 ppmvd with DB	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference a Major Stationa		Department of Environmental Conservation; Preconstruction Permit for eary Source; Cricket Valley Energy Center, Dover Plains, NY; Air State ID 3-1326-00275/00004; September 27, 2012.	

Applicant Name: CPV Towantic, LLC
Jnit No.: CT1/DB1 and CT2/DB2
Jnit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: VOC
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER	
Source	2 - Combined	d-cycle combustion turbine units / GE 7FA	
Facility/Location	Green Energ	y Partners/Stonewall LLC / Leesburg, VA	
Permitting Authority	Virginia Depa	artment of Environmental Quality	
Permit No.	73826		
Capacity (specify units)	2,230 MMBtu	2,230 MMBtu/hr heat input per unit	
BACT/LAER Determination	Oxidation cat	alyst system and good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Performance yesting	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		2.4 ppmv with DB firing; 1 ppmv without DB firing 7.3 lb/hr with HRSG DB firing; 16.2 without DB firing (for each unit)	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference	Green Energy Partners/Stonewall LLC, Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit, Non-Attain New Source Review Permit, Stationary Source Permit to Construction and Operation Registration Number 73826, April 30, 2013.		

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: VOC
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT ⊠ LAER		
Source	2 - Combined burner	2 - Combined-cycle combustion turbine units (GE 207FA.05) with HRSG and duct burner		
Facility/Location	Hess Newark	Hess Newark Energy Center / Newark, NJ		
Permitting Authority	New Jersey [New Jersey Department of Environmental Protection		
Permit No.	BOP110001			
Capacity (specify units)	2,320 MMBtu	2,320 MMBtu/hr heat input per unit		
BACT/LAER Determination	Catalytic oxid	Catalytic oxidation system and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		1.0 ppmvd without DB and 2.0 ppmvd with DB		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	State of New Jersey Department of Environmental Protection; Division of Air Quality, Bureau of Air Permits; Air Pollution Control Operating Permit PSD Permit and Initial Operating Permit for a PSD Affected Facility; Permit Activity Number: BOP110001 Program Interest Number: 08857; Hess Newark Energy Center, Newark, NJ; 11/1/2012			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: VOC
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER
Source	2 - Combined	d-cycle combustion turbine units with duct-fire HRSG
Facility/Location	Kleen Energy	/ Systems LLC / Middletown, CT
Permitting Authority	Connecticut I	Department of Energy & Environmental Protection
Permit No.	0131 & 0133	
Capacity (specify units)	2,136 MMBtu	ı/hr heat input per unit
BACT/LAER Determination	Oxidation cat	alyst system and good combustion practices
Compliance Achieved? (Yes/No)		No
Method of Compliance Determination		CEMS and performance testing
Actions Taken for Noncompliance		NA
Baseline Emissions Rate (specify units)		Not Available
Allowable Emissions Rate (specify units)		Gas Firing: 5.0 ppmv & 10.0 lb/hr with DB firing; 5.0 ppmv & 10.8 lb/hr without DB firing; ULSD Firing: 3.6 ppmvd
Emissions Reduction Potential (%)		Not Available
Cost Effectiveness (\$/ton removed)		Not Available
Reference Management, No Source, Kleen E		Ppartment of Energy & Environmental Protection, Bureau of Air New Source Review Permit to Construct and Operate a Stationary Energy Systems LLC, Middletown, CT, Town-Permit Numbers 104-0131 emises Number 246, July, 2, 2013.

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: VOC
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	Combined-cy	Combined-cycle combustion turbine with duct burner / Siemens SGT6-5000F		
Facility/Location	Idaho Power	Idaho Power Company - Langley Gulch Power Plant / New Plymouth, ID		
Permitting Authority	Idaho Depart	ment of Environmental Quality		
Permit No.	P-2009.0092			
Capacity (specify units)	2,134 MMBtu	2,134 MMBtu/hr heat input		
BACT/LAER Determination	Catalytic oxid	Catalytic oxidation system and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2.0 ppmv		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
		ity Permit to Construct, Idaho Power Company - Langley Gulch Power unber P-2009.0092, Project ID 61199, Facility ID 075-00012, Issued 3		

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: VOC
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	2 - Combined	2 - Combined-cycle combustion turbine units with duct burner (Siemens)		
Facility/Location	Oregon Clear	Oregon Clean Energy Center / Oregon, OH		
Permitting Authority	Ohio Environ	Ohio Environmental Protection Agency		
Permit No.	P0110840			
Capacity (specify units)	2,932 MMBtu	2,932 MMBtu/hr heat input per unit		
BACT/LAER Determination	Catalytic oxid	Catalytic oxidizer and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		1.9 ppmv and 5.9 lbs/hr with DB Firing; 1.0 ppmv and 3.9 lbs/hr without DB firing		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Ohio Environmental Protection Agency, Final, Division of Air Pollution Control, Permit-tinstall for Oregon Clean Energy Center, Facility ID 0448020102, Permit Number P0110840, June 18, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: VOC
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT ☐ LAER		
Source	Combined-cy	Combined-cycle combustion turbine unit with HRSG		
Facility/Location		Westfield Land Development Company, LLC - Pioneer Valley Energy Center / Westfield, MA		
Permitting Authority	Massachuset	etts Department of Environmental Protection		
Permit No.	Plan #: 1-B-0	08-037; Trans. #: X223780		
Capacity (specify units)	2,542 MMBtu/hr heat input			
BACT/LAER Determination		burning fuels, state-of-the-art combustion technology, oxidation catalyst establishing minimum load restrictions.		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		1.0 ppmvd firing natural gas & 6.0 ppmvd firing ULSD		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Commonwealth of Massachusetts, Executive Office of Energy & Environmental Affairs, Department of Environmental Protection Western Regional Office; Conditional Approval to Construct, Westfield Land Development Company, LLC - Pioneer Valley Energy Center, Plan #: 1-B-08-037; Trans. #: X223780; December 31, 2010.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: VOC
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	4 - Combined	4 - Combined-cycle combustion turbine units with duct burner		
Facility/Location	Renaissance	Renaissance Power LLC / Carson City, Michigan		
Permitting Authority	Michigan Dep	partment of Environmental Quality		
Permit No.	51-13			
Capacity (specify units)	2,147 MMBtu	/hr heat input per unit		
BACT/LAER Determination	Catalytic oxid	Catalytic oxidation system and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance Testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2 ppmv		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
		rtment of Environmental Quality, Air Quality Division, Permit to Install 51- enaissance Power LLC, State Registration Number N6873, November 1,		

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: VOC
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	4 - Combined	-cycle combustion turbine units with duct-fire HRSG		
Facility/Location	Tampa Electr	ic Company - Polk Power Station / Mulberry, FL		
Permitting Authority	Florida Depai	rtment of Environmental Protection		
Permit No.	PSD-FL-421			
Capacity (specify units)	1,951 MMBtu/hr heat input per unit			
BACT/LAER Determination	Good combus	Good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		1.4 ppmv		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
		nent of Environmental Protection, Final Permit, Tampa Electric Company tion, Polk County, Mulberry, FL, Project No. 1050233-034-AC, Permit No. lay 15, 2013.		

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: PM10/PM2.5
BACT Option: Catalytic oxidation system and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER	
Source	3 - Combined	d-cycle combustion turbine units with duct-fired HRSG	
Facility/Location	Virginia Elect	tric and Power Company / Brunswick Co., Freeman, VA	
Permitting Authority	Virginia Depa	artment of Environmental Quality	
Permit No.	52404		
Capacity (specify units)	3,442 MMBtu	3,442 MMBtu/hr heat input per turbine	
BACT/LAER Determination	Oxidation cat	Oxidation catalyst system and good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		0.0033 lb/MMBtu & 9.7 lb/hr without DB firing; 0.0047 lb/MMBtu & 16.3 lb/hr with DB firing (each unit)	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference	Significant Dete	h of Virginia Department of Environmental Quality, Prevention of erioration Permit, Virginia Electric and Power Company - Brunswick Station, Registration Number 52404, March 12, 2013.	

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: PM10/PM2.5
BACT Ontion: Zero ash content & low sulfur content fuels and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT ☐ LAER	
Source	2 - Combined	d-cycle combustion turbine units with duct burner / GE 7FA	
Facility/Location	Carroll Count	ty Energy LLC / Washington Township, OH	
Permitting Authority	Ohio Environ	nmental Protection Agency	
Permit No.	P0113762	P0113762	
Capacity (specify units)	2,045 MMBtu	2,045 MMBtu/hr heat input per turbine	
BACT/LAER Determination	Zero ash con	ntent & low sulfur content fuels and good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		0.0078 lb/MMBtu and 19.8 lb/hr with DB Firing; 0.0108 lb/MMBtu and 12.4 lb/hr without DB firing	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference		nental Protection Agency, Final, Division of Air Pollution Control, Permit-to- Il County Energy LLC, Facility ID 0210002025, Permit Number P0113762, 1013.	

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: PM10/PM2.5
BACT Option: Good combustion practices and pipeline-quality natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	3 - Combined	-cycle combustion turbine units with HRSG		
Facility/Location	Cricket Valley	Cricket Valley Energy Center LLC / Dover Plains, NY		
Permitting Authority	New York Sta	New York State Department of Environmental Conservation		
Permit No.	3-1326-0027	5/00004		
Capacity (specify units)	2,061 MMBtu	/hr heat input		
BACT/LAER Determination	Good combus	Good combustion practices and pipeline-quality natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.005 lb/MMBtu without DB and 0.006 lb/MMBtu with DB		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference a Major Station		Department of Environmental Conservation; Preconstruction Permit for ary Source; Cricket Valley Energy Center, Dover Plains, NY; Air State D 3-1326-00275/00004; September 27, 2012.		

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: PM10/PM2.5
BACT Option: Zero ash content & low sulfur content fuels and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER	
Source	2 - Combined	d-cycle combustion turbine units / GE 7FA	
Facility/Location	Green Energ	y Partners/Stonewall LLC / Leesburg, VA	
Permitting Authority	Virginia Depa	artment of Environmental Quality	
Permit No.	73826		
Capacity (specify units)	2,230 MMBtu	ı/hr heat input per unit	
BACT/LAER Determination	Zero ash con	Zero ash content & low sulfur content fuels and good combustion practices	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Performance Testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		3.34E-03 lb/MMBtu; 16.2 lb/hr with DB firing; 9.6 lb/hr without DB firing (each unit)	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference	Environmental New Source Re	Partners/Stonewall LLC, Commonwealth of Virginia Department of Quality, Prevention of Significant Deterioration Permit, Non-Attainment eview Permit, Stationary Source Permit to Construction and Operate, umber 73826, April 30, 2013.	

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: PM10/PM2.5
BACT Option: Good combustion practices and pipeline-quality natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	2 - Combined burner	2 - Combined-cycle combustion turbine units (GE 207FA.05) with HRSG and duct burner		
Facility/Location	Hess Newark	Hess Newark Energy Center / Newark, NJ		
Permitting Authority	New Jersey [New Jersey Department of Environmental Protection		
Permit No.	BOP110001	BOP110001		
Capacity (specify units)	2,320 MMBtu	2,320 MMBtu/hr heat input per unit		
BACT/LAER Determination	Good combus	Good combustion practices and pipeline-quality natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.0047 lb/MMBtu without DB; 0.0058 lb/MMBtu with DB; and 11 lb/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	State of New Jersey Department of Environmental Protection; Division of Air Quality, Bureau of Air Permits; Air Pollution Control Operating Permit PSD Permit and Initial Operating Permit for a PSD Affected Facility; Permit Activity Number: BOP110001 Program Interest Number: 08857; Hess Newark Energy Center, Newark, NJ; 11/1/20			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: PM10/PM2.5
BACT Ontion: Zero ash content & low sulfur content fuels and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	2 - Combined	2 - Combined-cycle combustion turbine units with duct-fire HRSG		
Facility/Location	Kleen Energy	Kleen Energy Systems LLC / Middletown, CT		
Permitting Authority	Connecticut [Connecticut Department of Energy & Environmental Protection		
Permit No.	0131 & 0133	0131 & 0133		
Capacity (specify units)	2,136 MMBtu/hr heat input per unit			
BACT/LAER Determination	Zero ash content & low sulfur content fuels and good combustion practices			
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		11.0 lb/hr with DB firing; 15.2 lb/hr without DB firing		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Connecticut Department of Energy & Environmental Protection, Bureau of Air Management, New Source Review Permit to Construct and Operate a Stationary Source, Kleen Energy Systems LLC, Middletown, CT, Town-Permit Numbers 104-0131 & 104-0133, Premises Number 246, July, 2, 2013.			

Applicant Name: CPV Towantic, LLC
Jnit No.: CT1/DB1 and CT2/DB2
Jnit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: PM10/PM2.5
BACT Option:

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	☐ BACT ☐ LAER	
Source	Combined-cy	Combined-cycle combustion turbine with duct burner / Siemens SGT6-5000F	
Facility/Location	Idaho Power	Idaho Power Company - Langley Gulch Power Plant / New Plymouth, ID	
Permitting Authority	Idaho Depart	Idaho Department of Environmental Quality	
Permit No.	P-2009.0092	P-2009.0092	
Capacity (specify units)	2,134 MMBtu/hr heat input		
BACT/LAER Determination			
Compliance Achieved? (Yes/N	lo)	No	
Method of Compliance Determination		Performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		12.55 lbs/hr or 0.0053 lbs/MMBtu	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Reference	IDEQ, Air Quality Permit to Construct, Idaho Power Company - Langley Gulch Power Plant, Permit Nunber P-2009.0092, Project ID 61199, Facility ID 075-00012, Issued August 14, 2013		

Applicant Name: <u>CPV Towantic, LLC</u>
Unit No.: CT1/DB1 and CT2/DB2
Jnit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: PM10/PM2.5
BACT Option: Zero ash content & low sulfur content fuels and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	2 - Combined	2 - Combined-cycle combustion turbine units with duct burner (Siemens)		
Facility/Location	Oregon Clear	an Energy Center / Oregon, OH		
Permitting Authority	Ohio Environ	Ohio Environmental Protection Agency		
Permit No.	P0110840	P0110840		
Capacity (specify units)	2,932 MMBtu	2,932 MMBtu/hr heat input per unit		
BACT/LAER Determination	Zero ash content & low sulfur content fuels and good combustion practices			
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.0055 lb/MMBtu and 14 lbs/hr with DB Firing; 0.0047 lb/MMBtu and 13.3 lbs/hr without DB firing		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference		nental Protection Agency, Final, Division of Air Pollution Control, Permit-to- gon Clean Energy Center, Facility ID 0448020102, Permit Number ne 18, 2013.		

Applicant Name: CPV Towantic, LLC
Jnit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: PM10/PM2.5
BACT Option: Good combustion practices and pipeline-quality natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT	LAER
Source	Combined-cy	Combined-cycle combustion turbine unit with HRSG	
Facility/Location	·	Westfield Land Development Company, LLC - Pioneer Valley Energy Center /	
Permitting Authority	· ·	Massachusetts Department of Environmental Protection	
Permit No.	Plan #: 1-B-0	Plan #: 1-B-08-037; Trans. #: X223780	
Capacity (specify units)	2,542 MMBtu/hr heat input		
BACT/LAER Determination	Zero ash content & low sulfur content fuels and good combustion practices		
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		Performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		0.0040 lb/MMBtu with and without lb/MMBtu firing ULSD	ut DB burning firing gas; 0.014
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Poforonco	Commonwealth of Massachusetts, Executive Office of Energy & Environmental Affairs, Department of Environmental Protection Western Regional Office; Conditional Approval to Construct, Westfield Land Development Company, LLC - Pioneer Valley Energy Center, Plan #: 1-B-08-037; Trans. #: X223780; December 31, 2010.		

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: PM10/PM2.5
BACT Ontion: Zero ash content & low sulfur content fuels and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT	LAER	
Source	4 - Combined	4 - Combined-cycle combustion turbine units with duct burner		
Facility/Location	Renaissance	Renaissance Power LLC / Carson City, Michigan		
Permitting Authority	Michigan Der	Michigan Department of Environmental Quality		
Permit No.	51-13	51-13		
Capacity (specify units)	2,147 MMBtu	2,147 MMBtu/hr heat input per unit		
BACT/LAER Determination	Zero ash con	Zero ash content & low sulfur content fuels and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance Testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.0042 lb/MMBtu; 9 lbs/hr (each	n unit)	
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Michigan Department of Environmental Quality, Air Quality Division, Permit to Install 51-13, Issued to Renaissance Power LLC, State Registration Number N6873, November 1, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: PM10/PM2.5
BACT Ontion: Zero ash content & low sulfur content fuels and good combustion practices

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT	LAER	
Source	4 - Combined	4 - Combined-cycle combustion turbine units with duct-fire HRSG		
Facility/Location	Tampa Electr	Tampa Electric Company - Polk Power Station / Mulberry, FL		
Permitting Authority	Florida Depa	Florida Department of Environmental Protection		
Permit No.	PSD-FL-421	PSD-FL-421		
Capacity (specify units)	1,951 MMBtu	1,951 MMBtu/hr heat input per unit		
BACT/LAER Determination	Zero ash con	Zero ash content & low sulfur content fuels and good combustion practices		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Record keeping		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2 gr S/100 scf of gas		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Florida Department of Environmental Protection, Final Permit, Tampa Electric Company Polk Power Station, Polk County, Mulberry, FL, Project No. 1050233-034-AC, Permit No. PSD-FL-421, May 15, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: SO2
BACT Option: Use of low sulfur fuels - pipeline natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	3 - Combined	3 - Combined-cycle combustion turbine units with duct-fired HRSG		
Facility/Location	Virginia Elect	ric and Power Company / Brunswick Co., Freeman, VA		
Permitting Authority	Virginia Depa	Virginia Department of Environmental Quality		
Permit No.	52404			
Capacity (specify units)	3,442 MMBtu	3,442 MMBtu/hr heat input per turbine		
BACT/LAER Determination	Use of low su	Use of low sulfur fuels - pipeline natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.00112 lb/MMBtu (each unit)		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit, Virginia Electric and Power Company - Brunswick County Power Station, Registration Number 52404, March 12, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: SO2
BACT Option: Use of low sulfur fuels - pipeline natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT	□LAER	
Source	2 - Combined	2 - Combined-cycle combustion turbine units with duct burner / GE 7FA		
Facility/Location	Carroll Count	y Energy LLC / Washington Tow	nship, OH	
Permitting Authority	Ohio Environ	mental Protection Agency		
Permit No.	P0113762	P0113762		
Capacity (specify units)	2,045 MMBtu	2,045 MMBtu/hr heat input per turbine		
BACT/LAER Determination	Use of low su	Use of low sulfur fuels - pipeline natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.0029 lb/MMBtu		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Ohio Environmental Protection Agency, Final, Division of Air Pollution Control, Permit-to-Install for Caroll County Energy LLC, Facility ID 0210002025, Permit Number P0113762, November 5, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: SO2
BACT Option: Use of low sulfur fuels - pipeline natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	2 - Combined	2 - Combined-cycle combustion turbine units / GE 7FA		
Facility/Location	Green Energ	y Partners/Stonewall LLC / Leesburg, VA		
Permitting Authority	Virginia Depa	artment of Environmental Quality		
Permit No.	73826			
Capacity (specify units)	2,230 million	2,230 million Btu per hour heat input		
BACT/LAER Determination	Use of low su	ulfur fuels		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determ	nination	Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2.61E-04 lb/MMBtu; 0.75 lb/hr with DB firing; 0.58 lb/hr without DB firing (each unit)		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Green Energy Partners/Stonewall LLC, Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit, Non-Attainment New Source Review Permit, Stationary Source Permit to Construction and Operate, Registration Number 73826, April 30, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: SO2
BACT Option: Use of low sulfur fuels - pipeline natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	2 - Combined	2 - Combined-cycle combustion turbine units with duct-fire HRSG		
Facility/Location	Kleen Energy	y Systems LLC / Middletown, CT		
Permitting Authority	Connecticut I	Department of Energy & Environmental Protection		
Permit No.	0131 & 0133			
Capacity (specify units)	2,136 MMBtu	2,136 MMBtu/hr heat input per unit		
BACT/LAER Determination	Use of low su	Use of low sulfur fuels - pipeline natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		4.9 lb/hr with DB firing; 5.1 lb/hr without DB firing		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Connecticut Department of Energy & Environmental Protection, Bureau of Air Management, New Source Review Permit to Construct and Operate a Stationary Source, Kleen Energy Systems LLC, Middletown, CT, Town-Permit Numbers 104-0131 & 104-0133, Premises Number 246, July, 2, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: SO2
BACT Option: Fuel Selection - natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT	LAER	
Source	Combined-cy	Combined-cycle combustion turbine with duct burner / Siemens SGT6-5000F		
Facility/Location	Idaho Power	Idaho Power Company - Langley Gulch Power Plant / New Plymouth, ID		
Permitting Authority	Idaho Depart	ment of Environmental Quality		
Permit No.	P-2009.0092	P-2009.0092		
Capacity (specify units)	2,134 MMBtu	2,134 MMBtu/hr heat input		
BACT/LAER Determination	Fuel selection	Fuel selection - pipeline natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Fuel sampling of sulfur content		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.060 lb SO2/MMBtu		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	IDEQ, Air Quality Permit to Construct, Idaho Power Company - Langley Gulch Power Plant, Permit Nunber P-2009.0092, Project ID 61199, Facility ID 075-00012, Issued August 14, 2013			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: SO2
BACT Option: Use of low sulfur fuels - pipeline natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	2 - Combined	2 - Combined-cycle combustion turbine units with duct burner (Siemens)		
Facility/Location	Oregon Clear	Oregon Clean Energy Center / Oregon, OH		
Permitting Authority	Ohio Environ	mental Protection Agency		
Permit No.	P0110840	P0110840		
Capacity (specify units)	2,932 MMBtu	2,932 MMBtu/hr heat input per unit		
BACT/LAER Determination	Use of low su	Use of low sulfur fuels - pipeline natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering Calculations		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.0014 lb/MMBtu of heat input; 36.8 tons/year for both units		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Ohio Environmental Protection Agency, Final, Division of Air Pollution Control, Permit-to- Install for Oregon Clean Energy Center, Facility ID 0448020102, Permit Number P0110840, June 18, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: SO2
BACT Option: Use of low sulfur fuels - pipeline natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	4 - Combined	4 - Combined-cycle combustion turbine units with duct-fire HRSG		
Facility/Location	Tampa Electr	ic Company - Polk Power Station / Mulberry, FL		
Permitting Authority	Florida Depai	rtment of Environmental Protection		
Permit No.	PSD-FL-421	PSD-FL-421		
Capacity (specify units)	1,951 MMBtu	1,951 MMBtu/hr heat input per unit		
BACT/LAER Determination	Use of low su	Use of low sulfur fuels - pipeline natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Record keeping		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2 gr S/100 scf of gas		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Florida Department of Environmental Protection, Final Permit, Tampa Electric Company Polk Power Station, Polk County, Mulberry, FL, Project No. 1050233-034-AC, Permit No. PSD-FL-421, May 15, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: GHG
BACT Option: Good combustion practices and use of low carbon fuels (natural gas)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	3 - Combined	d-cycle combustion turbine units with duct-fired HRSG		
Facility/Location	Virginia Elect	tric and Power Company / Brunswick Co., Freeman, VA		
Permitting Authority	Virginia Depa	artment of Environmental Quality		
Permit No.	52404			
Capacity (specify units)	3,442 MMBtu	ı/hr heat input per turbine		
BACT/LAER Determination		High efficiency design and operation of the CTGs and HRSG and use of low carbon fuels (natural gas)		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS and Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		920 lbs/MWh & not to exceed 7,500 Btu/kWh net (HHV) output (each unit)		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Significant Dete	or of Virginia Department of Environmental Quality, Prevention of erioration Permit, Virginia Electric and Power Company - Brunswick Station, Registration Number 52404, March 12, 2013.		

Applicant Name: CPV Towantic, LLC
Jnit No.: CT1/DB1 and CT2/DB2
Jnit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: GHG / CO2e
BACT Option: Good combustion practices and use of low carbon fuels (natural gas)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	2 - Combined	2 - Combined-cycle combustion turbine units with duct burner / GE 7FA		
Facility/Location	Carroll Count	y Energy LLC / Washington Township, OH		
Permitting Authority	Ohio Environ	mental Protection Agency		
Permit No.	P0113762			
Capacity (specify units)	2,045 MMBtu	2,045 MMBtu/hr heat input per turbine		
BACT/LAER Determination	Good combu	stion practices and use of low carbon fuels (natural gas)		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering calculations based on monitors		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		859 lb/MW-hr without DB firing & 307,279 lb/hr gross energy output with DB firing; Plant design not to exceed 7,350 Btu/kW-hr HHV (ISO conditions without DB firing)		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference		ental Protection Agency, Final, Division of Air Pollution Control, Permit-to-I County Energy LLC, Facility ID 0210002025, Permit Number P0113762, 013.		

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: GHG
BACT Option: Good combustion practices and use of low carbon fuels (natural gas)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	3 - Combined	3 - Combined-cycle combustion turbine units with HRSG		
Facility/Location	Cricket Valley	Cricket Valley Energy Center LLC / Dover Plains, NY		
Permitting Authority	New York Sta	ate Department of Environmental Conservation		
Permit No.	3-1326-0027	5/00004		
Capacity (specify units)	2,061 MMBtu	/hr heat input		
BACT/LAER Determination	Good combus	Good combustion practices and use of low carbon fuels (natural gas)		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS & performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		910 lb/MW-hr and 7,650 Btu/kW-hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	a Major Station	Department of Environmental Conservation; Preconstruction Permit for ary Source; Cricket Valley Energy Center, Dover Plains, NY; Air State D 3-1326-00275/00004; September 27, 2012.		

Applicant Name: CPV Towantic, LLC
Jnit No.: CT1/DB1 and CT2/DB2
Jnit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: GHG
BACT Option: Good combustion practices and use of low carbon fuels (natural gas)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT	LAER	
Source	2 - Combined	2 - Combined-cycle combustion turbine units / GE 7FA		
Facility/Location	Green Energ	y Partners/Stonewall LLC / Lee	esburg, VA	
Permitting Authority	Virginia Depa	Virginia Department of Environmental Quality		
Permit No.	73826	73826		
Capacity (specify units)	2,230 million Btu per hour heat input			
BACT/LAER Determination	Good combu	Good combustion practices and use of low carbon fuels (natural gas)		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS and calculation based	on power generated to grid	
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		903 lb/MWh (gross); operate DB burning & 7,780 Btu HHV/	not to exceed 7,340 Btu HHV/kWh without /kWh gross output (each unit)	
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference Environmental (New Source Re		Quality, Prevention of Significa	nonwealth of Virginia Department of Int Deterioration Permit, Non-Attainment e Permit to Construction and Operate,	

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: GHG
BACT Option: Good combustion practices and use of low carbon fuels (natural gas)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:			
Source	2 - Combined burner	2 - Combined-cycle combustion turbine units (GE 207FA.05) with HRSG and duct burner		
Facility/Location	Hess Newark	Hess Newark Energy Center / Newark, NJ		
Permitting Authority	New Jersey [Department of Environmental Protection		
Permit No.	BOP110001	BOP110001		
Capacity (specify units)	2,320 MMBtu/hr heat input per unit			
BACT/LAER Determination	High efficiency design and operation of the CTGs and HRSG and use of low carbon fuels (natural gas)			
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS and performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		887 lbs/MWh & not to exceed 7,522 Btu/kWh net (HHV) output (each unit)		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	State of New Jersey Department of Environmental Protection; Division of Air Question and It of Air Permits; Air Pollution Control Operating Permit PSD Permit and It of Operating Permit for a PSD Affected Facility; Permit Activity Number: BOP1100 Program Interest Number: 08857; Hess Newark Energy Center, Newark, NJ; 17			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: GHG / CO2e
BACT Option: Good combustion practices and use of low carbon fuels (natural gas)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT ☐ LAER		
Source	2 - Combined	2 - Combined-cycle combustion turbine units with duct burner (Siemens)		
Facility/Location	Oregon Clear	n Energy Center / Oregon, OH		
Permitting Authority	Ohio Environ	mental Protection Agency		
Permit No.	P0110840	P0110840		
Capacity (specify units)	2,932 MMBtu	2,932 MMBtu/hr heat input per unit		
BACT/LAER Determination	Good combus	Good combustion practices and use of low carbon fuels (natural gas)		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Engineering calculations based on monitors		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		833 lbs/MW-hr gross energy output & 327,819 lbs/hr; operate not to exceed 7,227 Btu/kW-hr HHV (ISO without DB firing)		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
		nental Protection Agency, Final, Division of Air Pollution Control, Permit-to- on Clean Energy Center, Facility ID 0448020102, Permit Number ne 18, 2013.		

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: GHG
BACT Option: Good combustion practices and use of low carbon fuels (natural gas)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT	LAER	
Source	Combined-cy	Combined-cycle combustion turbine units with HRSG		
Facility/Location		Westfield Land Development Company, LLC - Pioneer Valley Energy Center / Westfield, MA		
Permitting Authority	United States	United States Environmental Protection Agency		
Permit No.	Permit Numb	Permit Number 052-042-MA15		
Capacity (specify units)	2,542 MMBtu	2,542 MMBtu/hr heat input		
BACT/LAER Determination	Use of clean	Use of clean burning fuels and highly efficient combustion technology,		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		895 lbs/MWh (effective 365	days after initial operation)	
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	United States Environmental Protection Agency, PSD Permit Number 052-042-MA1		ency, PSD Permit Number 052-042-MA15	

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: GHG
BACT Option: Good combustion practices and use of low carbon fuels (natural gas)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	4 - Combined	4 - Combined-cycle combustion turbine units with duct burner		
Facility/Location	Renaissance	Renaissance Power LLC / Carson City, Michigan		
Permitting Authority	Michigan Der	Michigan Department of Environmental Quality		
Permit No.	51-13	51-13		
Capacity (specify units)	2,147 MMBtu	2,147 MMBtu/hr heat input per unit		
BACT/LAER Determination	Good combus	Good combustion practices and use of low carbon fuels (natural gas)		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		1,000 lbs/MW-hr gross output (each unit)		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
		rtment of Environmental Quality, Air Quality Division, Permit to Install 51- enaissance Power LLC, State Registration Number N6873, November 1,		

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: GHG
BACT Option: Good combustion practices and use of low carbon fuels (natural gas)

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER	
Source	4 - Combined	d-cycle combustion turbine units with duct-fire HRSG	
Facility/Location	Tampa Electi	ric Company - Polk Power Station / Mulberry, FL	
Permitting Authority	US Environm	nental Protection Agency	
Permit No.	PSD-EPA-R4	4014	
Capacity (specify units)	1,951 MMBtu	u/hr heat input per unit	
BACT/LAER Determination	Good combu	Good combustion practices and use of low carbon fuels (natural gas)	
Compliance Achieved? (Yes/No)		No	
Method of Compliance Determination		CEMS and performance testing	
Actions Taken for Noncompliance		NA	
Baseline Emissions Rate (specify units)		Not Available	
Allowable Emissions Rate (specify units)		877 lbs/MWh combined cycle with & without DB firing; 1,320 lbs/MWh simple cycle	
Emissions Reduction Potential (%)		Not Available	
Cost Effectiveness (\$/ton removed)		Not Available	
Prevention of S		Department of Environmental Protection, Region 4, Atlanta, Georgia; Significant Deterioration Permit For Greehouse Gas Emissions; Permit 14; Tampa Electric Company Polk Power Station, Polk County, Mulberry, 18, 2013	

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: H2SO4
BACT Option: Use of low sulfur fuels - pipeline natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:				
Source	3 - Combined	3 - Combined-cycle combustion turbine units with duct-fired HRSG		
Facility/Location	Virginia Elect	Virginia Electric and Power Company / Brunswick Co., Freeman, VA		
Permitting Authority	Virginia Depa	Virginia Department of Environmental Quality		
Permit No.	52404	52404		
Capacity (specify units)	3,442 MMBtu	3,442 MMBtu/hr heat input per turbine		
BACT/LAER Determination	Use of low su	Use of low sulfur fuels - pipeline natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.00058 lb/MMBtu without DB firing: 0.00067 lbMMBtu with DB firing (each unit)		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit, Virginia Electric and Power Company - Brunswic County Power Station, Registration Number 52404, March 12, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: H2SO4
BACT Option: Use of low sulfur fuels - pipeline natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	2 - Combined	2 - Combined-cycle combustion turbine units with duct burner / GE 7FA		
Facility/Location	Carroll Count	Carroll County Energy LLC / Washington Township, OH		
Permitting Authority	Ohio Environ	Ohio Environmental Protection Agency		
Permit No.	P0113762	P0113762		
Capacity (specify units)	2,045 MMBtu	2,045 MMBtu/hr heat input per turbine		
BACT/LAER Determination	Use of low su	Use of low sulfur fuels - pipeline natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.0012 lb/MMBtu and 2.52 lb/hr with DB Firing; 0.0016 lb/MMBtu and 4.26 lb/hr without DB firing		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Ohio Environmental Protection Agency, Final, Division of Air Pollution Control, Pel Install for Caroll County Energy LLC, Facility ID 0210002025, Permit Number P01 November 5, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: H2SO4
BACT Option: Use of low sulfur fuels - pipeline natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAEP Date	ermination:	⊠ BACT	LAER	
Indicate if BACT or LAER Determination:		M DACI	LAER	
Source	2 - Combined	d-cycle combustion turbine units v	with duct burner (Siemens)	
Facility/Location	Oregon Clear	n Energy Center / Oregon, OH		
Permitting Authority	Ohio Environ	mental Protection Agency		
Permit No.	P0110840			
Capacity (specify units)	2,932 MMBtu	2,932 MMBtu/hr heat input per unit		
BACT/LAER Determination	Use of low su	Use of low sulfur fuels - pipeline natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.0007 lb/MMBtu and 1.5 lbs/hr lbs/hr without DB firing	with DB Firing; 0.0006 lb/MMBtu and 1.6	
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference		on Clean Energy Center, Facility	livision of Air Pollution Control, Permit-to- ID 0448020102, Permit Number	

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: H2SO4
BACT Option: Use of low sulfur fuels - pipeline natural gas

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	4 - Combined	4 - Combined-cycle combustion turbine units with duct-fire HRSG		
Facility/Location	Tampa Electr	ric Company - Polk Power Station / Mulberry, FL		
Permitting Authority	Florida Depai	rtment of Environmental Protection		
Permit No.	PSD-FL-421			
Capacity (specify units)	1,951 MMBtu	1,951 MMBtu/hr heat input per unit		
BACT/LAER Determination	Use of low su	Use of low sulfur fuels - pipeline natural gas		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Record keeping		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2 gr S/100 scf of gas		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed) Not Available		Not Available		
Reference	Florida Department of Environmental Protection, Final Permit, Tampa Electric Company Polk Power Station, Polk County, Mulberry, FL, Project No. 1050233-034-AC, Permit No. PSD-FL-421, May 15, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: NH3
BACT Option: Monitor to continuously measure and record ammonia feed rate

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	3 - Combined	3 - Combined-cycle combustion turbine units with HRSG		
Facility/Location	Cricket Valley	/ Energy Center LLC / Dover Plains, NY		
Permitting Authority	New York Sta	ate Department of Environmental Conservation		
Permit No.	3-1326-0027	5/00004		
Capacity (specify units)	2,061 MMBtu	2,061 MMBtu/hr heat input		
BACT/LAER Determination	СЕМ	СЕМ		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEM and Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		5.0 ppmvd @ 15% O2		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed) Not Availa		Not Available		
Reference	New York State Department of Environmental Conservation; Preconstruction Permit for a Major Stationary Source; Cricket Valley Energy Center, Dover Plains, NY; Air State Facility Permit ID 3-1326-00275/00004; September 27, 2012.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: NH3
BACT Option: Monitor to continuously measure and record ammonia feed rate

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	2 - Combined	d-cycle combustion turbine units / GE 7FA		
Facility/Location	Green Energ	gy Partners/Stonewall LLC / Leesburg, VA		
Permitting Authority	Virginia Depa	artment of Environmental Quality		
Permit No.	73826			
Capacity (specify units)	2,230 million	2,230 million Btu per hour heat input		
BACT/LAER Determination	Monitor to co	Monitor to continuously measure and record ammonia feed rate		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Observation and documentation daily of the NH3 feed rate monitor		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		5.0 ppmv		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Green Energy Partners/Stonewall LLC, Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit, Non-Attainment New Source Review Permit, Stationary Source Permit to Construction and Operate, Registration Number 73826, April 30, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: NH3
BACT Option: Flow meter for ammonia injection system

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:				
Source	2 - Combined burner	2 - Combined-cycle combustion turbine units (GE 207FA.05) with HRSG and duct burner		
Facility/Location	Hess Newark	Energy Center / Newark, NJ		
Permitting Authority	New Jersey [Department of Environmental Protection		
Permit No.	BOP110001	BOP110001		
Capacity (specify units)	2,320 MMBtu	2,320 MMBtu/hr heat input per unit		
BACT/LAER Determination	Flow meter fo	Flow meter for ammonia injection system		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Continuous Process Monitoring System & initial performance test		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		5 ppmvd @ 15% O2; 16 lbs/hr		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed) Not		Not Available		
Reference	State of New Jersey Department of Environmental Protection; Division of Air Quality, Bureau of Air Permits; Air Pollution Control Operating Permit PSD Permit and Initial Operating Permit for a PSD Affected Facility; Permit Activity Number: BOP110001 Program Interest Number: 08857; Hess Newark Energy Center, Newark, NJ; 11/1/2012			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: NH3
BACT Option: Monitor to continuously measure and record ammonia feed rate

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT	☐ LAER	
Source	2 - Combined	2 - Combined-cycle combustion turbine units with duct-fire HRSG		
Facility/Location	Kleen Energy	Systems LLC / Middletown, CT		
Permitting Authority	Connecticut [Department of Energy & Environm	ental Protection	
Permit No.	0131 & 0133	0131 & 0133		
Capacity (specify units)	2,136 MMBtu	2,136 MMBtu/hr heat input per unit		
BACT/LAER Determination	CEMS	CEMS		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS & performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2.0 ppmv firing gas with & withou	ut DB firing; 5.0 ppmv firing ULSD	
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Connecticut Department of Energy & Environmental Protection, Bureau of Air Management, New Source Review Permit to Construct and Operate a Stationary Source, Kleen Energy Systems LLC, Middletown, CT, Town-Permit Numbers 104-0131 & 104-0133, Premises Number 246, July, 2, 2013.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: NH3
BACT Option: Flow meter for ammonia injection system

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Combined-cy	Combined-cycle combustion turbine with duct burner / Siemens SGT6-5000F		
Facility/Location	Idaho Power	Idaho Power Company - Langley Gulch Power Plant / New Plymouth, ID		
Permitting Authority	Idaho Departi	Idaho Department of Environmental Quality		
Permit No.	P-2009.0092	P-2009.0092		
Capacity (specify units)	2,134 MMBtu	2,134 MMBtu/hr heat input		
BACT/LAER Determination	Flow meter fo	Flow meter for ammonia injection system		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		5.0 ppmv		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	IDEQ, Air Quality Permit to Construct, Idaho Power Company - Langley Gulch Power Plant, Permit Nunber P-2009.0092, Project ID 61199, Facility ID 075-00012, Issued August 14, 2013			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: NH3
BACT Option: Monitor to continuously measure and record ammonia feed rate

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	Combined-cy	Combined-cycle combustion turbine unit with HRSG		
Facility/Location	Westfield Lan Westfield, MA	Westfield Land Development Company, LLC - Pioneer Valley Energy Center / Westfield, MA		
Permitting Authority	Massachuset	tts Department of Environmental Protection		
Permit No.	Plan #: 1-B-0	08-037; Trans. #: X223780		
Capacity (specify units)	2,542 MMBtu	2,542 MMBtu/hr heat input		
BACT/LAER Determination	Monitor to co	Monitor to continuously measure and record amonia feed rate		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determ	ination	Performance testing		
Actions Taken for Noncomplia	ince	NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		2.0 ppmvd (0.003 lb/MMBtu) with and without DB burning firing gas; 2.0 ppmvd (0.0032 lb/MMBtu) firing ULSD		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Commonwealth of Massachusetts, Executive Office of Energy & Environmental Affairs, Department of Environmental Protection Western Regional Office; Conditional Approval to Construct, Westfield Land Development Company, LLC - Pioneer Valley Energy Center, Plan #: 1-B-08-037; Trans. #: X223780; December 31, 2010.			

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 and CT2/DB2
Unit Description: Combined-Cycle Combustion Turbines #1 and #2
Pollutant: NH3
BACT Option: Monitor to continuously measure and record ammonia feed rate

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	4 - Combined	4 - Combined-cycle combustion turbine units with duct-fire HRSG		
Facility/Location	Tampa Electr	ric Company - Polk Power Station / Mulberry, FL		
Permitting Authority	Florida Depai	rtment of Environmental Protection		
Permit No.	PSD-FL-421	PSD-FL-421		
Capacity (specify units)	1,951 MMBtu	1,951 MMBtu/hr heat input per unit		
BACT/LAER Determination	Monitor to co	Monitor to continuously measure and record ammonia feed rate		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		5.0 ppmv		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Florida Department of Environmental Protection, Final Permit, Tampa Electric Company Polk Power Station, Polk County, Mulberry, FL, Project No. 1050233-034-AC, Permit No. PSD-FL-421, May 15, 2013.			

Applicant Name: CPV Towantic, LLC	
Jnit No.: FUG	
Jnit Description: Fugitive Natural Gas Emissions	
Pollutant: GHG	
BACT Option: Enclosed pressure system with pressure gauges and a low pressure detec	tion system

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT	LAER	
Source	Electrical Circ	Electrical Circuit Breakers with SF6		
Facility/Location	Virginia Elect	Virginia Electric and Power Company / Brunswick Co., Freeman, VA		
Permitting Authority	Virginia Depa	Virginia Department of Environmental Quality		
Permit No.	52404	52404		
Capacity (specify units)	Circuit breake	Circuit breakers - CB-1 through CB-11		
BACT/LAER Determination	Enclosed circ	Enclosed circuit breakers and a low pressure detection system with alarm		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Leak detection system with	n alarm	
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		1% by weight annual leaka	age rate	
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit, Virginia Electric and Power Company - Brunswick County Power Station, Registration Number 52404, March 12, 2013.		ectric and Power Company - Brunswick	

Applicant Name: CPV Towantic, LLC	
Jnit No.: FUG	
Jnit Description: Fugitive Natural Gas Emissions	
Pollutant: GHG	
BACT Option: Enclosed pressure system with pressure gauges and a low pressure detec	tion system

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	Electrical Circ	Electrical Circuit Breakers with SF6		
Facility/Location	Green Energ	y Partners/Stonewall LLC / Leesburg, VA		
Permitting Authority	Virginia Depa	rtment of Environmental Quality		
Permit No.	73826	73826		
Capacity (specify units)	Circuit break	Circuit breakers - CB1		
BACT/LAER Determination	Enclosed circ	Enclosed circuit breakers and a low pressure detection system with alarm		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Leak detection system with alarm		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		1% by weight annual leakage rate		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	Green Energy Partners/Stonewall LLC, Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit, Non-Attainment New Source Review Permit, Stationary Source Permit to Construction and Operate, Registration Number 73826, April 30, 2013.			

Applicant Name: CPV Towantic, LLC	
Unit No.: FUG	
Unit Description: Fugitive Natural Gas Emissions	
Pollutant: GHG	
BACT Option: Enclosed pressure system with pressure gauges and a low pressure detection	tion system with alarm

Complete this form in accordance with the instructions (DEEP-NSR-INST-214) to ensure the proper handling of your

application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

Indicate if BACT or LAER Determination:		⊠ BACT □ LAER		
Source	Electrical Circ	Electrical Circuit Breakers with SF6		
Facility/Location	Tampa Electr	ric Company - Polk Power Station / Mulberry, FL		
Permitting Authority	US Environm	ental Protection Agency		
Permit No.	PSD-EPA-R4	014		
Capacity (specify units)	Circuit breake	Circuit breakers - 18 units		
BACT/LAER Determination		Enclosed pressure system with pressure gauges with internal set points, and a low pressure detection system with alarm		
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		Leak detection system with alarm		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		0.5% by weight annual leakage rate		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed)		Not Available		
Reference	United States Department of Environmental Protection, Region 4, Atlanta, Georgia; Prevention of Significant Deterioration Permit for Greehouse Gas Emissions; Permit PSD-EPA-R4014; Tampa Electric Company Polk Power Station, Polk County, Mulberry, FL, December 18, 2013			

Attachment G1: Background Search – Existing BACT Determinations

Applicant Name: CPV Towantic, LLC
Unit No.: FUG
Unit Description: Fugitive Natural Gas Component Leaks
Pollutant: GHG
BACT Option: Monthly inspection of piping components and leak repair

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each existing BACT or LAER determination found for a unit which is the same or similar to the subject unit. LAER determinations may be considered BACT in some instances.

To ensure a sufficiently broad and comprehensive search of control alternatives, sources other than the RBLC data should be investigated and documented. These sources include: DEEP BACT Database, EPA/State air quality permits, control equipment vendors, trade associations, international agencies or companies, technical papers or journals.

Indicate if BACT or LAER Dete	ermination:	⊠ BACT □ LAER		
Source	Natural Gas (Component Leaks		
Facility/Location	Tampa Electr	ic Company - Polk Power Station / Mulberry, FL		
Permitting Authority	US Environm	ental Protection Agency		
Permit No.	PSD-EPA-R4	014		
Capacity (specify units)	Piping compo	nents delivering natural gas		
BACT/LAER Determination	Piping components inspected monthly basis - leaks repaired immediately			
Compliance Achieved? (Yes/No)		No		
Method of Compliance Determination		CEMS and performance testing		
Actions Taken for Noncompliance		NA		
Baseline Emissions Rate (specify units)		Not Available		
Allowable Emissions Rate (specify units)		Repair of leak dectects immediately		
Emissions Reduction Potential (%)		Not Available		
Cost Effectiveness (\$/ton removed) Not Available				
Prevention of S		Department of Environmental Protection, Region 4, Atlanta, Georgia; ignificant Deterioration Permit for Greehouse Gas Emissions; Permit 14; Tampa Electric Company Polk Power Station, Polk County, Mulberry, 18, 2013		

Attachment G2: Cost/Economic Impact Analysis

Applicant Name: CPV Towantic, LLC	
Unit No.: AB	
Pollutant: CO	
BACT Option: Oxidation Catalyst	

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each BACT option in which cost and economic impacts are to be considered. On this form, do not include costs that would be incurred regardless of whether the BACT option is chosen. If the particular item is not applicable to the BACT option being evaluated, indicate "Not Applicable" (N/A) in the appropriate blanks. Add additional lines and/or use additional forms as necessary. Complete this form for each technically feasible BACT Option in Part II of Attachment G Best Available Control Technology (DEEP-NSR-APP-214a).

Part I. Total Capital Investment

Total Capital Investment (TCI) is the total direct and indirect capital costs associated with implementation of a BACT option. Use Tables A and B to indicate the direct and indirect capital costs that would be incurred above the baseline project costs. Attach vendor quotes and additional sheets as necessary.

Table A. Direct Capital Costs

	Item	Cost Estimate	Reference/Comments
	Equipment Costs (Itemize Below)		
	Oxidation Catalyst	\$ 100,000	Babcock & Wilcox budgetary quote
Costs		\$	
nt C		\$	
Equipment		\$	
Equ	2. Instrumentation	\$ 10,000	10%
sed	3. Sales Tax	\$ 5,000	5%
Purchased	4. Freight	\$ 0	Included with sales tax
Pu	5. Other:	\$ 0	
	6. Purchased Equipment Subtotal (Sum of Items 1, 2, 3, 4, and 5)	\$ 115,000	PEC

Table A. Direct Capital Costs (continued)

	7. Foundations and Supports	\$ 9,200	8% of PEC
its	8. Auxiliaries (duct work, fittings – include only the equipment which would not be necessary if the facility not controlled)	/ was \$ 10,000	
Costs	9. Handling and Erection	\$ 16,100	14% of PEC
ıtion	10. Piping	\$ 2,300	2% of PEC
Installation	11. Insulation and Painting	\$ 2,300	2% of PEC
H Ins	12. Electrical	\$ 4,600	4% of PEC
Direct	13. Site Preparation	\$ 0	
_	14. Other:	\$	
	15. Direct Installation Costs Subtotal (Sum of Items 7, 8, 9, 10, 11, 12, 13 and 14)	\$ 44,500	
	16. DIRECT CAPITAL COSTS SUBTOTAL (Sum of Items 6 and 15)	\$ 159,500	

Table B. Indirect Installation Costs

Item	Cost Estimate	Reference/Comments
1. Engineering and Supervision	\$ 11,500	10% of PEC
2. Lost Production (for retrofit situations only)	\$ N/A	
3. Construction and Field Expenses	\$ 5,750	5% of PEC
4. Contractor Fees	\$ 11,500	10% of PEC
5. Start-up and Performance Tests	\$ 3,450	3% of PEC
6. Over-all Contingencies	\$ 3,450	3% of PEC
7. Working Capital (if applicable)	\$ N/A	
8. Other:	\$	
9. Indirect Installation Costs Subtotal (Sum of Items 1, 2, 3, 4, 5, 6, 7, and 8)	\$ 35,650	

Table C. Capital Cost Summary

Item	Cost Estimate	Reference/Comments
Total Capital Investment Subtotal (Sum of Table A, item 16 and Table B Item 9)	\$ 195,150	
2. Capital Recovery Factor	0.1098	Non-Catalyst Components
a. Interest Rate	7.0	Non-Catalyst Components
b. Economic Lifetime	15 years	Non-Catalyst Components
3. Capital Recovery Cost	\$ 11,956	Non-Catalyst Components

Part II. Total Annual Cost

Total Annual Cost includes the direct and indirect costs and recovery credits associated with implementation of a BACT option. Use Tables D and E to indicate the annual costs that would be incurred above the baseline project costs. Use Table F to indicate the recovery credits that would be realized after implementation of the BACT option. Summarize the total annual costs in Table G. Attach vendor quotes and additional sheets as necessary.

Table D. Direct Capital Costs

Item	Cost Estimate	Reference/Comments		
1. Operating Labor (Itemize Below)				
	\$ 0			
	\$			
2. Maintenance Labor (Itemize Below)				
	\$ 0			
	\$			
3. Materials (Itemize Below)	<u>'</u>			
	\$			
	\$			
4. Utilities (Itemize Below)				
	\$ 0			
	\$			
5. Waste Treatment and Disposal (Itemize Below)				
Catalyst disposal	\$ 73			
	\$			
6. Replacement Parts (Itemize Below)				
Catalyst Replacement	\$ 21,306	Catalyst replacement annualized over 3 years		
	\$			
7. Other (Please Specify)				
	\$			
	\$			
8. DIRECT ANNUAL COSTS SUBTOTAL (Sum of Items 1, 2, 3, 4, 5, 6, and 7)	\$ 21,110			

Table E. Indirect Annual Costs

Item	Cost Estimate	Reference/Comments
1. Overhead	\$ 0	
Property Taxes, Insurance, and Administrative Charges	\$ 7,806	4% of Total Capital Investment
3. Other:	\$	
4. Indirect Annual Costs Subtotal (Sum of Items 1, 2, and 3)	\$ 7,806	

Table F. Recovery Credits

Item	Cost Estimate	Reference/Comments
1. Materials Recovered		
	\$	
2. Energy Recovered		
	\$	
3. Other (Please Specify)		
	\$	
4. RECOVERY CREDITS SUBTOTAL (Sum of Items 1, 2, and 3)	\$	

Table G. Total Annual Cost Summary

Item	Cost Estimate	Reference/Comments
Direct Annual Costs Subtotal (Table D, Item 8)	\$ 21,110	
Indirect Annual Costs Subtotal (Table E, Item 4)	\$ 7,806	
3. Recovery Credits Subtotal (Table F, Item 4)	\$ 0	
TOTAL ANNUAL COST SUBTOTAL (Items 1 plus Item 2 minus Item 3)	\$ 28,916	

Part III. Cost/Economic Impact Summary

Table H. Total Annualized Cost Summary

Item	Cost Estimate
Capital Recovery Cost (Table C, Item 3)	\$ 11,956
2. Total Annual Cost Subtotal (Table G, Item 4)	\$ 28,916
3. TOTAL ANNUALIZED COST (TAC) (Sum of Items 1 and 2)	\$ 40,872

Table I. Cost Effectiveness

Item	Cost Estimate
Baseline Emissions Rate (tpy)	6.83
2. Allowable Emissions Rate (tpy)	1.37
3. Total Pollutant Removed (tpy) (Difference of Item 1 and Item 2)	5.46
4. AVERAGE COST EFFECTIVENESS OF BACT OPTION (\$/ton of pollutant removed) (Divide Table H, Item 3 by Table I, Item 3)	\$ 7,480

Part IV. Attachments

List any attachments used to support your calculations in the table below.

Attachment	Description
Appendix A	Supporting calculations

CPV Towantic, LLC Economic Analysis For Oxidation Catalyst - CO Control Auxiliary Boiler

Assumptions: E	missions reduction	based on ι	ootential	emissions d	of 6.83 tov per
----------------	--------------------	------------------	-----------	-------------	-----------------

Heat Input (MMBtu/hr) 92.4	total operating hours	4.000
----------------------------	-----------------------	-------

Catalyst volume (ft³) 20 Estimated

CO Emissions After Control (tpy) 1.37 Reduction from 50 ppm to 10 ppm

Equipment Cost (EC)

Oxidation catalyst \$100,000 Vendor quote Instrumentation (10% Of Equipment Costs) \$10,000 OAQPS
Taxes and Freight (5% Of Equipment Costs) \$5,000 OAQPS

Total Equipment Cost (TEC) \$115,000

Direct Installation Costs

Foundation	(TEC*0.08)	\$9,200 <i>OA</i> (QPS
Erection and Handling	(TEC*0.14)	\$16,100 <i>OA</i> (QPS
Electrical	(TEC*0.04)	\$4,600 <i>OA</i> (QPS
Piping	(TEC*0.02)	\$2,300 OAG	QPS
Insulation	(TEC*0.01)	\$1,150 <i>OA</i> (QPS
Painting	(TEC*0.01)	\$1,150 <i>OA</i> (QPS
Inlet/Outlet Transitions and Vanes	Estimate	\$10,000	

Total Direct Installation Cost \$44,500

Indirect Installation Costs

Engineering and Supervision	(TEC*0.1)	\$11,500 <i>OAQPS</i>
Construction/Field Expenses	(TEC*0.05)	\$5,750 OAQPS
Construction Fee	(TEC*0.1)	\$11,500 <i>OAQPS</i>
Start up	(TEC*0.02)	\$2,300 OAQPS
Performance Test	(TEC*0.01)	\$1,150 OAQPS
Contingencies	(TEC*0.03)	\$3,450 OAQPS

Total Indirect Installation Cost \$35,650

A. Total Capital Cost (TCC) \$195,150

B. Direct annual costs, \$/yr

Total direct annual cost	\$21.110	
Production loss (negligible)	\$0	Assumed zero
Performance Loss	\$0	Assumed zero
Electricity	\$0	Assumed zero
Catalyst Disposal (Catalyst Volume x (\$15/cf) x(0.2439))	\$73	OAQPS
Catalyst replacement (5 yrs @ 7% interest)	\$21,036	Catalyst = 75% of TEC
Maintenance labor & Materials	\$0	Assumed zero
Supervisory labor (15% of Operating Labor)	\$0	Assumed zero
Operating labor	\$0	Assumed zero

C. Indirect annual costs, \$/yr

Overhead (60% of Operating, Supervisory, & Maintenance Labor) \$0 OAQPS Property taxes, insurance and administration (0.04 x TCC) \$7,806 OAQPS

Capital Recovery⁽¹⁾ [0.1098 x [total capital invest. - (catalyst replacement /0.2439)] \$11,956 15 years at 7% interest

Total indirect annual cost \$19,762

Total annual cost \$40,872

CO (tons controlled/yr) 5.46

Cost/ton CO controlled \$7,480

Sources: OAQPS Control Cost Manual (USEPA 1990a)

⁽¹⁾ The capital recovery factor for the non-catalyst components is 0.1098 based on a 15-year equipment life and 7 percent interest rate. The annualized catalyst replacement costs is based upon a 3 year life at 7% interest resulting in a capital recovery factor of 0.3811.

Attachment G2: Cost/Economic Impact Analysis

Applicant Name: CPV Towantic, LLC
Jnit No.: AB
Pollutant: NOx
BACT Option: Selective Catalytic Reduction

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each BACT option in which cost and economic impacts are to be considered. On this form, do not include costs that would be incurred regardless of whether the BACT option is chosen. If the particular item is not applicable to the BACT option being evaluated, indicate "Not Applicable" (N/A) in the appropriate blanks. Add additional lines and/or use additional forms as necessary. Complete this form for each technically feasible BACT Option in Part II of Attachment G Best Available Control Technology (DEEP-NSR-APP-214a).

Part I. Total Capital Investment

Total Capital Investment (TCI) is the total direct and indirect capital costs associated with implementation of a BACT option. Use Tables A and B to indicate the direct and indirect capital costs that would be incurred above the baseline project costs. Attach vendor quotes and additional sheets as necessary.

Table A. Direct Capital Costs

	Item	Cost Estimate	Reference/Comments
	Equipment Costs (Itemize Below)		
	Selective Catalytic Reduction	\$ 150,000	Babcock & Wilcox budgetary quote
Costs		\$	
nt C		\$	
Equipment		\$	
Equ	2. Instrumentation	\$ 15,000	10%
sed	3. Sales Tax	\$ 7,500	5%
Purchased	4. Freight	\$0	Included with sales tax
Pu	5. Other:	\$ 0	
	6. Purchased Equipment Subtotal (Sum of Items 1, 2, 3, 4, and 5)	\$ 172,500	PEC

Table A. Direct Capital Costs (continued)

	7. Foundations and Supports	\$ 13,800	8% of PEC
sts	Auxiliaries (duct work, fittings – include only the equipment which would not be necessary if the facility was not controlled)	\$ 10,000	
Costs	9. Handling and Erection	\$ 24,150	14% of PEC
ıtion	10. Piping	\$ 3,450	2% of PEC
stalls	11. Insulation and Painting	\$ 3,450	2% of PEC
H Ins	12. Electrical	\$ 6,900	4% of PEC
Direct Installation	13. Site Preparation	\$ 0	
	14. Other:	\$	
	15. Direct Installation Costs Subtotal (Sum of Items 7, 8, 9, 10, 11, 12, 13 and 14)	\$ 61,750	
	16. DIRECT CAPITAL COSTS SUBTOTAL (Sum of Items 6 and 15)	\$ 234,250	

Table B. Indirect Installation Costs

Item	Cost Estimate	Reference/Comments
1. Engineering and Supervision	\$ 17,250	10% of PEC
2. Lost Production (for retrofit situations only)	\$ N/A	
3. Construction and Field Expenses	\$ 8,625	5% of PEC
4. Contractor Fees	\$ 17,250	10% of PEC
5. Start-up and Performance Tests	\$ 5,175	3% of PEC
6. Over-all Contingencies	\$ 5,175	3% of PEC
7. Working Capital (if applicable)	\$ N/A	
8. Other:	\$	
9. Indirect Installation Costs Subtotal (Sum of Items 1, 2, 3, 4, 5, 6, 7, and 8)	\$ 53,475	

Table C. Capital Cost Summary

Item	Cost Estimate	Reference/Comments
Total Capital Investment Subtotal (Sum of Table A, item 16 and Table B Item 9)	\$ 287,725	
2. Capital Recovery Factor	0.1098	Non-Catalyst Components
a. Interest Rate	7.0	Non-Catalyst Components
b. Economic Lifetime	15 years	Non-Catalyst Components
3. Capital Recovery Cost	\$ 22,120	Non-Catalyst Components

Part II. Total Annual Cost

Total Annual Cost includes the direct and indirect costs and recovery credits associated with implementation of a BACT option. Use Tables D and E to indicate the annual costs that would be incurred above the baseline project costs. Use Table F to indicate the recovery credits that would be realized after implementation of the BACT option. Summarize the total annual costs in Table G. Attach vendor quotes and additional sheets as necessary.

Table D. Direct Capital Costs

Item	Cost Estimate	Reference/Comments		
1. Operating Labor (Itemize Below)				
	\$ 0			
	\$			
2. Maintenance Labor (Itemize Below)				
	\$0			
	\$			
3. Materials (Itemize Below)				
Ammonia	\$ 348	Reagent		
	\$			
4. Utilities (Itemize Below)				
	\$ 0			
	\$			
5. Waste Treatment and Disposal (Itemize Below)				
Catalyst disposal	\$ 73			
	\$			
6. Replacement Parts (Itemize Below)				
Catalyst Replacement	\$ 21,036	Catalyst replacement annualized over 3 years		
	\$			
7. Other (Please Specify)				
	\$			
	\$			
8. DIRECT ANNUAL COSTS SUBTOTAL (Sum of Items 1, 2, 3, 4, 5, 6, and 7)	\$ 21,458			

Table E. Indirect Annual Costs

Item	Cost Estimate	Reference/Comments
1. Overhead	\$ 0	
Property Taxes, Insurance, and Administrative Charges	\$ 11,509	4% of Total Capital Investment
3. Other:	\$	
4. Indirect Annual Costs Subtotal (Sum of Items 1, 2, and 3)	\$ 11,509	

Table F. Recovery Credits

Item	Cost Estimate	Reference/Comments	
1. Materials Recovered			
	\$		
2. Energy Recovered			
	\$		
3. Other (Please Specify)	3. Other (Please Specify)		
	\$		
4. RECOVERY CREDITS SUBTOTAL (Sum of Items 1, 2, and 3)	\$		

Table G. Total Annual Cost Summary

Item	Cost Estimate	Reference/Comments
Direct Annual Costs Subtotal (Table D, Item 8)	\$ 21,458	
2. Indirect Annual Costs Subtotal (Table E, Item 4)	\$ 11,509	
3. Recovery Credits Subtotal (Table F, Item 4)	\$ 0	
4. TOTAL ANNUAL COST SUBTOTAL (Items 1 plus Item 2 minus Item 3)	\$ 32,967	

Part III. Cost/Economic Impact Summary

Table H. Total Annualized Cost Summary

Item	Cost Estimate
Capital Recovery Cost (Table C, Item 3)	\$ 22,120
Total Annual Cost Subtotal (Table G, Item 4)	\$ 32,967
3. TOTAL ANNUALIZED COST (TAC) (Sum of Items 1 and 2)	\$ 55,087

Table I. Cost Effectiveness

Item	Cost Estimate
Baseline Emissions Rate (tpy)	2.02
2. Allowable Emissions Rate (tpy)	0.45
3. Total Pollutant Removed (tpy) (Difference of Item 1 and Item 2)	1.57
4. AVERAGE COST EFFECTIVENESS OF BACT OPTION (\$/ton of pollutant removed) (Divide Table H, Item 3 by Table I, Item 3)	\$ 35,062

Part IV. Attachments

List any attachments used to support your calculations in the table below.

Attachment	Description
Appendix A	Supporting calculations

CPV Towantic, LLC Economic Analysis For SCR - Auxiliary Boiler

Assumptions:	Emissions reduction based	d on potentia	al emissions of 2.02 tpy per		
Heat Input (MN Catalyst volum NOx Emissions		92.4 20 0.449	total operating hours Estimated Reduction from 9 ppm to 2 ppm	4,000	
Equipment Cos					
SCR Instrumentation (10% Of Equipment Costs) Taxes and Freight (5% Of Equipment Costs) Total Equipment Cost (TEC)					Vendor quote OAQPS OAQPS
Direct Installati	on Costs				
	Foundation Erection and Handling Electrical Piping Insulation Painting Inlet/Outlet Transitions and	d Vanes	(TEC*0.08) (TEC*0.14) (TEC*0.04) (TEC*0.02) (TEC*0.01) (TEC*0.01) Estimate	\$3,450 \$1,725	
Total Direct In	stallation Cost			\$61,750	
Indirect Installa	ation Costs				
Engineering and Supervision (TEC*0.1) Construction/Field Expenses (TEC*0.05) Construction Fee (TEC*0.1) Start up (TEC*0.02) Performance Test (TEC*0.01) Contingencies (TEC*0.03)			\$17,250 \$3,450 \$1,725	OAQPS	
A. Total Capit	Installation Cost			\$287,725	
•				Ψ201,120	
B. Direct annual costs, \$/yr Operating labor Supervisory labor (15% of Operating Labor) Maintenance labor & Materials Catalyst replacement (5 yrs @ 7% interest) Catalyst Disposal (Catalyst Volume x (\$15/cu) x(0.2439)) Ammonia (\$600/ton anhydrous NH3, 0.37 tons NH3 per ton NOx removed) Electricity Performance Loss Production loss (negligible) Total direct annual cost				\$0 \$0 \$21,036 \$73 \$348 \$0 \$0	Assumed zero Assumed zero Assumed zero Catalyst = 50% of TEC ACT Market Price Assumed zero Assumed zero Assumed zero
C. Indirect ann	ual costs, \$/vr				
	Overhead (60% of Operati Property taxes, insurance	and adminis		\$11,509	
	Capital Recovery [0.1098	x [total capital	invest (catalyst replacement /0.2439)]	_	15 years at 7% interest
			Total indirect annual cost Total annual cost NOx (tons controlled/yr) Cost/ton NOx controlled	\$33,629 \$55,087 1.57 \$35,062	

⁽¹⁾ The capital recovery factor for the non-catalyst SCR components is 0.1098 based on a 15-year equipment life and 7 percent interest rate. The annualized catalyst replacement costs is based upon a 3 year life at 7% interest resulting in a capital recovery factor of 0.3811.

Sources: USEPA, 1993a: "Alternative Control Techniques Document--NOx Emission from Stationary Gas Turbines."

EPA-453/R-93-007, U.S. Environmental Protection Agency, Research Triangle Park, NC.

OAQPS Control Cost Manual (USEPA 1990a)

Attachment G2: Cost/Economic Impact Analysis

Applicant Name: CPV Towantic, LLC	
Unit No.: AB	
Pollutant: VOC	
BACT Option: Oxidation Catalyst	

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each BACT option in which cost and economic impacts are to be considered. On this form, do not include costs that would be incurred regardless of whether the BACT option is chosen. If the particular item is not applicable to the BACT option being evaluated, indicate "Not Applicable" (N/A) in the appropriate blanks. Add additional lines and/or use additional forms as necessary. Complete this form for each technically feasible BACT Option in Part II of Attachment G Best Available Control Technology (DEEP-NSR-APP-214a).

Part I. Total Capital Investment

Total Capital Investment (TCI) is the total direct and indirect capital costs associated with implementation of a BACT option. Use Tables A and B to indicate the direct and indirect capital costs that would be incurred above the baseline project costs. Attach vendor quotes and additional sheets as necessary.

Table A. Direct Capital Costs

	Item	Cost Estimate	Reference/Comments
	Equipment Costs (Itemize Below)		
	Oxidation Catalyst	\$ 100,000	Babcock & Wilcox budgetary quote
Costs		\$	
nt C		\$	
Equipment		\$	
Equ	2. Instrumentation	\$ 10,000	10%
sed	3. Sales Tax	\$ 5,000	5%
Purchased	4. Freight	\$ 0	Included with sales tax
Pu	5. Other:	\$ 0	
	6. Purchased Equipment Subtotal (Sum of Items 1, 2, 3, 4, and 5)	\$ 115,000	PEC

Table A. Direct Capital Costs (continued)

	7. Foundations and Supports	\$ 9,200	8% of PEC
sts	Auxiliaries (duct work, fittings – include only the equipment which would not be necessary if the facility was not controlled)	\$ 10,000	
Costs	9. Handling and Erection	\$ 16,100	14% of PEC
ıtion	10. Piping	\$ 2,300	2% of PEC
stalls	11. Insulation and Painting	\$ 2,300	2% of PEC
H Ins	12. Electrical	\$ 4,600	4% of PEC
Direct Installation	13. Site Preparation	\$ 0	
	14. Other:	\$	
	15. Direct Installation Costs Subtotal (Sum of Items 7, 8, 9, 10, 11, 12, 13 and 14)	\$ 44,500	
	16. DIRECT CAPITAL COSTS SUBTOTAL (Sum of Items 6 and 15)	\$ 159,500	

Table B. Indirect Installation Costs

Item	Cost Estimate	Reference/Comments
1. Engineering and Supervision	\$ 11,500	10% of PEC
2. Lost Production (for retrofit situations only)	\$ N/A	
3. Construction and Field Expenses	\$ 5,750	5% of PEC
4. Contractor Fees	\$ 11,500	10% of PEC
5. Start-up and Performance Tests	\$ 3,450	3% of PEC
6. Over-all Contingencies	\$ 3,450	3% of PEC
7. Working Capital (if applicable)	\$ N/A	
8. Other:	\$	
9. Indirect Installation Costs Subtotal (Sum of Items 1, 2, 3, 4, 5, 6, 7, and 8)	\$ 35,650	

Table C. Capital Cost Summary

Item	Cost Estimate	Reference/Comments
Total Capital Investment Subtotal (Sum of Table A, item 16 and Table B Item 9)	\$ 195,150	
2. Capital Recovery Factor	0.1098	Non-Catalyst Components
a. Interest Rate	7.0	Non-Catalyst Components
b. Economic Lifetime	15 years	Non-Catalyst Components
3. Capital Recovery Cost	\$ 11,956	Non-Catalyst Components

Part II. Total Annual Cost

Total Annual Cost includes the direct and indirect costs and recovery credits associated with implementation of a BACT option. Use Tables D and E to indicate the annual costs that would be incurred above the baseline project costs. Use Table F to indicate the recovery credits that would be realized after implementation of the BACT option. Summarize the total annual costs in Table G. Attach vendor quotes and additional sheets as necessary.

Table D. Direct Capital Costs

Item	Cost Estimate	Reference/Comments		
1. Operating Labor (Itemize Below)				
	\$ 0			
	\$			
2. Maintenance Labor (Itemize Below)				
	\$ 0			
	\$			
3. Materials (Itemize Below)	<u>'</u>			
	\$			
	\$			
4. Utilities (Itemize Below)				
	\$ 0			
	\$			
5. Waste Treatment and Disposal (Itemize Below)	<u>'</u>			
Catalyst disposal	\$ 73			
	\$			
6. Replacement Parts (Itemize Below)				
Catalyst Replacement	\$ 21,306	Catalyst replacement annualized over 3 years		
	\$			
7. Other (Please Specify)				
	\$			
	\$			
8. DIRECT ANNUAL COSTS SUBTOTAL (Sum of Items 1, 2, 3, 4, 5, 6, and 7)	\$ 21,110			

Table E. Indirect Annual Costs

Item	Cost Estimate	Reference/Comments
1. Overhead	\$ 0	
Property Taxes, Insurance, and Administrative Charges	\$ 7,806	4% of Total Capital Investment
3. Other:	\$	
4. Indirect Annual Costs Subtotal (Sum of Items 1, 2, and 3)	\$ 7,806	

Table F. Recovery Credits

Item	Cost Estimate	Reference/Comments
1. Materials Recovered		
	\$	
2. Energy Recovered		
	\$	
3. Other (Please Specify)		
	\$	
4. RECOVERY CREDITS SUBTOTAL (Sum of Items 1, 2, and 3)	\$	

Table G. Total Annual Cost Summary

Item	Cost Estimate	Reference/Comments
Direct Annual Costs Subtotal (Table D, Item 8)	\$ 21,110	
Indirect Annual Costs Subtotal (Table E, Item 4)	\$ 7,806	
3. Recovery Credits Subtotal (Table F, Item 4)	\$ 0	
TOTAL ANNUAL COST SUBTOTAL (Items 1 plus Item 2 minus Item 3)	\$ 28,916	

Part III. Cost/Economic Impact Summary

Table H. Total Annualized Cost Summary

Item	Cost Estimate
Capital Recovery Cost (Table C, Item 3)	\$ 11,956
2. Total Annual Cost Subtotal (Table G, Item 4)	\$ 28,916
3. TOTAL ANNUALIZED COST (TAC) (Sum of Items 1 and 2)	\$ 40,872

Table I. Cost Effectiveness

Item	Cost Estimate
Baseline Emissions Rate (tpy)	0.75
2. Allowable Emissions Rate (tpy)	0.50
Total Pollutant Removed (tpy) (Difference of Item 1 and Item 2)	0.25
4. AVERAGE COST EFFECTIVENESS OF BACT OPTION (\$/ton of pollutant removed) (Divide Table H, Item 3 by Table I, Item 3)	\$ 163,487

Part IV. Attachments

List any attachments used to support your calculations in the table below.

Attachment	Description
Appendix A	Supporting calculations

CPV Towantic, LLC Economic Analysis For Oxidation Catalyst - VOC Control Auxiliary Boiler

Assumptions: Emissions reduction based on potential emissions of 6.83 tpy per

Heat Input (MMBtu/hr) 92.4 total operating hours 4,000

Catalyst volume (ft³) 20 Estimated

CO Emissions After Control (tpy) 0.50 Reduction from 50 ppm to 10 ppm

Equipment Cost (EC)

Oxidation catalyst \$100,000 Vendor quote Instrumentation (10% Of Equipment Costs) \$10,000 OAQPS

Taxes and Freight (5% Of Equipment Costs) \$5,000 OAQPS

Total Equipment Cost (TEC) \$115,000

Direct Installation Costs

Foundation	(TEC*0.08)	\$9,200 OAG	QPS
Erection and Handling	(TEC*0.14)	\$16,100 <i>OA</i> 0	QPS
Electrical	(TEC*0.04)	\$4,600 <i>OA</i> (QPS
Piping	(TEC*0.02)	\$2,300 OAG	QPS
Insulation	(TEC*0.01)	\$1,150 <i>OA</i> (QPS
Painting	(TEC*0.01)	\$1,150 <i>OA</i> (QPS
Inlet/Outlet Transitions and Vanes	Estimate	\$10,000	

Total Direct Installation Cost \$44,500

Indirect Installation Costs

Engineering and Supervision	(TEC*0.1)	\$11,500 <i>OAQPS</i>
Construction/Field Expenses	(TEC*0.05)	\$5,750 OAQPS
Construction Fee	(TEC*0.1)	\$11,500 <i>OAQPS</i>
Start up	(TEC*0.02)	\$2,300 OAQPS
Performance Test	(TEC*0.01)	\$1,150 OAQPS
Contingencies	(TEC*0.03)	\$3,450 OAQPS

Total Indirect Installation Cost \$35,650

A. Total Capital Cost (TCC) \$195,150

B. Direct annual costs, \$/yr

Operating labor \$0 Assumed zero Supervisory labor (15% of Operating Labor) \$0 Assumed zero Maintenance labor & Materials \$0 Assumed zero Catalyst replacement (5 yrs @ 7% interest) \$21,036 Catalyst = 75% of TEC Catalyst Disposal (Catalyst Volume x (\$15/cf) x(0.2439)) \$73 OAQPS Electricity \$0 Assumed zero Performance Loss \$0 Assumed zero Production loss (negligible) \$0 Assumed zero Total direct annual cost \$21,110

C. Indirect annual costs, \$/yr

Overhead (60% of Operating, Supervisory, & Maintenance Labor) \$0 OAQPS Property taxes, insurance and administration (0.04 x TCC) \$7,806 OAQPS

Capital Recovery⁽¹⁾ [0.1098 x [total capital invest. - (catalyst replacement /0.2439)] \$11,956 15 years at 7% interest

Total indirect annual cost \$19,762

Total annual cost \$40,872

CO (tons controlled/yr) 0.25

Cost/ton CO controlled \$163,487

Sources: OAQPS Control Cost Manual (USEPA 1990a)

⁽¹⁾ The capital recovery factor for the non-catalyst components is 0.1098 based on a 15-year equipment life and 7 percent interest rate. The annualized catalyst replacement costs is based upon a 3 year life at 7% interest resulting in a capital recovery factor of 0.3811.

Attachment G2: Cost/Economic Impact Analysis

Applicant Name: CPV Towantic, LLC
Unit No.: CT1/DB1 & CT2/DB2 Combined
Pollutant: GHGs
BACT Option: Carbon Capture and Sequestration

Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

Complete this form for each BACT option in which cost and economic impacts are to be considered. On this form, do not include costs that would be incurred regardless of whether the BACT option is chosen. If the particular item is not applicable to the BACT option being evaluated, indicate "Not Applicable" (N/A) in the appropriate blanks. Add additional lines and/or use additional forms as necessary. Complete this form for each technically feasible BACT Option in Part II of Attachment G Best Available Control Technology (DEEP-NSR-APP-214a).

Part I. Total Capital Investment

Total Capital Investment (TCI) is the total direct and indirect capital costs associated with implementation of a BACT option. Use Tables A and B to indicate the direct and indirect capital costs that would be incurred above the baseline project costs. Attach vendor quotes and additional sheets as necessary.

Table A. Direct Capital Costs

	Item	Cost Estimate	Reference/Comments
	1. Equipment Costs (Itemize Below)		
	Carbon Capture System	\$ 497,636,364	Report of the Interagency Task Force on Carbon Capture and Storage estimate of \$340 million for 550 MW plant scaled up to 805 MW.
Equipment Costs	Transport Pipeline	\$ 112,123,162	NETL "Carbon Dioxide Transport and Storage Costs in NETL Studies" estimate for 100 mile, 16" ID pipeline. See Appendix A
uipn		\$	
		\$	
Purchased	2. Instrumentation	\$	
urch	3. Sales Tax	\$	
_	4. Freight	\$	
	5. Other:	\$	
	6. Purchased Equipment Subtotal (Sum of Items 1, 2, 3, 4, and 5)	\$	

Table A. Direct Capital Costs (continued)

	7. Foundations and Supports	\$
ts	8. Auxiliaries (duct work, fittings – include only the equipment which would not be necessary if the facility was not controlled)	\$
Costs	9. Handling and Erection	\$
ıtion	10. Piping	\$
talla	11. Insulation and Painting	\$
t Ins	12. Electrical	\$
Direct Installation	13. Site Preparation	\$
_	14. Other:	\$
	15. Direct Installation Costs Subtotal (Sum of Items 7, 8, 9, 10, 11, 12, 13 and 14)	\$
	16. DIRECT CAPITAL COSTS SUBTOTAL (Sum of Items 6 and 15)	\$

Table B. Indirect Installation Costs

Item	Cost Estimate	Reference/Comments
1. Engineering and Supervision	\$	
2. Lost Production (for retrofit situations only)	\$	
3. Construction and Field Expenses	\$	
4. Contractor Fees	\$	
5. Start-up and Performance Tests	\$	
6. Over-all Contingencies	\$	
7. Working Capital (if applicable)	\$	
8. Other:	\$	
9. Indirect Installation Costs Subtotal (Sum of Items 1, 2, 3, 4, 5, 6, 7, and 8)	\$	

Table C. Capital Cost Summary

Item	Cost Estimate	Reference/Comments
Total Capital Investment Subtotal (Sum of Table A, item 16 and Table B Item 9)	\$ 609,759,526	Total capital investment for carbon capture equipment and pipeline
2. Capital Recovery Factor		
a. Interest Rate		
b. Economic Lifetime		
3. Capital Recovery Cost	\$	

Part II. Total Annual Cost

Total Annual Cost includes the direct and indirect costs and recovery credits associated with implementation of a BACT option. Use Tables D and E to indicate the annual costs that would be incurred above the baseline project costs. Use Table F to indicate the recovery credits that would be realized after implementation of the BACT option. Summarize the total annual costs in Table G. Attach vendor quotes and additional sheets as necessary.

Table D. Direct Capital Costs

Item	Cost Estimate	Reference/Comments						
1. Operating Labor (Itemize Below)								
	\$							
	\$							
2. Maintenance Labor (Itemize Below)								
	\$							
	\$							
3. Materials (Itemize Below)								
	\$							
	\$							
4. Utilities (Itemize Below)	•							
	\$							
	\$							
5. Waste Treatment and Disposal (Itemize Below)	•							
	\$							
	\$							
6. Replacement Parts (Itemize Below)								
	\$							
	\$							
7. Other (Please Specify)								
	\$							
	\$							
8. DIRECT ANNUAL COSTS SUBTOTAL (Sum of Items 1, 2, 3, 4, 5, 6, and 7)	\$							

Table E. Indirect Annual Costs

Item	Cost Estimate	Reference/Comments
1. Overhead	\$	
Property Taxes, Insurance, and Administrative Charges	\$	
3. Other:	\$	
4. Indirect Annual Costs Subtotal (Sum of Items 1, 2, and 3)	\$	

Table F. Recovery Credits

Item	Cost Estimate	Reference/Comments					
1. Materials Recovered							
	\$						
2. Energy Recovered							
	\$						
3. Other (Please Specify)							
	\$						
4. RECOVERY CREDITS SUBTOTAL (Sum of Items 1, 2, and 3)	\$						

Table G. Total Annual Cost Summary

Item	Cost Estimate	Reference/Comments
Direct Annual Costs Subtotal (Table D, Item 8)	\$	
2. Indirect Annual Costs Subtotal (Table E, Item 4)	\$	
3. Recovery Credits Subtotal (Table F, Item 4)	\$	
4. TOTAL ANNUAL COST SUBTOTAL (Items 1 plus Item 2 minus Item 3)	\$ 302,435,980	Based upon Interagency Task Force report estimate of \$44/MWh (Figure III-I) and 6,873,545 MWh/yr

Part III. Cost/Economic Impact Summary

Table H. Total Annualized Cost Summary

Item	Cost Estimate
Capital Recovery Cost (Table C, Item 3)	\$
2. Total Annual Cost Subtotal (Table G, Item 4)	\$
3. TOTAL ANNUALIZED COST (TAC) (Sum of Items 1 and 2)	\$ 302,435,980

Table I. Cost Effectiveness

Item	Cost Estimate
Baseline Emissions Rate (tpy)	2,656,018
2. Allowable Emissions Rate (tpy)	531,203
3. Total Pollutant Removed (tpy) (Difference of Item 1 and Item 2)	2,124,814
4. AVERAGE COST EFFECTIVENESS OF BACT OPTION (\$/ton of pollutant removed) (Divide Table H, Item 3 by Table I, Item 3)	\$ 142

Part IV. Attachments

List any attachments used to support your calculations in the table below.

Attachment	Description								
Appendix A	Transport pipeline cost calculation								

Pipeline Costs for Carbon Transport CPV Towantic, LLC

Diameter	16	inches
Miles	100	miles
Materials		\$70,350 + \$2.01×L × (330.5 × D ² + 686.7 × D + 26,960)
Labor	\$58,874,146	\$371,850 + \$2.01 × L × (343.2 × D ² + 2,074 × D + 170,013)
Misc	\$22,142,680	$147,250 + 1.55 \times L \times (8,417 \times D + 7,234)$
Right of Way	\$5,045,760	\$51,200 + \$1.28 × L × (577 × D + 29,788)
Surge Tank	\$1,244,724	Fixed cost = $$1,244,724$
Control System	\$111,907	Fixed cost = \$111,907
TOTAL	\$112,123,162	

Source: National Energy Technology Lab report "Carbon Dioxide Transport and Storage Costs in NETL Studies" (March 2013)

Attachment G3: Summary of Best Available Control Technology Reviews

Complete this form in accordance with the instructions (DEEP-NSR-INST-214) to ensure the proper handling of your application. Print or type unless otherwise noted.

List each emissions unit subject to the BACT requirements. For each emissions unit listed, indicate the Emissions Unit number and all pollutants that are subject to the BACT requirements. *Attachment G: Analysis of Best Available Control Technology* (DEEP-NSR-APP-214a) should be completed for each emissions unit-pollutant combination listed in this table.

i -	Pollutants Subject to BACT											
Unit Description	Unit Number	PM	PM ₁₀	PM _{2.5}	SO ₂	NO _x	со	voc	GHG		Other (please specify)	
Combustion Turbine #1	CT1	\boxtimes	\boxtimes	\boxtimes			\boxtimes		\boxtimes	\boxtimes	H2SO4 & NH3	
Combustion Turbine #2	CT2							\boxtimes	\boxtimes		H2SO4 & NH3	
Duct Burner #1	DB1		\boxtimes	\boxtimes		\boxtimes	\boxtimes	\boxtimes	\boxtimes		H2SO4 & NH3	
Duct Burner #2	DB2	\boxtimes	\boxtimes	\boxtimes	\boxtimes	\boxtimes	\boxtimes	\boxtimes	\boxtimes	\boxtimes	H2SO4 & NH3	
Auxliary Boiler	AB	\boxtimes	\boxtimes	\boxtimes	\boxtimes	\boxtimes	\boxtimes	\boxtimes	\boxtimes	\boxtimes	H2SO4	
Emergency Generator Engine	EG	\boxtimes	\boxtimes	\boxtimes	\boxtimes	\boxtimes	\boxtimes	\boxtimes	\boxtimes	\boxtimes	H2SO4	
Emergency Fire Pump Engine	FP	\boxtimes		\boxtimes			\boxtimes		\boxtimes	\boxtimes	H2SO4	
Fugitive Emissions	FUG								\boxtimes			
Baseline Project Emissions Total in tons per year (tpy):		154.7	154.7	154.7	39.7	6,800	1,742	58.1	4,065,51 6	180.6	Comments: 180.6 tpy reflects combined H2SO4 and NH3 emissions	
Allowable Project Emissions Total in tons per year (tpy):		154.7	154.7	154.7	39.7	196.2	136.4	49.9	2,678,61 2	180.6		

Bureau of Air Management DEEP-NSR-APP-214d

ATTACHMENT H - MAJOR MODIFICATION DETERMINATION FORM

Not required.



ATTACHMENT I - PREVENTION OF SIGNIFICANT DETERIORATION

The following pages provide a complete PSD of Air Quality form (DEEP-NSR-APP-216) and additional information to support the form in accordance with DEEP's instructions. Attachments associated with this form are listed below, indicating applicability and location, if not provided following this form.

- Attachment 216-A: Existing Actual Emissions: Alternative Two-Year Period Justification (Not Applicable)
- Attachment 216-B: New Actual Emissions: Alternative Two-Year Period Justification (Not Applicable)
- Attachment 216-C: BACT Determination (see Attachments G, G1, G2, and G3)
- Attachment 216-D: Ambient Monitoring Analysis (see Attachment L)
- Attachment 216-E: Source Impact Analysis (see Attachment L)
- Attachment 216-F: Ambient Air Quality Analysis (see Attachment L)
- Attachment 216-G: Visibility, Soils, Vegetation, and Growth Analysis (see Attachment L)
- Attachment 216-H: Growth and Ambient Air Impact Analysis (see Attachment L)
- Attachment 216-I: Project Description and Operating Schedule (see Forms 200, E202, and E212)
- Attachment 216-J: Construction Schedule



Attachment I: Prevention of Significant Deterioration of Air Quality (PSD) Program Form

Applicant Name: CPV Towantic, LLC	DEEP USE ONLY									
Complete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-216) to ensure the proper handling of your application. Print or type unless otherwise noted.	App. No.:									
Complete a separate form for each unit that is part of this application package.										
Questions? Visit the Air Permitting web page or contact the Air Permitting Engineer	of the Day at 860-424-4152.									
Note: This form is not required if Current Premises Potential Emissions and Propose Part VII.B of <i>Attachment F: Premises Information Form - DEEP-NSR-APP-217</i>) from than major source thresholds for each pollutant. (i.e. an existing minor premises acresults in the premises becoming a new major source.)	m this project are each less									
Part I: Applicability										
A. Project with Proposed Allowable Emissions Greater than Major Stationary at an Existing Minor Stationary Source (Premises)	Source Thresholds Located									
Indicate the pollutants for which the project will be classified as a major stationary source as indicated in Part VII.B of Attachment F. (Check all that apply.) □ SO₂ □ NO _x	.₅									
The project is subject to PSD review for each pollutant that is checked above. Call other pollutants.	complete Part II of this form for									
B. Any Project Located at an Existing Major Stationary Source (Premises)										
If the project is located at an existing major stationary source (prior to the subject complete Attachment H: Major Modification Determination Form (DEEP-NSR-AF form.	et equipment being permitted), P-213) before completing this									
Indicate the pollutants for which the project will be considered a major modification as indicated in Part V of Attachment H. (Check all that apply.) □ PM □ P	.5 □ Pb □CO₂e and GHG									

The project is subject to PSD review for each pollutant that is checked above. Complete Part II of this form for all other pollutants.

Part II: Additional Pollutant PSD Applicability

In addition to the pollutants previously indicated, PSD review must be completed for every other pollutant that has a total project emissions increase and a net emissions increase that are greater than the significant emission rate thresholds in <u>Table 3a(k)-1</u> of RCSA section 22a-174-3a(k) even if the premises is not major for that pollutant.

Indicate in the following table the pollutants that the source emits (that were not checked in Part I of this form) and enter the total proposed project emissions increase.

A. Total Project Emissions Increase

Pollutant	Project Emits Pollutant?	Total Project Proposed Potential Emissions (tpy)	Total Project 2-yr Actual Emissions, if modification (tpy)	Total Project Emissions Increase (tpy)	Significant Emission Rate Threshold (tpy)	Is TOTAL PROJECT EMISSIONS INCREASE greater than the SIGNIFICANT EMISSION RATE THRESHOLD?
PM					25	☐ Yes ☐ No
PM ₁₀					15	☐ Yes ☐ No
PM _{2.5}					10	☐ Yes ☐ No
SO ₂ (as a PM _{2.5} precursor)	\boxtimes	39.7	0	39.7	40	☐ Yes ⊠ No
SO ₂ (NAAQS)	\boxtimes	39.7	0	39.7	40	☐ Yes ⊠ No
NO _x (as an ozone precursor)					25	☐ Yes ☐ No
NO _x (as a PM _{2.5} precursor)					40	☐ Yes ☐ No
NO _x (NAAQS)					40	☐ Yes ☐ No
СО					100	☐ Yes ☐ No
voc	\boxtimes	49.9	0	49.9	25	⊠ Yes □ No
Pb	\boxtimes	0.03	0	0.03	0.6	☐ Yes ⊠ No
H ₂ S					10	☐ Yes ☐ No
Reduced Sulfur & Compounds					10	☐ Yes ☐ No

A. Total Project Emissions Increase, continued

Pollutant	Project Emits Pollutant?	Total Project Proposed Potential Emissions (tpy)	Total Project 2-yr Actual Emissions, if modification (tpy)	Total Project Emissions Increase (tpy)	Significant Emission Rate Threshold (tpy)	Is TOTAL PROJECT EMISSIONS INCREASE greater than the SIGNIFICANT EMISSION RATE THRESHOLD?
Sulfuric Acid Mist		25.3	0	25.3	7	⊠ Yes □ No
Fluorides					3	☐ Yes ☐ No
Mercury		0.007	0	0.007	0.1	☐ Yes ☐ No
MWC Organics					3.5E-6	☐ Yes ☐ No
MWC Metals					15	☐ Yes ☐ No
MWC Acid Gases					40	☐ Yes ☐ No
CO₂e					75,000	☐ Yes ☐ No

3 of 7

If "No":

This pollutant *is not* subject to PSD Review and the PSD Review determination is complete.

If "Yes" and the project is located at an existing minor stationary source (i.e. completed Part I.A of this form):

This pollutant $\emph{\textbf{is}}$ subject to PSD Review. Continue to Part III.

If "Yes" and the project is located at an existing major stationary source (i.e. completed Part I.B of this form):

Continue on to Parts II.B and C for the subject pollutant.

B. Contemporaneous Creditable Emissions Increases and Decreases

Provide the following information for all contemporaneous creditable emissions increases and decreases during the 5-year contemporaneous period determined in Part II of *Attachment H: Major Modification Determination Form.* Calculate the *Total Contemporaneous Increases/Decreases* for the subject pollutant and enter the results in Part I.C. Duplicate this page if necessary.

Change		License or Regulation No. (P)		Pollutants (tpy)									
Type (NEW, MOD,	Equipment Description		Date of										
REM, PBR, DB)	EEM, PBR,		Change	New ACT	2-yr ACT	New ACT	2-yr ACT	New ACT	2-yr ACT	New ACT	2-yr ACT	New ACT	2-yr ACT
			/ /										
			/ /										
			/ /										
			/ /										
			/ /										
			/ /										
			/ /										
			/ /										
	Totals (tpy)												
TOTAL	TOTAL CONTEMPORANEOUS INCREASES/DECREASES (tpy) (New ACT – 2-yr ACT)												

The 2-yr ACT emissions for each unit listed in Part II.B must be based on the average actual emissions for the two years immediately preceding the change. New units would enter a "0" since they did not previously exist. If the most recent two year period was not selected as the representative two year period for actual emissions for any changed unit, check here and submit written justification for using a period other than two years of actual emissions immediately preceding the change as Attachment 216-B.

C. Emissions Summation

Add the *Total Project Emission Increase* values from Part II.A of this form to the *Total Contemporaneous Increases/Decreases* value from Part II.B of this form to calculate the *Net Emissions Increase* for the subject pollutant.

Pollutant	Total Project Emissions Increase (tpy)	Total Contemporaneous Increases/Decreases	Net Emissions Increase	Significant Emission Rate Threshold (RCSA §22a-174-3a(k), Table 3a(k)-1)	Is NET EMISSION equal to or gro SIGNIFICANT EM THRESHO	eater than ISSION RATE
					☐ Yes	☐ No
					☐ Yes	☐ No
					☐ Yes	☐ No
					☐ Yes	☐ No
					☐ Yes	☐ No
					☐ Yes	□No
					☐ Yes	□No
					☐ Yes	□No
					☐ Yes	□No
					☐ Yes	□No
					☐ Yes	□No
					☐ Yes	□No

If "No":

This pollutant *is not* subject to PSD Review and the PSD Review determination is complete.

If "Yes":

This pollutant is subject to PSD Review. Continue to Part III.

5 of 7

Part III: Attachments

Complete this part for each pollutant subject to PSD review as indicated in Parts I and II of this form.

Please check the attachments being submitted as verification that all applicable attachments have been submitted with this application form. When submitting such documents, please label the documents as indicated in this Part (e.g., Attachment 216-A, etc.) and be sure to include the applicant's name. All Attachments are **REQUIRED**.

Best Available Control Technology (BACT) Determination Submit a BACT analysis for each pollutant subject to PSD review. The owner or operator of any source subject to PSD shall install BACT as approved by the commissioner. Please complete Attachment G: BACT Determination Form (DEEP-NSR-APP-214) and attach it as Attachment 216-A. Include a detailed description as to what system of continuous emission reduction is planned for the subject source or modification, emission estimates, or any other information necessary to demonstrate that BACT will be applied. [RCSA sections 22a-174-3a(k)(4); -3a(k)(8)(A)(v)]	⊠ Attachment 216-C
Air Quality Analysis	
Ambient Monitoring Analysis Submit an analysis of the effect on ambient air quality in the area of the subject source or modification for pollutants that have allowable emissions in excess of the amount listed in Table 3a(k)-1 of RCSA section 22a-174-3a(k)-1 or those listed in RCSA section 22a-174-24. The analysis shall meet the requirements of RCSA section 22a-174-3a(k)(5). [RCSA section 22a-174-3a(k)(5)]	⊠ Attachment 216-D
Source Impact Analysis Submit a source impact analysis of the effects on ambient air quality in the area of the subject source or modification for pollutants that will have an impact on air quality equal or greater than any amount listed in Table 3a(i)-1 of RCSA section 22a-174-3a(i) or any applicable maximum allowable increase above baseline concentration established in Table 3a(k)-2 of RCSA section 22a-174-3a(k). The analysis shall meet the requirements of RCSA section 22a-174-3a(k)(6). [RCSA section 22a-174-3a(k)(6)]	⊠ Attachment 216-E
Ambient Air Quality Analysis Submit an ambient air quality analysis in accordance with RCSA section 22a-174-3a(i), of the effect of the pollutants listed in Table 3a(k)-1 of RCSA section 22a-174-3a(k). [RCSA section 22a-174-3a(k)(7)]	⊠ Attachment 216-F
Additional Source Information	
Visibility, Soils, Vegetation and Growth Analysis Submit an analysis of the impairment to visibility, soils, and vegetation that would result from construction and operation of the subject source or modification, and an analysis of the general commercial, residential, industrial and other associated growth. The applicant does not need to provide an analysis of the impact on vegetation having no significant commercial or residential value. [RCSA section 22a-174-3a(k)(8)(A)(i)]	⊠ Attachment 216-G

6 of 7

Part III: Attachments (continued)

Growth and Ambient Air Impact Analysis Submit an analysis of the ambient air quality impact projected for the area as a result of the general commercial, residential, industrial, and other growth associated with the subject source or modification. [RCSA section 22a-174-3a(k)(8)(A)(ii)]	⊠ Attachment 216-H
Project Description and Operating Schedule Submit a description of the nature, location, design capacity and typical operating schedule of the subject source or modification, including specifications and drawings showing its design and plant layout. [RCSA section 22a-174-3a(k)(8)(A)(iii)]	⊠ Attachment 216-I
Construction Schedule Submit a schedule for construction of the subject source or modification. [RCSA section 22a-174-3a(k)(8)(A)(iv)]	⊠ Attachment 216-J

Attachment 216-J Construction Schedule

Estimated Towantic Construction Schedule



	Activity	Start Finish			2015				2016				2017				2018			
				Q1	Q2	Q3	Q4													
1	NTP Date	12/01/15	12/04/15																	
2	Engineering design	12/01/15	03/31/17																	
3	Owner Provide Full Site Access	12/01/15	12/04/15																	
4	Construction Mobilization	03/01/16	03/04/16																	
5	Civil Tasks	03/01/16	06/01/17																	
6	Mechanical Tasks	12/01/16	05/01/18																	
7	Electrical Tasks	06/01/17	05/01/18																	
8	Erect Heat Recovery Steam Generator #1	01/01/17	01/01/18																	
9	Erect Heat Recovery Steam Generator #2	02/01/17	02/01/18																	
10	Erect Gas Turbine #1	03/01/17	09/01/17																	
11	Erect Gas Turbine #2	04/01/17	10/03/17																	
12	Erect Steam Turbine	06/01/17	01/31/18																	
13	Start-Up / Comissioning	10/01/17	06/06/18																	
14	Guaranteed Substantial Completion	06/01/18	06/06/18																	

ATTACHMENT J - NON-ATTAINMENT NEW SOURCE REVIEW

The following pages provide a complete Non-Attainment Review of Air Quality form (DEEP-NSR-APP-215) and additional information to support the form in accordance with DEEP's instructions. Attachments associated with this form are listed below, indicating applicability and location, if not provided following this form.

- Attachment 215-A: Alternative Two-Year Period Justification (Not Applicable)
- Attachment 215-B: Analysis of Alternatives
- Attachment 215-C: Secondary or Cumulative Impact Analysis (see Attachment L)
- Attachment 215-D: Off-setting Emission Reductions or Emission Reduction Credits Determination
- Attachment 215-E: Required Number of CERCs Determination (See Attachment J: Part II)



Attachment J: Non-Attainment Review Form

Applic	ant Name: CPV Towantic, LLC		DEEP (JSE ONLY
	lete this form in accordance with the <u>instructions</u> (DEEP-NSR-INST-215) to e the proper handling this application. Print or type unless otherwise noted.	App. No.:		
Quest	ions? Visit the Air Permitting web page or contact the Air Permitting Engineer of the	Day at 8	60-424	-4152.
VII.B o	This form is not required if Current Premises Potential Emissions and Proposed All of Attachment F: Premises Information Form - DEEP-NSR-APP-217) from this project thresholds for each pollutant. (i.e. an existing minor premises adds a minor source in a new major source.)	ct are ea	ch less	than major
	proposed project will be a major modification for NOx or VOC, after completing cation Determination Form (DEEP-NSR-APP-215), skip Part I of this form and comp			
Part	l: Applicability			
A. If	the proposed project is a new major stationary source:			
the pro	te the air quality status of the area in which the premises is or will be located and list oposed project for each pollutant. Indicate if such emissions are greater than the mark all that apply. See instructions for the air quality attainment status of Connecticut in	ajor sourd	e thres	
Ozone	e (check one):			
	Severe Non-Attainment			
	NOx Allowable Emissions from Proposed Project:		tpy	
	Are NOx Allowable Emissions from the Proposed Project Greater Than 25 tp	y? □	Yes	□No
	VOC Allowable Emissions from Proposed Project:		tpy	
	Are VOC Allowable Emissions from the Proposed Project Greater Than 25 tp	oy? □	Yes	□ No
\boxtimes	Serious Non-Attainment			
	NOx Allowable Emissions from Proposed Project:	194	.7 tpy	
	Are NOx Allowable Emissions from the Proposed Project Greater Than 50 tp	y? ⊠	Yes	□No
	VOC Allowable Emissions from Proposed Project	49.	9 tpy	

If "No":

This pollutant is not subject to Non-Attainment Review and the Non-Attainment Review determination is complete.

Are VOC Allowable Emissions from the Proposed Project Greater Than 50 tpy?

If "Yes":

This pollutant is subject to Non-Attainment Review. Continue to Parts II and III of this form for the subject pollutant.

☐ Yes

No

B. If the proposed project is being located at an existing major stationary source and the project did not trigger a major modification for NOx or VOC:

Calculate the net emissions increase of NOx and VOC during the 5-year contemporaneous period determined in Part II of *Attachment H: Major Modification Determination Form,* including the current project. ("Deminimis Rule")

If the net emissions increase during the 5-year contemporaneous period was calculated on *Attachment H – Major Modification Determination Form*, please enter the values in Part I.B.2 of this form. You do not need to complete Part I.B.1 of this form. Otherwise, complete Part I.B.1 of this form to determine the contemporaneous increases and decreases during the 5-year contemporaneous period and enter the results in Part I.B.2.

1. Contemporaneous Creditable Emissions Increases and Decreases

Provide the following information for all contemporaneous creditable NOx and VOC emissions increases and decreases during the 5-year contemporaneous period. Calculate the *Total Contemporaneous Increases/Decreases* for the subject pollutant and enter the results in Part I.B.2. Duplicate this page if necessary.

					Pollutar	its (tpy)	
Change Type (NEW, MOD,	Equipment Description	License or Regulation	Date of	NO	NOx VO		C
REM, PBR, DB)		No. (P)	Change	New ACT	2-yr ACT	New ACT	2-yr ACT
			/ /				
			/ /				
			/ /				
			/ /				
			/ /				
			/ /				
			/ /				
			/ /				
	Totals (tpy)						
TOTAL	CONTEMPORANEOUS INCREA (New ACT – 2-yr A		ES (tpy)		I		I

2. Emission Summation

Add the *Total Project Emission Increase* from Part III of *Attachment H: Major Modification Determination Form* to the *Total Contemporaneous Increases/Decreases* from Part I.B.1 of this form to calculate the *Net Emissions Increase* for the subject pollutant.

Pollutant	Total Project Emissions Increase (tpy)	Total Contemporaneous Increases/Decreases	Net Emissions Increase	Is NET EMISSIONS INCREASE equal to or greater than 25 tpy?	
NOx				☐ Yes	☐ No
VOC				☐ Yes	☐ No

If "No":	
----------	--

This pollutant is not subject to Non-Attainment Review and the Non-Attainment Review determination is complete.

If "Yes":

This pollutant is subject to Non-Attainment Review. Continue to Parts II and III of this form for the subject pollutant.

3 of 6

Part II: Application Requirements for Non-Attainment Areas

Check the applicable box below for each attachment being submitted with this application form. When submitting any supporting documents, please label the documents as indicated in this Part (e.g., Attachment 215A, etc.) and be sure to include the applicant's name as indicated on this application form. All Attachments are **REQUIRED**.

Analysis of Alternatives		
Submit an Analysis of Alternatives for each non-attainment pollutant that includes:		
Alternative sites for the proposed activity;		
Alternative sizes for the subject source or modification;		
Alternative production processes;		
 A demonstration of whether the benefits of the subject source or modification would significantly outweigh its adverse environmental impacts, including secondary impacts and cumulative impacts, and social costs imposed as a result of the location, construction or modification. 		
Secondary or Cumulative Impact Analysis		
Submit an evaluation of secondary impacts or cumulative impacts for each non-attainment pollutant with potential emissions in excess of the amount listed in Table 3a(k)-1 of RCSA section 22a-174-3a(k).	Attachment 215-C	
Offsetting Emission Reductions or Emission Reduction Credits Determination		
Submit documentation for each non-attainment pollutant demonstrating that the planned use of any internal offsets comply with the requirements of RCSA section $22a-174-3a(I)(4)(B)$ and that certified emission reduction credits comply with the requirements of RCSA section $22a-174-3a(I)(5)$.	⊠ Attachment 215-D	
	⊠ Attachment 215-E	
Required Number of CERCs Determination	Number of CERCs Required:	
Submit the calculation method for the number of required CERCs for approval for each non-attainment pollutant.	NOx: 233.6	
	VOC:	
	PM _{2.5} :	

Part III: Lowest Achievable Emission Rate (LAER) Review

Note: Complete this part for each non-attainment pollutant.

Pollutant:	⊠ NOx] VOC	□ PM _{2.5}	
should be inv EPA/State ai technical pap South Coast contact inforr	vestigated and docum r quality permits, cont pers or journals. Attac AQMD, state permit,	ented. Thes rol equipme h documenta vendor, etc. ne, affiliation	e sources include: Ant vendors, trade as ation of investigation) and sufficient inform	ol alternatives, sources other than the RBLC database my limitation found in a State Implementation Plan, sociations, international agencies or companies, to this form. The source of information, (e.g., RBLC, mation for verification of the achievable limit, (e.g. mail of contact; any relevant permit; RBLC ID; etc.)
A. Achieva	bility			
	found for a unit whicl strated in practice.	n is the same	e or similar to the su	bject unit and determine if the emissions limitation has
	LAER		Achievable?	If No, Explain (be specific)
natural gas	ppmvd at 15% O2 dur s firing of combustion duct burners	ring	⊠ Yes □ No	
	ppmvd at 15% O2 dui g of combustion turbir		⊠ Yes □ No	
	ppmvd at 3% O2 usin Ox burners for the au		⊠ Yes □ No	
NOx - mee	et NSPS Subpart IIII fo engines	or	⊠ Yes □ No	
			☐ Yes ☐ No	
			☐ Yes ☐ No	
			☐ Yes ☐ No	
			☐ Yes ☐ No	
			☐ Yes ☐ No	
			☐ Yes ☐ No	

Complete this table for each LAER listed in Part III.A of this form.

LAER Option: NOx - 9.0 ppmvd at 3% O2 using ultra-low NOx burners for the auxliary boiler

Unit Description Auxiliary boiler		
Facility/Location	Green Energy Partners/Stonewall LLC / Leesburg, VA	
Permitting Authority with Contact Information	Virginia Department of Environmental Quality	
Permit No.	73826	
Capacity (specify units) 75 MMBtu/hr heat input		
LAER Determination	Ultra Low-NOx burners and good combustion practices	
Compliance Achieved? ☐ Yes ☐ No		
Method of Compliance Determination Initial performance testing		
Post-LAER Emissions Rate (specify units) N/A		
Reference	Green Energy Partners/Stonewall LLC, Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit, Non-Attainment New Source Review Permit, Stationary Source Permit to Construction and Operate, Registration Number 73826, April 30, 2013.	

LAER Option Proposed:	NOx - 9.0 ppmvd at 3% O2 during natural gas firing of auxiliary boiler
-----------------------	--

Justification:	Lowest permitted NOx emission rate for a natural gas fired auxiliary boiler. See Att. G discussion for further detail.

Complete this table for each LAER listed in Part III.A of this form.

LAER Option: NOx - 2.0 ppmvd at 15% O2 during natural gas firing of combustion turbines & duct burners

Unit Description	Combined Cycle Combustion Turbine	
Facility/Location	Cricket Valley Energy Center LLC / Dover Plains, NY	
Permitting Authority with Contact Information	New York State Department of Environmental Conservation	
Permit No.	3-1326-00275/00004	
Capacity (specify units)	2,061 MMBtu/hr heat input	
LAER Determination Dry low NOx combustors, Selective Catalytic Reduction, good combustion practices		
Compliance Achieved?	☐ Yes ⊠ No	
Method of Compliance Determination CEMS and performance testing		
Post-LAER Emissions Rate (specify units) N/A		
Reference	New York State Department of Environmental Conservation; Preconstruction Permit for a Major Stationary Source; Cricket Valley Energy Center, Dover Plains, NY; Air State Facility Permit ID 3-1326-00275/00004; September 27, 2012.	

LAER Option Proposed: NOx - 2.0 ppmvd at 15% O2 during natural gas firing of combustion turbines & duct burners.

Justification:	Lowest permitted NOx emission rate for a combined cycle combustion turbine firing natural gas. See Att. G discussion for further detail.

Complete this table for each LAER listed in Part III.A of this form.

LAER Option: NOx - 5.0 ppmvd at 15% O2 during ULSD firing of combustion turbines

Unit Description	Combined Cycle Combustion Turbine	
Facility/Location	Westfield Land Development Company, LLC - Pioneer Valley Energy Center / Westfield, MA	
Permitting Authority with Contact Information	Massachusetts Department of Environmental Protection	
Permit No.	Plan #: 1-B-08-037; Trans. #: X223780	
Capacity (specify units) 2,542 MMBtu/hr heat input		
LAER Determination	Dry low NOx combustors, Selective Catalytic Reduction, Water injection during ULSD firing and good combustion practices	
Compliance Achieved?	☐ Yes ☑ No	
Method of Compliance Determination	CEMS and performance testing	
Post-LAER Emissions Rate (specify units)	N/A	
Reference	Commonwealth of Massachusetts, Executive Office of Energy & Environmental Affairs, Department of Environmental Protection Western Regional Office; Conditional Approval to Construct, Westfield Land Development Company, LLC - Pioneer Valley Energy Center, Plan #: 1-B-08-037; Trans. #: X223780; December 31, 2010.	

LAER Option Proposed: NOx - 5.0 ppmvd at 15% O2 during natural gas firing of combustion turbines & duct burners
--

Justification:	Lowest permitted NOx emission rate for a combined cycle combustion turbine firing ULSD. See Att. G discussion for further detail.	

Complete this table for each LAER listed in Part III.A of this form.

LAER Option: NOx - meet NSPS Subpart IIII limit for emergency engines

Unit Description	Emergency Generator Engine and Emergency Fire Pump Engine	
Facility/Location	Green Energy Partners/Stonewall LLC / Leesburg, VA	
Permitting Authority with Contact Information	Virginia Department of Environmental Quality	
Permit No.	73826	
Capacity (specify units)	15.4 MMBtu/hr (generator), 2.54 MMBtu/hr (fire pump)	
LAER Determination	Good combustion practices	
Compliance Achieved?	☐ Yes ☑ No	
Method of Compliance Determination	None	
Post-LAER Emissions Rate (specify units)	N/A	
Reference	Green Energy Partners/Stonewall LLC, Commonwealth of Virginia Department of Environmental Quality, Prevention of Significant Deterioration Permit, Non-Attainment New Source Review Permit, Stationary Source Permit to Construction and Operate, Registration Number 73826, April 30, 2013.	

LAER Option Proposed:	NOx - meet NSPS Subpart IIII limit for emergency engines
-----------------------	--

Justification:	Lowest permitted NOx emission rate for ULSD fired emergency engines. See Att. G discussion for further detail.

ATTACHMENT 215-B ANALYSIS OF ALTERNATIVES

This attachment provides an analysis of alternatives for the CPV Towantic Energy Center (the Project). The Project is currently fully permitted as a 512-megawatt (MW) combined-cycle natural gas-fired electric generating facility, after extensive reviews by state and local agencies and subsequent appeals. As a part of that approval process considerable review occurred by the Connecticut Siting Council (CSC) to evaluate alternatives and confirm that the Project provided an appropriate balance of environmental and community impacts with the need for a reliable and efficient source of energy.

The following sections consider alternatives for the Project as currently proposed, addressing the extent to which its benefits outweigh its adverse environmental impact, including secondary impacts, cumulative impacts, and social costs. As required by CTDEEP, consideration of alternative sites, alternative Project sizes, and technologies are discussed. Lastly, environmental control techniques and technology are summarized, with cross-referencing to Attachment G, which includes a detailed demonstration of Lowest Achievable Emission Rate (LAER) and Best Available Control Technology (BACT) for the Project.

1.0 ALTERNATIVE SITES

A robust consideration of alternative sites was included in the 1998 CSC application for the Project, and the Oxford site was selected based on its balance of favorable attributes. The Town of Oxford had recently added acreage to its industrial zone, and views the Project as an "anchor" tenant. The 20-acre Oxford site was directly proximate to both suitable electric and natural gas infrastructure. Water and sewer infrastructure would be extended directly within the industrial park roadway abutting the site. The following conclusions were made in the CSC application supporting selection of this site for the Project:

- The site, its location, existing infrastructure, environment and topography are characteristics that are conducive to Project development without adverse impacts to the public and the environment.
- Oxford town officials' support is enthusiastic and receptive, since the Project meets several of the town's objectives for its industrial development plan for the area.
- The site requires no new construction of natural gas pipelines or electric transmission lines, nor does it
 present a significant burden on the existing water and sewer capacities of Oxford or the surrounding
 area.
- Since the Oxford area and surrounding region is a net importer of energy, the Project is more likely to service existing and projected electric needs for the area and region in which it is located.

The CSC recognized these advantages in approving the project.

In the years since the Project's initial CSC and air permit approvals, energy and financial market conditions have changed, with favorable conditions currently supporting the Project updates and planned construction. The favorable attributes of the site remain, and have been further improved since the original approvals through construction of Woodruff Hill Road and development of the Woodruff Hill Industrial Park, with utility piping extended to the site and a compatible industrial use (the Spectra compressor station) located immediately to the east. An additional 6 acres of industrially zoned land within the industrial park has been optioned for the Project to utilize the entire property to the north of the compressor station access drive and allow for layout optimization.

2.0 ALTERNATIVE SIZES OR ALTERNATIVE PROCESSES

2.1 Alternative Size/Project Output

As noted above, existing Project approvals reflect a 512-MW generating capability. The proposed Project update incorporates General Electric (GE) H technology to allow for generation of a nominal 805 MW using a similar design and footprint. The updated output for the Project reflects the optimal size to meet current ISO New England needs within the energy market. Note that, although the Project remains similar in physical size, adjustments have been made in specific equipment size reflecting the updated technology as well as considerations for reducing visual and downwash effects (e.g., shorter air cooled condenser, three smaller building enclosures instead of one larger building enclosure).

2.2 Alternative Generation Technologies

The CSC application for the Project evaluated a thorough list of potential generation technologies, and affirmed that combined-cycle technology utilizing natural gas as its primary fuel not only presented economic and efficiency advantages, demonstrated in practice, but was a favorable option from an environmental and acceptability perspective. CPV focuses on clean energy solutions, and also develops renewable energy facilities throughout the U.S. and Canada. However, in this region, on-shore renewable resources are not sufficiently robust to support a commercial-scale energy facility, and energy storage solutions do not yet allow for reliable power generation across the potential demand spectrum. Natural gas combined-cycle technology, as proposed, is an effective companion for renewable energy, with its ability for flexible operation and rapid starts. Combined-cycle technology utilizing natural gas as its primary fuel remains the most favorable option today from a market point of view. This was recently demonstated by ISO New England's choice of a gas-fired combined-cycle facility as the forward capacity market's proxy unit. This technology also maximizes energy efficiency and minimizes air emissions.

2.3 Alternative Fuels

The CSC application for the Project considered a range of alternatives. As noted above, wind and solar renewable energy are not currently able to support commercial energy generation at this scale. Other fossil fuels, such as coal and oil burning facilities, result in greater levels of emissions, as well as potential social impacts associated with fuel delivery and/or storage. Natural gas, delivered via pipeline located adjacent to the site, eliminates the need for road or rail delivery, and provides efficient combustion in combined-cycle mode resulting in the lowest emissions for all fossil fuels. In selecting a backup fuel, in order to support the most reliable Project possible, the use of ultra-low sulfur distillate (ULSD) presents the lowest emitting option of liquid fuels available, and is able to be utilized by the same combustion process and equipment.

2.4 Alternative Cooling Technologies

A natural gas-fired combined-cycle electric generating facility requires cooling, particularly for the condensing of turbine exhaust steam in the steam turbine condensers. The range of cooling technologies was evaluated in the CSC application, with air cooling selected for the Project. Other cooling options such as once-through cooling and wet cooling, utilize significant greater water volume. In a community for which water conservation is a priority, selection of air-cooled condensing technology was appropriate. In considering updates to the Project, CPV investigated the range of currently available technology and has incorporated a design that reduces the size and height of the air-cooled condenser (even with the greater energy output), reducing visibility as well as the effect of downwash.

2.5 Environmental Control Technique and Technology Review

A detailed LAER/BACT demonstration analysis is provided in Section G of this application. As outlined in that section, the Project has selected advanced pollution control technologies and add-on controls to achieve low levels of emissions when operating both with its primary fuel (natural gas) and its backup source (ULSD). In addition, the Project has continued to integrate technology improvements, for example, adding an oxidation catalyst in the recertification of BACT that occurred in 2010. The Project will employ dry-low NO_x combustion, selective catalytic reduction, an oxidation catalyst and good combustion practices utilizing the latest techniques and technologies.

2.6 Summary and Conclusion

The CSC review of the Project incorporated a robust and thorough consideration of the range of alternatives. The Project as proposed reflects the use of an appropriate site, the most efficient generating technology, clean fuels, and state-of-the-art pollution controls for a Project of the optimal size for successful participation in the current ISO New England forward capacity and energy markets. Air quality impacts associated with the Project will comply with National Ambient Air Quality Standards and PSD Increments, which have been established for the protection of the most sensitive members of the population. Benefits of the Project area associated with its efficient, reliable energy production and presence as an anchor tenant in a planned industrial park area. Employment opportunities associated with construction and operation will have secondary beneficial effects throughout the local community, and the Project will contribute substantial financial support to the local community. Beneficial cumulative effects will result from displacement of older, less efficient generating units. The Project has incorporated the best available alternatives in order to balance its impacts and create a beneficial source of electrical generation.

Attachment 215-D - Offsetting Emission Reductions or Emission Reduction Credits Determination

Documentation is required to be provided for each non-attainment pollutant demonstrating that the planned use of any internal offsets comply with the requirements of RCSA section 22a-174-3a(I)(4)(B) and that certified emission reduction credits comply with the requirements of RCSA section 22a-174-3a(I)(5).

In accordance with the requirements of RCSA section 22a-174-3a(I)(5), the emission reduction credits (ERCs) must satisfy the following requirements:

- A. Created and used in accordance with 40 CFR 51;
- B. Real, that is, resulting in a reduction of actual emissions, net of any consequential increase in actual emissions resulting from shifting demand. The emission reductions shall be measured, recorded and reported to the commissioner;
- C. Quantifiable, based on either stack testing approved by the commissioner in writing, conducted pursuant to an appropriate, reliable, and replicable protocol approved by the commissioner, or continuous emissions monitoring certified by the commissioner. Such quantification shall be in terms of the rate and total mass amount of non-attainment pollutant emission reduction;
- D. Surplus, not required by any Connecticut General Statute or regulation adopted thereunder, or mandated by the State Implementation Plan, and not currently relied upon for any attainment plan, any Reasonable Further Progress plan or milestone demonstration;
- E. Permanent, in that at the source of the emission reduction, the emission reduction system shall be in place and operating, and an appropriate record keeping system is maintained to collect and record the data required to verify and quantify such emissions reductions; and
- F. Enforceable and approved by the commissioner in writing after the submission to the commissioner of documents satisfactory to the commissioner or incorporated into a permit as a restriction on emissions.

The Project is required to hold 233.6 ERCs to offset the 194.7 tons per year of NO_X emissions from the Project in accordance with the requirements of 22a-174-3a(I)(5). As noted in the current permit (Permit #144-0011), the Project currently holds 177 ERCs; therefore, the Project will require an additional 56.6 NO_X ERCs.

The additional NO_X ERCs will be created prior to the date the Project becomes operational, and will come from an area in Connecticut or New York that is designated as an equal or higher nonattainment classification than the Project area. Prior to operation of the Project, CPV Towantic will provide documentation to DEEP that it has acquired the additional ERCs, along with the documentation necessary to verify that the additional 56.6 ERCs meet all of the requirements of RCSA section 22a-174-3a(I)(5).

ATTACHMENT K – OPERATION AND MAINTENANCE PLAN

Since DEEP has not requested an Operation and Maintenance Plan, and no other permit or order requires it, Attachment K is not required.



ATTACHMENT L - AMBIENT AIR QUALITY ANALYSIS

Provided on the following pages is a completed Ambient Air Quality Analysis, consistent with RCSA sections 22a-174-3a(d)(3)(B) & (C).

This attachment includes information cross-referenced in prior attachments, including:

- Attachment 216-D: Found in Section 3.8
- Attachment 216-E: Found in Section 3.2
- Attachment 216-F: Found in Section 3.8
- Attachment 216-G: Found in Section 4.2 and 4.3
- Attachment 216-H: Found in Section 4.4
- Attachment 215-C: Found in Section 4.4



Ambient Air Quality Analysis

CPV Towantic Energy Center

September 2014



Prepared for:

CPV Towantic, LLC

50 Braintree Hill Office Park, Suite 300 Braintree, MA 02184

Prepared by:

Tetra Tech, Inc.

238 Littleton Road, Suite 201B Westford, MA 01886



TABLE OF CONTENTS

1.0	INTI	RODUCTION	L-1
2.0	PRO	JECT DESCRIPTION	L-2
2.	.1	Site Location	L-2
2.	2	Facility Description	L-2
2.	.3	Ambient Air Quality Regulatory Criteria	L-3
	2.3.	National Ambient Air Quality Standards	L-3
	2.3.	2 Prevention of Significant Deterioration Review	L-4
3.0	AIR	QUALITY IMPACT ASSESSMENT	L-7
3.	.1	Introduction	L-7
3.	2	Source Data and Operating Scenarios [Attachment 216-E]	L-8
3.	.3	Model Selection	L-10
3.	4	Meteorological Data	L-10
3.	.5	Land Use	L-11
3.	6	Good Engineering Practice Stack Height Analysis	L-11
3.	7	Receptor Grid and AERMAP Processing	L-12
3.	8	Ambient Background Data [Attachment 216-D AND 216-F]	L-12
3.	.9	PM _{2.5} Assessment	L-13
3.	10	Modeling Analysis and Significant Impact Area (SIA) Determination	L-14
3.	.11	Cumulative Impact Modeling	L-16
3.	12	PSD Increment Consumption Analysis	L-17
4.0	EVA	LUATION OF ADDITIONAL IMPACTS	L-18
4.	.1	Class I Area Air Quality Related Values	L-18
4.	2	Visibility [Attachment 216-G]	L-18
4.	.3	Soils and Vegetation [Attachment 216-G]	L-18
	4.3.	1 Vegetation Assessment	L-19
	4.3.	Soil Assessment	L-19
4.	4	Growth [Attachment 216-H and 215-C]	L-20
5.0	REF	ERENCES	L-22
LIS	ГОБ	TABLES	
Table	L-1. N	ational Ambient Air Quality Standards	L-5
Table	L-2. P	SD Regulatory Threshold Evaluation	L-6

Table L-3. SILs, NAAQS, and PSD Increments	. L-7
Table L-4. Stack Characteristics	. L-8
Table L-5. Load Scenarios and Emission Rates for a General Electric (GE) 7HA.01 Combustion Turbine Firing Natural Gas (per unit)	
Table L-6. Load Scenarios and Emission Rates for a GE 7HA.01 Combustion Turbine Firing ULSD (per unit)	. L-9
Table L-7. Startup Condition Stack Parameters for Each FuelL	10
Table L-8. Stack Parameters for Ancillary EquipmentL	10
Table L-9. Ambient Air Quality Monitoring Data and Selected Background ConcentrationsL	13
Table L-10. Maximum Predicted Impact ConcentrationsL	15
Table L-11. Cumulative NAAQS Compliance AssessmentL	17
Table L-12. Cumulative PSD Increment Compliance AssessmentL	17
Table L-13. Vegetation Impact Screening Thresholds AssessmentL	19

APPENDICES

Figures

- Figure L-1: Wind Rose Plot
- Figure L-2: Urban/Rural Land Use Determination Map
- Appendix L-A: Detailed Source Parameter Data
- Appendix L-B: Facility Layout Diagrams and BPIP Data
- Appendix L-C: Detailed AERMOD Results Summary
- Appendix L-D: Background Inventory Source Data
- Appendix L-E: VISCREEN Analysis
- Appendix L-F: Detailed Calculations for Impacts to Soils and Vegetation

ACRONYMS/ABBREVIATIONS

Acronyms/Abbreviations	Definition	
°F	degrees Farenheit	
μg/m ³	micrograms per cubic meter	
ACC	air-cooled condenser	
AERMOD	USEPA-approved steady-state air quality dispersion model	
AQRV	Air Quality Related Value	
BPIP	Building Profile Input Program	
CEMS	continuous emissions monitoring system	
CO	carbon monoxide	
CO ₂	carbon dioxide	
CO _{2e}	carbon dioxide equivalent	
CPV	CPV Towantic, LLC	
CTG	combustion turbine generator	
DEEP	Connecticut Department of Energy and Environmental Protection	
FLAG	Federal Land Managers' Air Quality Related Values Work Group	
FLM	Federal Land Manager	
g/s	grams per second	
GE	General Electric	
GEP	good engineering practice	
GHG	greenhouse gases	
H1H	highest first highest	
HRSG	heat recovery steam generator	
K	Kelvin	
km	kilometers	
kV	kilovolt	
kW	kilowatt	
MASC	maximum allowable stack concentration	
m/s	meters per second	
MMBtu/hr	million British thermal units per hour	
msl	mean sea level	
MW	megawatt	
NAAQS	National Ambient Air Quality Standards	
NAD83	North American Datum of 1983	
NH ₃	ammonia	

Acronyms/Abbreviations	Definition	
NNSR	Nonattainment New Source Review	
NO ₂	nitrogen dioxide	
NO_x	nitrogen oxides	
NPS	National Park Service	
NSR	New Source Review	
O ₃	ozone	
Pb	lead	
PM	particulate matter	
PM ₁₀	particulate matter with an aerodynamic diameter of 10 micrometers or less	
PM _{2.5}	particulate matter with an aerodynamic diameter of 2.5 micrometers or less	
ppm	parts per million	
ppmw	parts per million weight	
Project A nominal 805-MW natural gas-fired, combined-cycle generating facility Woodruff Hill Road in Oxford, Connecticut		
PSD	Prevention of Significant Deterioration	
SCR	selective catalytic reduction	
SIA	Significant Impact Area	
SILs	Significant Impact Levels	
SO ₂	sulfur dioxide	
STG	steam turbine generator	
tpy	tons per year	
ULSD	ultra-low sulfur distillate	
USEPA	United States Environmental Protection Agency	
USFS	United States Forest Service	
USFWS	United States Fish and Wildlife Service	
USGS	United States Geological Survey	
UTM	Universal Transverse Mercator	
VISCREEN	USEPA-approved plume visibility model	
VOC	volatile organic compounds	

1.0 INTRODUCTION

CPV Towantic, LLC (CPV) proposes to construct and operate a nominal 805-megawatt (MW) combined-cycle electric generating facility at a site located on Woodruff Hill Road in Oxford, Connecticut (the Project). The United States Geological Survey (USGS) map provided in Attachment D of this application, illustrates the general location of the Project. Construction of the proposed Project is scheduled to begin in December 2015 and continue for a period of approximately 30 months. Commercial operation is expected to commence in June 2018.

The proposed Project will include two combustion turbine generators (CTGs), each with an independent supplementary-fired heat recovery steam generator (HRSG), an auxiliary boiler, an emergency diesel generator, and a fire pump diesel engine. The Project will be fired primarily with natural gas; the use of ultra-low sulfur distillate (ULSD) will be authorized for up to 30 days per year as the backup fuel. The purpose of this report is to present the air quality dispersion modeling analyses performed in support of the Prevention of Significant Deterioration (PSD) permit application to the Connecticut Department of Energy and Environmental Protection (DEEP) for criteria pollutants. The modeling analyses were conducted in accordance with the methodologies described in correspondence with the DEEP submitted on June 19, 2014.

This report consists of four sections in addition to this introduction.

- Section 2 contains a Project description, including information regarding the facility's location and the expected air pollutant emissions, along with an applicability assessment relative to key permit-related regulations.
- Section 3 presents a detailed description of the modeling analyses undertaken to evaluate the air quality impacts of the proposed Project, including: model selection criteria; good engineering practice (GEP) stack height determination and building dimensions for model input; meteorological data; refined modeling analyses; and the ambient air quality compliance assessment, along with the modeling results.
- Section 4 discusses additional PSD analyses such as Class I Area Air Quality Related Values (AQRVs), visibility, growth, and impacts to vegetation and soils.
- Section 5 provides the references that were used in preparing this report.

The appendices include detailed source parameter data and supporting vendor data, a description of the facility building layout and Building Profile Input Program (BPIP) analysis results, detailed AERMOD results data, background inventory source data, VISCREEN results, and detailed soils and vegetation analysis data.

The modeling analyses demonstrate that the Project is in compliance with all applicable ambient air quality standards and PSD increments.

2.0 PROJECT DESCRIPTION

The equipment layout and exact location of the facility is illustrated in the Site Plan and USGS map provided in Attachments C and D of this application, respectively.

2.1 SITE LOCATION

The proposed Project will be constructed on a 26-acre parcel at a greenfield location in Oxford, Connecticut. The site is located in western New Haven County, approximately 3 miles southwest of Naugatuck, Connecticut, approximately 5 miles southwest of Waterbury, Connecticut, approximately 0.5 mile east of the Waterbury-Oxford Airport, and approximately 2 miles south of Interstate 84. The site will have a graded elevation of 830 feet above mean sea level (msl) elevation. The nearest terrain with elevations reaching stack-top height (980 feet msl) is located approximately 12 miles north-northwest of the proposed facility stack location.

2.2 FACILITY DESCRIPTION

The proposed nominal 805 MW¹ combined-cycle electric generating facility will be configured as two operating units. The power plant will be configured in a "2-on-1" power block configuration with steam from the two HRSGs feeding a single steam turbine generator (STG). The HRSGs will be equipped with supplementary firing (duct burners) to provide additional generating capacity during periods of peak electrical demand. The facility is designed to run as a base load plant with both combustion turbines operating concurrently, but will have the capability of operating with a single combustion turbine and at part load operation.

The Project will include a variety of power plant equipment including two General Electric (GE) 7HA.01 CTGs; one STG; two HRSGs with selective catalytic reduction (SCR) and oxidation catalyst emissions control equipment; generator step-up transformers; an electrical switchyard; an ammonia (NH₃) storage tank; water tanks; and an air-cooled condenser (ACC). The Project will be fired primarily with natural gas, but will have the ability to run on back-up ULSD as necessary, for up to 720 hours per year. In addition, the Project will include other buildings for administrative and operating staff; warehousing of parts and consumables; and maintenance shops and equipment servicing.

The first stage in the generation process of a combined-cycle power plant is the operation of the CTGs. Thermal energy, in the form of hot exhaust gas, is produced in the CTGs through the combustion of fuel (natural gas or ULSD). The hot exhaust gases are then converted into mechanical energy by a turbine that drives a generator. The exhaust gas temperature exiting the CTGs is in excess of 1,000 degrees Fahrenheit (°F) and still has remaining a significant amount of recoverable heat energy. This heat energy is recovered in the HRSG by generating steam that is sent to the STG to generate additional electrical energy. The generation of electricity using both a combustion turbine and steam turbine defines the combined cycle, which is the most efficient form of electrical generation available. The efficiency of the facility is further enhanced by using reheat systems, as well as waste energy to heat feedwater in the HRSG through an additional economizer loop and also for fuel preheating. Once the steam leaves the STG, it is condensed back into water using an ACC, and this condensed water is returned to the HRSGs to minimize water use. Additional steam, and consequently additional electricity, may be generated when

¹ Based on 59°F ambient temperature, 60% relative humidity, and duct firing.



_

required by the use of supplemental natural gas-fired burners (duct burners) within the HRSGs. The CTGs will also be equipped with inlet air evaporative cooling.

Pollutant emissions from the Project will be minimized through the use of natural gas as the primary fuel to be fired in the CTGs and duct burners. Fifteen parts per million (ppm) ULSD oil will be fired as a backup fuel as necessary for up to 720 hours per year. Each HRSG will be equipped with SCR and an oxidation catalyst to reduce emissions of nitrogen oxides (NO_x), and carbon monoxide (CO) and volatile organic compounds (VOC), respectively. The SCR system will utilize 19% aqueous NH_3 as the reagent in the SCR systems. Continuous emissions monitoring systems (CEMS) will continuously sample, analyze, and record exhaust gas concentrations of NO_x , CO, and NH_3 from each of the two HRSG exhaust stacks. The CEMS will be installed and operated in accordance with United States Environmental Protection Agency (VSEPA) and VSEPA a

Ancillary equipment at the proposed Project will include three additional fuel combustion emission units:

- A 92.4-million British thermal units per hour (MMBtu/hr) natural gas-fired auxiliary boiler equipped with ultra-low NO_x burners;
- A 2,206-brake horsepower emergency generator firing ULSD oil; and
- A 315-kilowatt (kW) emergency fire pump engine firing ULSD oil.

To support the SCR systems, a 20,000-gallon aboveground storage tank will contain 19% aqueous NH₃. The tank will be located within a concrete containment structure along with the ammonia transfer pumps, valves, and piping.

The Project will interconnect with the existing 115-kilovolt (kV) transmission line that crosses the northwest portion of the site via a new switchyard. Natural gas will be delivered via a new connection to the existing pipeline located adjacent to the north of the site.

2.3 AMBIENT AIR QUALITY REGULATORY CRITERIA

The USEPA and the DEEP have promulgated regulations that establish ambient air quality standards and PSD increments. These standards and increments provide the basis for an evaluation of the potential impacts of the Project on ambient air quality.

2.3.1 National Ambient Air Quality Standards

The USEPA has developed National Ambient Air Quality Standards (NAAQS) for six air contaminants, known as criteria pollutants, for the protection of public health and welfare. These criteria pollutants are sulfur dioxide (SO₂), particulate matter,² nitrogen dioxide (NO₂), CO, ozone (O₃), and lead (Pb). The DEEP has also adopted these limits. The NAAQS have been developed for various durations of exposure. The NAAQS for short-term periods (24 hours or less) typically refer to pollutant levels that cannot be exceeded except for a limited number of cases per year. The NAAQS for long-term levels typically refer to pollutant levels that cannot be exceeded for exposures averaged typically over one year. As shown on Table L-1, the NAAQS include both "primary" and "secondary" standards. The primary

 $^{^2}$ Particulate matter (PM) is characterized according to size. PM having an effective aerodynamic diameter of 10 microns or less is referred to as PM₁₀. PM having an effective aerodynamic diameter of 2.5 microns or less is referred to as PM_{2.5}, or "fine particulate." PM_{2.5} is a subset of PM₁₀.



standards are intended to protect human health and the secondary standards are intended to protect public welfare from any known or anticipated adverse effects associated with the presence of air pollutants.

One of the basic goals of federal and state air pollution regulations is to ensure that ambient air quality, including the impact of background, existing sources, and new sources, is in compliance with ambient air quality standards. Toward this end, for each criteria pollutant, every area of the United States has been designated as one of the following categories: attainment, unclassifiable, or nonattainment, with respect to each NAAQS. In areas designated as attainment, the air quality is equal to or better than the NAAQS. These areas are under a mandate to maintain, i.e., prevent significant deterioration of, such air quality.

In areas designated as unclassifiable, there are limited air quality data, and those areas are treated as attainment areas for regulatory purposes.

In areas designated as nonattainment, the air quality is worse than the NAAQS. These areas must take actions to improve air quality and attain the NAAQS within a certain period of time.

The Project site area is presently classified as "attainment" or "attainment/unclassifiable" (combined definition) for all pollutants except O_3 , for which it is a serious nonattainment area. Thus, emissions of the pollutants SO_2 , NO_x , CO, and $PM_{10}/PM_{2.5}$ are evaluated under the PSD program.

If a new major source of air pollution is proposed, it must undergo New Source Review (NSR). There are two NSR programs: one for sources being built in attainment/unclassifiable areas, and one for sources in nonattainment areas. The NSR program for sources in attainment/unclassifiable areas is known as the PSD program. The NSR program for sources being built in nonattainment areas is known as the Nonattainment New Source Review (NNSR) program.

Major sources of the O₃ precursors, NO_x and VOC, are subject to the NNSR program, and the proposed Project is a major source of NO_x.since annual potential emissions exceed 50 tons per year (tpy)

2.3.2 Prevention of Significant Deterioration Review

The PSD Program is a federally mandated review of new major sources of criteria pollutants designed to maintain the NAAQS and prevent degradation of air quality in attainment/unclassifiable areas. Review authority for the PSD program has been delgated by the USEPA to the DEEP for all pollutants.

For PSD purposes, a combined-cycle electric generating facility is considered a major source if emissions of any one criteria pollutant are greater than 100 tpy or if emissions of greenhouse gases (GHG) expressed as carbon dioxide (CO_2) equivalent (or CO_{2e}) are greater than 100,000 tpy. As shown in Table L-2, the facility will have potential emissions greater than 100 tpy for one or more attainment criteria pollutants and potential emissions greater than 100,000 tpy of CO_{2e} . Therefore, the proposed facility will be a major PSD source. For a major PSD source, PSD regulations also apply to each criteria pollutant that is emitted in excess of a defined significant emission rate.

Table L-2 presents a PSD major source threshold analysis for the facility for those pollutants with applicable PSD emission criteria. As shown in Table L-2, the facility is subject to PSD review for PM/PM₁₀/PM_{2.5}, NO_x, CO, VOC, sulfuric acid mist, and GHGs. Since there are no NAAQS for VOC or GHGs, a modeling analysis for those pollutants is not a PSD permit application requirement; therefore, they are not addressed in this report. Sulfuric acid is treated as an air toxic; as such, a maximum allowable stack concentration analysis is included in the air permit application and is not the subject of modeling. Therefore, it is not addressed further in this report.

Table L-1. National Ambient Air Quality Standards

Pollutant	Averaging Period	NAAQS Primary Standard (µg/m³)	NAAQS Secondary Standard (μg/m³)
SO ₂	Annual ^{a, j}	80	NA
	24-Hour ^{b, j}	365	NA
	3-Hour ^b	NA	1,300
	1-hour ⁱ	196	NA
PM ₁₀	24-Hour ^d	150	150
PM _{2.5}	Annual ^e	12	15
	24-Hour ^f	35	35
СО	8-Hour ^b	10,000	NA
	1-Hour ^b	40,000	NA
O ₃	8-Hour (2008 Standard) ⁹	150	150
	8-Hour (1997 Standard) ^{9, h}	157	157
NO ₂	Annual ^a	100	100
	1-hour ^c	188	NA
Pb	Rolling 3-month ^a	0.15	0.15

a Not to be exceeded.

μg/m³ = micrograms per cubic meter

Not to be exceeded more than once per year.

^c Compliance based on 3-year average of the 98th percentile of the daily maximum 1-hour average at each monitor within an area.

Not to be exceeded more than once per year on average over 3 years.

^e Compliance based on 3-year average of weighted annual mean PM_{2.5} concentrations at community-oriented monitors.

Compliance based on 3-year average of 98th percentile of 24-hour concentrations at each population-oriented monitor within an area.

Gompliance based on 3-year average of fourth-highest daily maximum 8-hour average O₃ concentrations measured at each monitor within an area.

The 1997 8-hour O₃ standard and associated implementation rules remain in place as the transition to the 2008 standard occurs.

Compliance based on 3-year average of 99th percentile of the daily maximum 1-hour average at each monitor within an area.

The 24-hour and annual average primary standards for SO₂ will remain in effect until one year after the effective date of the 1-hour SO₂ designations.

Table L-2. PSD Regulatory Threshold Evaluation

Pollutant	Project Annual Emissions (tons)	PSD Major Source Threshold (tons)	PSD Significant Emission Rate (tons)	PSD Review Applies
СО	136.4	100	100	Yes
NO _x	196.2	100	40	Yes
SO ₂	39.7	100	40	No
PM	154.7	100	25	Yes
PM ₁₀	154.7	100	15	Yes
PM _{2.5}	154.7	100	10	Yes
VOC	49.9	100	40	Yes
Pb	0.034	100	0.6	No
Sulfuric Acid Mist	25.3	100	7	Yes
GHGs (as CO _{2e})	2,678,612	100,000	75,000	Yes

3.0 AIR QUALITY IMPACT ASSESSMENT

3.1 INTRODUCTION

The dispersion modeling analyses for the Project have been conducted in accordance with USEPA (2005) and DEEP (2009) guidance, as well as the detailed methodology description submitted by email to the DEEP on June 19, 2014.

As described in Section 2.3.2, the Project will be a major source subject to PSD regulations for CO_{2e} , CO, NO_X , PM, PM_{10} , $PM_{2.5}$, VOC and sulfuric acid mist. Dispersion modeling has been conducted for CO, NO_2 , PM, PM_{10} , and $PM_{2.5}$ to demonstrate compliance with the NAAQS and PSD increments; for completeness, SO_2 has also been modeled.

The dispersion modeling for this Project has been conducted with the EPA and DEEP recommended AERMOD dispersion model, in a manner that evaluates worst-case operating conditions in an effort to predict the highest impact for each pollutant and averaging period. Maximum predicted impacts from the worst-case scenarios are compared to the Significant Impact Levels (SILs). If maximum predicted impacts are below the corresponding SILs, then compliance is demonstrated and no additional analysis is necessary. However, if predicted impacts are greater than the SILs, a cumulative impact analysis has been conducted with other major emission sources in the area, as identified by the DEEP (with DEEP's Radius Search Tool and subsequent correspondence with DEEP). The results of the cumulative modeling are compared to the NAAQS, and PSD increments. Table L-3 provides the SILs, NAAQS and PSD increments along with the modeling rank basis used for assessment of the various thresholds. All electronic modeling files have been provided to the DEEP.

Table L-3. SILs, NAAQS, and PSD Increments

Pollutant	Averaging Period	Rank for SIL Assessment	SIL (µg/m³)	NAAQS (μg/m³)	PSD Class II Increment (µg/m³)	Rank for NAAQS/PSD Assessment
NO ₂	1-hour	H1H ¹ (5-year Average)	7.5	188	NA	H8H (5-year Average)
	Annual	H1H	1	100	25	H1H
СО	1-hour	H1H	2,000	40,000	NA	H2H
CO	8-hour	H1H	500	10,000	NA	H2H
PM ₁₀	24-hour	H1H	5	150	30	Н6Н
PIVI ₁₀	Annual	HH	1	NA	17	H1H
PM _{2.5}	24-hour	H1H (5-year Average)	1.2	35	NA	H8H (5-year Average)
(NAAQS))	Annual	H1H (5-year Average)	0.3	12	NA	H1H (5-year Average)
PM _{2.5}	24-hour	H1H	1.2	NA	9	H2H
(PSD)	Annual	H1H	0.3	NA	4	H1H
	1-hour	H1H (5-year Average)	7.8	196	NA	H4H (5-year Average)
SO ₂	3-hour	H1H	25	1,300	512	H2H
	24-hour	H1H	5	365	91	H2H
	Annual	H1H	1	80	20	H1H
¹ H1H =	highest first high	hest, H2H = highest	second highest,	etc.		

L-7

The PM_{2.5} SILs were vacated on January 22, 2013 by the United States Court of Appeals for the District of Columbia Circuit (Sierra Club v. USEPA). However, as will be discussed in Section 3.8, existing ambient monitoring data representative of ambient background for the Project area indicate that there is sufficient margin between the ambient background levels and the NAAQS to allow use of the PM25 SILs as a demonstration of compliance with the NAAQS. The SIL is only approximately 10% of this margin. Predicted Project impacts below the SILs would ensure protection of the NAAQS and, therefore, the PM_{2.5} SILs are proposed to be used for this analysis.

3.2 SOURCE DATA AND OPERATING SCENARIOS [ATTACHMENT 216-E]

The modeling analyses for the Project include the combustion turbine units, the emergency diesel generator, the fire pump diesel engine, and the auxiliary boiler. Air quality dispersion modeling has been conducted for a range of operating scenarios to capture worst-case potential impact concentrations from the combustion turbine units. Table L-4 summarizes stack characteristics for the combustion turbine stacks and ancillary sources.

Tables L-5 and L-6 provide emission rates and stack parameters that bracket the full range of normal operating loads for natural gas-fired and oil-fired conditions, respectively.

Table L-7 provides worst-case emission rates and stack parameters under startup conditions. The start-up parameters are based on worst-case emissions and stack parameters considering the hot start, warm start, and cold start-up conditions, as well as shutdown conditions.

Table L-8 provides the stack parameters for the emergency diesel generator, fire pump engine, and the auxiliary boiler.

The turbines were first modeled alone to determine worst-case load conditions for each pollutant and averaging period. The turbines under worst-case load conditions were then modeled in combination with the ancillary units to determine total Project impacts. Note that the auxiliary boiler will not operate simultaneously with the combustion turbines except during brief periods when operation overlaps with a single turbine startup. The emergency generator and fire pump engines will operate for emergencies and for testing, which will normally

consist of operation one time per week for up to one hour. Table L-4. Stack Characteristics

Parameter	Combustion Turbine Stacks	Emergency Generator Stack	Fire Pump Engine Stack	Auxiliary Boiler
Base Elevation, msl (feet/meters)	830/252.98	830/252.98	830/252.98	830/252.98
Stack Height (feet/meters)	150/45.72	14.5/4.42	17.5/5.33	62/18.9
Inside Stack Diameter (feet/meters)	22/6.71	1.2/0.37	0.7/0.21	4.0/1.22
Number of Stacks	2	1	1	1
Stack Location: UTM ^a -E (m), UTM-N(m) (in NAD83, zone 14)	1) 656815.8, 4594161.2 2) 656775.3, 4594151.0	656729.2, 4594234.2	656748.5, 4594146.3	656687.5, 4594203.9
^a UTM – Universal Transverse Mere	cator			

Table L-5. Load Scenarios and Emission Rates for a General Electric (GE) 7HA.01 Combustion Turbine Firing Natural Gas (per unit)

			GE Design Cases																	
Parameter	Units	#1	#2	#3	#4	#28	#29	#35	#9	#31	#32	#11	#36	#13	#14	#16	#17	#23	#24	#22
Ambient Temperature	°F	-14.2°F	-14.2°F	-14.2°F	-14.2°F	-14.2°F	-14.2°F	59°F	59°F	59°F	59°F	59°F	90°F	90°F	100°F	100°F	100°F	100°F	100°F	100°F
CTGs Operating		2	2	1	2	2	2	2	2	2	2	2	2	2	2	1	2	2	2	2
Percent Load Rate	%	100%	100%	100%	100%	75%	50%	100%	100%	75%	50%	30%	100%	100%	100%	100%	100%	75%	50%	41%
Duct Burner Operation		Fired	Fired	Fired	Unfired	Unfired	Unfired	Fired	Unfired	Unfired	Unfired	Unfired	Fired	Unfired	Fired	Fired	Unfired	Unfired	Unfired	Unfired
Stack Temperature	Kelvin (K)	356.4	360.3	349.8	364.5	360.7	355.6	352.2	357.2	355.5	354.8	349.8	359.1	364.4	364.9	349.8	368.0	364.9	360.9	357.0
Stack Exit Velocity	m/s	18.42	18.59	18.30	18.78	14.94	11.81	16.94	17.13	14.04	11.53	8.86	15.93	16.64	16.68	16.15	16.77	13.43	10.88	9.56
NO _x Emission Rate	g/s	2.633	2.533	3.377	2.444	1.953	1.512	2.495	2.318	1.827	1.399	1.058	2.318	2.192	2.369	2.936	2.192	1.613	1.246	1.115
CO Emission Rate	g/s	1.361	1.310	1.739	0.669	0.534	0.413	1.251	0.634	0.501	0.383	0.290	1.197	0.602	1.229	1.512	0.600	0.440	0.341	0.305
SO ₂ Emission Rate	g/s	0.611	0.588	0.782	0.565	0.458	0.354	0.585	0.543	0.431	0.328	0.249	0.543	0.516	0.556	0.686	0.514	0.378	0.293	0.262
PM ₁₀ /PM _{2.5} Emission Rate	g/s	2.52	2.457	2.570	1.226	1.158	1.104	2.558	1.215	1.144	1.090	1.050	2.407	1.201	2.533	2.268	1.200	1.116	1.072	1.056

Table L-6. Load Scenarios and Emission Rates for a GE 7HA.01 Combustion Turbine Firing ULSD (per unit)

		GE Design Cases											
Parameter	Units	#37	#46	#47	#38	#41	#52	#53	#42	#43	#44	#51	#45
Ambient Temperature	°F	-14.2°F	-14.2°F	-14.2°F	-14.2°F	59°F	59°F	59°F	90°F	100°F	100°F	100°F	100°F
CTGs Operating		2	1	2	2	2	2	2	2	2	1	2	2
Percent Load Rate	%	100%	100%	75%	50%	100%	75%	50%	100%	100%	100%	75%	50%
Duct Burner Operation		Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired
Stack Temperature	К	424.4	417.9	411.1	405.5	419.0	406.7	404.5	417.5	423.2	409.5	410.4	411.1
Stack Exit Velocity	m/s	21.82	21.41	16.91	13.40	20.98	16.00	12.24	19.76	19.95	18.09	14.46	11.49
NO _x Emission Rate	g/s	6.552	5.859	5.254	4.032	6.199	4.901	3.780	5.771	5.746	5.368	4.322	3.352
CO Emission Rate	g/s	1.600	1.424	1.273	0.982	1.512	1.194	0.921	1.411	1.399	1.310	1.051	0.816
SO ₂ Emission Rate	g/s	0.620	0.620	0.497	0.383	0.587	0.464	0.358	0.547	0.544	0.508	0.408	0.318
PM ₁₀ /PM _{2.5} Emission Rate	g/s	5.368	5.368	5.292	5.242	5.342	5.279	5.229	5.330	5.317	5.305	5.254	5.204



Table L-7. Startup Condition Stack Parameters for Each Fuel

Operating Load Case	Natural Gas	ULSD
Stack Exhaust Velocity (m/s)	7.67	10.30
Stack Exhaust Temperature (K)	344.1	344.1
CO (g/s)	30.49	29.106
NO _x (g/s)	0.33	0.37
SO ₂ (g/s)	0.33	0.36

Note: The startup parameters presented and evaluated with modeling are the worst-case emissions and flows over range of hot, warm, and cold start, and shutdown conditions. Startup conditions were considered for pollutants and averaging periods of 8 hours or less. Consistent with USEPA guidance for intermittent conditions, the NO_X emission rates are annualized for 250 starts per turbine per year.

Table L-8. Stack Parameters for Ancillary Equipment

Parameter	Emergency Diesel Generator	Fire Pump Engine	Auxiliary Boiler
Stack Exhaust Velocity (m/s)	51.82	27.30	7.91
Stack Exhaust Temperature (K)	891.8	789.3	399.8
Short Term Emission Rates:			
CO (g/s)	0.2696	0.0788	0.4304
NO _x (g/s)	2.5001	0.3325	0.1272
PM / PM ₁₀ / PM _{2.5} (g/s)	0.0184	0.0114	0.0815
SO ₂ (g/s)	0.0027	0.0005	0.0175
Annual Emission Rates:			
CO (g/s)	0.0092	0.0027	0.1965
NO _x (g/s)	0.0856	0.0114	0.0581
PM / PM ₁₀ / PM _{2.5} (g/s)	6.296e 10 ⁻⁴	3.90e 10 ⁻⁴	0.0372
SO ₂ (g/s)	9.25e 10 ⁻⁵	1.58e 10 ⁻⁵	0.0008

Note: Annual emission rates based 4,000 hours per year operation for the auxiliary boiler and 300 hours per year for the diesel generator and fire pump engines.

3.3 MODEL SELECTION

The USEPA-recommended AERMOD modeling system (USEPA 2004) has been used to conduct the dispersion modeling. The most current versions of the model have been used (AERMOD version 14134, AERMAP version 11103).

3.4 METEOROLOGICAL DATA

The modeling has been conducted using five years (2008-2012) of meteorological data collected, processed and provided by the DEEP. The surface data are from the Danbury Municipal Airport in Danbury, Connecticut and the

corresponding upper air data are from Albany, New York. The surface station is located approximately 32.5 kilometers (km) (20.3 miles) west-southwest from the Project site. It is representative of the Project site area because of its relatively close proximity and similar distance from the coastline. A windrose plot describing the wind speed and wind wind direction frequency distribution for this data is provided in Figure L-1.

3.5 LAND USE

A land-use determination has been made following the classification technique suggested by Auer (Auer 1978) in accordance with USEPA/DEEP modeling guidance. The classification technique was conducted to determine the predominant land use (urban versus rural) in the area for the dispersion characteristics, by assessing land-use categories within a 3-km radius of the proposed site. Figure L-2 provides an aerial view of the 3-km radius around the proposed Project site. Inspection of this aerial photo, other maps, and on-site inspection, indicates that the large majority of the area is characterized as rural. Therefore, rural dispersion coefficients have been used for the air quality modeling.

3.6 GOOD ENGINEERING PRACTICE STACK HEIGHT ANALYSIS

Good Engineering Practice (GEP) stack height is defined as "the height necessary to ensure that emissions from the stack do not results in excessive concentrations of any air pollutant in the immediate vicinity of the source as a result of atmospheric downwash, eddies or wakes which may be created by the source itself, nearby structures, or nearby terrain obstacles." A GEP stack height analysis has been performed based on the facility structures to determine the potential for building-induced aerodynamic downwash for the proposed stacks. The analysis procedures described in USEPA's Guidelines for Determination of Good Engineering Practice Stack Height (USEPA 1985) and DEEP guidance have been used.

The GEP formula height is based on the observed phenomena of disturbed atmospheric flow in the immediate vicinity of a structure resulting in higher ground-level concentrations at a closer proximity to the building than would otherwise occur. It identifies the minimum stack height at which significant aerodynamic downwash is avoided. The GEP formula stack height, as defined in the 1985 guidelines, is calculated as follows:

$$H_{GEP} = H_{BLDG} + 1.5L$$

Where:

- $\bullet \quad \ \ \, H_{GEP} \ is \ the \ calculated \ GEP \ formula \ height;$
- H_{BLDG} is the height of the nearby structure; and
- L is the lesser dimension (height or projected width) of the nearby structure.

Both the height and width of the structure are determined from the frontal area of the structure projected onto the plane perpendicular to the direction of the wind. The GEP stack height is based on the plane projected from any structure that results in the greatest calculated height. For the purpose of the GEP analysis, nearby refers to the "sphere of influence" defined as 5 times L (the lesser dimension [height or projected width] of the nearby structure), downwind from the trailing edge of the structure.

In order to limit visual impact and due to proximity to the Waterbury Oxford airport, the stack heights for the Project will be limited to 150 feet, which is less than the GEP height. Therefore, the USEPA's BPIP (Dated: 04274) version that is appropriate for use with the PRIME algorithms in AERMOD was used to evaluate downwash effects in the model. The building dimensions and coordinates for each potentially influencing structure were input in BPIPPRM program to determine direction-specific building data. The PRIME algorithms calculate the entire configuration of the structure's wake from the cavity immediately downwind of the structure to the far wake. Schematic diagrams, which describe the site building configuration along with the BPIP input and output data, are provided in Appendix L-B.

3.7 RECEPTOR GRID AND AERMAP PROCESSING

Discrete receptors were placed at 25-meter intervals along the facility fence line. In addition, a nested Cartesian grid was extended out from the fence line at the following receptor intervals and distances:

- At 25-meter intervals from the fence line to 300 meters;
- At 100-meter intervals from the 300 meters to 2,000 meters;
- At 500-meter intervals from 2,000 to 5,000 meters;
- At 1,000-meter intervals from 5,000 to 10,000 meters; and
- At 2,000-meter intervals from 10,000 to 20,000 meters.

Terrain elevations at receptors were determined using BEE-Line Software's BEEST program and USGS digital terrain data. BEEST implements the AERMAP model, which includes processing routines that extract National Elevation Data at 10-meter spacing based on North American Datum of 1983 (NAD83). The four nearest data points surrounding each receptor have been used to determine receptor terrain elevations (by interpolation) for air quality model input.

For any cases where the maximum model concentrations were predicted beyond the dense (100-meter intervals) portion of the grid, and the predicted concentration exceeded 75% of the applicable standard, supplemental receptors were placed around the initial maximum location (at the next lower grid spacing interval) to ensure higher concentrations were not overlooked.

3.8 AMBIENT BACKGROUND DATA [ATTACHMENT 216-D AND 216-F]

As previously stated, if AERMOD-predicted maximum-impact concentrations are significant (above SILs), multi-source modeling has been conducted. In the multi-source modeling analysis, representative ambient air quality background concentrations are added to modeled concentrations from the cumulative modeling to compare against the NAAQS. Representative ambient air quality data and the selected background concentrations that were used in the compliance assessment are provided in Table L-9.

DEEP monitoring data were reviewed to identify representative monitoring sites and determine ambient background concentrations for the Project area. The monitoring site selections considered proximately to the Project area, and similarity of the monitoring site environment to the relatively rural Project site area.

In general, the monitors located closest to the facility were used to establish existing background levels. The ambient data for CO and SO_2 come from the Criscuolo Park monitor located in New Haven. New Haven is an industrialized area and the monitor is located about 1 km away from a major highway (I-95). Therefore, the data from the monitoring site are conservatively representative of ambient background concentrations for the relatively rural project site area. The ambient data for $PM_{10}/PM_{2.5}$ come from the Meadow and Bank Street monitor located in Waterbury. This monitoring site is urban/residential in character and is located just 170 meters south of a major highway (I-84). Therefore, the data from the monitoring site are conservatively representative of ambient background concentrations for the relatively rural project site area. The ambient data for NO_2 come from the McAuliffe Park monitor located in East Hartford. This monitoring site is suburban/residential in character and is located just 120 meters east of Route 5, 2.0 km east of I-91, and 2.5 km south of I-291. Therefore, the data from the monitoring site are conservatively representative of ambient background concentrations for the relatively rural project site area. For these reasons, the ambient monitoring data presented in Table L-9 are representative of the Project site area ambient background.

84

29

Averaging Pollutant Monitor Rank Concentration **Period** $(\mu g/m^3)$ 2nd high CO 1-hour Α 1725 2nd high 8-hour Α 1380 98th percentile NO_2 1-hour В 87 В 21 Annual Mean 98th percentile С $PM_{2.5}$ 24-hour 24 С Annual Mean 9.2 2nd high С 40 PM_{10} 24-hour 99th percentile SO₂1-hour Α 87 2nd high Α 92 3-hour

2nd high

Mean

Α

Α

Table L-9. Ambient Air Quality Monitoring Data and Selected Background Concentrations

Monitor Key:

24-hour

Annual

3.9 POTENTIAL SECONDARY PM_{2.5} FORMATION ASSESSMENT

The analysis of $PM_{2.5}$ impacts is consistent with recent USEPA guidance on $PM_{2.5}$ permit modeling (USEPA 2013). Since the Project has an annual potential-to-emit of direct $PM_{2.5}$ and NO_x both greater than their respective significant emission rate thresholds, air quality impacts from both primary and secondary $PM_{2.5}$ emissions must be assessed. Impacts of primary $PM_{2.5}$ emissions have been determined with dispersion modeling using AERMOD. The guidance indicates that the Project falls in the Case 3 Assessment category, where secondary $PM_{2.5}$ can be assessed by either a qualitative, hybrid qualitative/quantitative, or full quantitative approach.

Since no suitable existing photochemical modeling study has been identified to use for a hybrid $PM_{2.5}$ assessment, a qualitative assessment has been used to assess potential secondary $PM_{2.5}$ impacts for the Project. The qualitative approach is analogous to the example qualitative approach described in the recent draft $PM_{2.5}$ guidance. Specific details are summarized below:

- 1. Model-predicted impacts indicate primary PM_{2.5} impacts will be located very close to the Project (either at the facility fence line or within a few 100 meters of the fence). Secondary PM_{2.5} impacts are expected to be very low (negligible) near where-model predicted primary PM_{2.5} impacts are highest, because there is not enough time for secondary chemical reactions to occur. Conversely, what limited secondary PM_{2.5} emissions may form will occur far from the Project site and where the primary PM_{2.5} impacts will be lowest. This makes it highly unlikely that maximum PM_{2.5} primary and secondary impacts will occur at the same time and place.
- There will be a relatively small amount of precursor emissions from the Project when compared to the
 existing source emissions in the region, especially for SO₂ where Project emissions are less than the
 significant emission rate threshold.

A = Criscuolo Park, New Haven, CT (ID# 09-009-0027)

B = McAuliffe Park, East Hartford, CT (ID# 09-009-1003)

C = Meadow and Bank Streets, Waterbury, CT (ID# 09-009-2123)

- 3. The ambient background PM_{2.5} monitoring data are quality assured and account for secondary PM_{2.5} from regional emission sources. There is no indication that secondary formation of PM_{2.5} from existing regional sources is causing or contributing to a violation of the NAAQS.
- 4. DEEP's Mohawk Mt. monitor (USEPA AIRS monitor 09-005-0005) located in Litchfield County could also be considered a representative monitor for PM_{2.5} ambient background data and this monitor has PM_{2.5} speciation data available. These speciated PM_{2.5} data were reviewed and it was determined that, over the last three-year period (2011-2013), the fraction of total nitrate to total PM_{2.5} is just 8.8% on an average annual basis. Given that the proposed NO_x emissions for the Project are a small fraction of the NO_x emissions in the airshed, and that the ambient monitoring data show relatively small fractions of nitrates, secondary PM_{2.5} formation from the proposed NO_x emissions would be expected to be considerably smaller than the monitored concentration of nitrates. The monitoring information supports the conclusion that the secondary PM_{2.5} formation will be negligible and would not be expected to cause a NAAQS or PSD increment exceedance.

For the reasons stated above, it is believed that detailed quantification of secondary $PM_{2.5}$ is not needed in order to determine that emissions of $PM_{2.5}$ precursors from the Project, together with emissions of primary $PM_{2.5}$, will not cause or contribute to violations of the $PM_{2.5}$ NAAQS.

3.10 MODELING ANALYSIS AND SIGNIFICANT IMPACT AREA (SIA) DETERMINATION

The modeling analysis has been conducted using AERMOD along with the set of representative meteorological data as described in Section 3.4. The analysis was conducted to demonstrate compliance with the NAAQS and PSD increments. If maximum impacts from the Project's criteria pollutant emissions are predicted to exceed their associated SILs shown in Table L-3, a refined cumulative modeling analysis with additional major sources was conducted to determine compliance with the NAAQS and PSD increments. The full range of turbine operating conditions described in Table L-5 through Table L-7 was evaluated to determine worst-case loads (highest impact concentrations) for each pollutant and averaging period. Detailed results of this analysis are provided in Appendix L-C.

The turbines under worst-case load conditions were then modeled along with the other Project emissions sources (engines and auxiliary boiler) to determine total Project impacts. Note that the auxiliary boiler will not operate simultaneously with the turbines, except for brief periods during turbine startup. The case of a turbine in startup mode along with the auxiliary boiler operating and the case of the turbine in startup along with the second turbine in normal operation have been assessed with modeling. Operation of the turbines simultaneously with the diesel generator and fire pump engine has also been assessed. Annualized emission rates corresponding with 300 hours per year operation for the diesel engines were used for assessment with annual standards. The emergency diesel and fire pump engines will typically only operate for testing one hour per week. Turbine startup conditions will be less than one hour in duration and be limited to 250 per turbine per year, but are expected to occur much less frequently.

Consistent with USEPA guidance for intermittent sources, the engines were excluded from the analysis for the statistically based 1-hour NO_2 and 1-hour SO_2 standards. Also consistent with USEPA guidance, NO_x emissions for the intermittent startup conditions were annualized based on 250 hours per year operation, which corresponds to a maximum of 250 starts per turbine per year.

The AERMOD results for the Project are summarized in Table L-10. Detailed results for the analysis are also provided in Appendix L-C. As shown in Table L-10, maximum predicted impact concentrations are less than SILs for all pollutants except 1-hour and annual NO₂, and 24-hour PM_{2.5}. Compliance with NAAQS and PSD increments is demonstrated for pollutants with predicted insignificant (less than SIL) impacts, therefore, no additional modeling for these pollutants is necessary.

Table L-10. Maximum Predicted Impact Concentrations

Pollutant	Averaging Period	Rank Basis for SIL Assessment	Impact Concentration (µg/m³)	SIL (µg/m³)	Extent of SIA (km)	NAAQS (μg/m³)	PSD Class II Increment (μg/m³)
NO ₂	1-hour	H1H (5-year Average)	12.9	7.5	0.82	188	NA
	Annual	H1H	1.4	1	0.45	100	25
СО	1-hour	H1H	301.9	2000	NA	40,000	NA
	8-hour	H1H	176.3	500	NA	10,000	NA
PM ₁₀	24-hour	H1H	4.2	5	NA	150	30
	Annual	H1H	0.290	1	NA	NA	17
PM _{2.5}	24-hour	H1H (5-year Average)	3.5	1.2	1.58	35	NA
(NAAQS)	Annual	H1H (5-year Average)	0.21	0.3	NA	12	NA
PM _{2.5}	24-hour	H1H	4.2	1.2	3.09	NA	9
(PSD)	Annual	H1H	0.290	0.3	NA	NA	4
SO ₂	1-hour	H1H (5-year Average)	2.7	7.8	NA	196	NA
	3-hour	H1H	1.4	25	NA	1300	512
	24-hour	H1H	0.5	5	NA	365	91
	Annual	H1H	0.03	1	NA	80	20

Notes:

Maximum highest first highest (H1H) concentrations are used for comparison with the SILs. Impact concentrations are based on maximum predicted across the range of 5 years modeled for all pollutants except $PM_{2.5}$ (both annual and 24-hour), NO_2 (1-hour only), and SO_2 (1-hour only), which are based on the maximum 5-year average H1H values. NO_2 concentrations conservatively assume 100% NO_x to NO_2 conversion. $PM_{2.5}$ SIL assessment relative to PSD increment compliance is based on H1H concentrations prediction over the range of 5 years modeled, rather than the 5-year average concentrations that are used for the NAAQS assessment.

Cumulative modeling has been conducted for pollutants with Project impacts that exceed their respective SILs to demonstrate compliance with the NAAQS and PSD increments. Cumulative modeling for 1-hour and annual NO₂, and 24-hour PM_{2.5} is described in Section 3.11. Note that there is no PSD increment for 1-hour NO₂, so no increment assessment is necessary for this averaging period.

3.11 CUMULATIVE IMPACT MODELING

As described in Section 3.10, maximum predicted impact concentrations for 1-hour and annual NO_2 , and 24-hour $PM_{2.5}$ exceed their respective SILs. Therefore, a cumulative modeling analysis including other regional emissions sources and existing ambient background concentrations has been conducted. The source inventory was based on the DEEP Radius Search Tool for 2008 Air Emissions Inventory Data, provided by DEEP. The Radius Search Tool was used to develop an inventory of sources located within 50 km of the project. DEEP guidance, based on distance and actual annual emissions levels, was used to select from the inventory the specific sources to be included in the cumulative modeling assessment.

Only one NO_X source met the DEEP criteria for inclusion in the cumulative NO_2 NAAQS analysis. Three additional NO_X sources met the criteria for inclusion in the annual NO_2 PSD increment consumption analysis. No inventory sources of PM met the criteria for inclusion in the cumulative modeling assessment for NAAQS compliance for $PM_{2.5}$. In addition, because the Project is the first $PM_{2.5}$ source to "trigger" PSD review in the region, no other PM sources need to be considered in the PSD increment consumption analysis.

The NO_x sources modeled cumulatively with the Project are as follows:

- Bridgeport Harbor Generating Station, Bridgeport, Connecticut
 - \circ Generator #3 Actual NO_x = 2,111.9 tpy, Distance from Project = 35.2 km (NAAQS and PSD)
- Algonquin Gas Transmission, Oxford, Connecticut
 - o Turbine #1 − Actual NO_x = 1.1 tpy, Distance from Project = 0.112 km (PSD only)
 - \circ Turbine #2 Actual NO_x = 0.3 tpy, Distance from Project = 0.112 km (PSD only)
 - \circ Turbine #3 Actual NO_x = 0.2 tpy, Distance from Project = 0.112 km (PSD only)

Detailed emissions and stack parameter data for these sources are provided in Appendix L-D, along with more details on the source inventory selection criteria.

Table L-11 presents the results of the cumulative NAAQS compliance assessment. This assessment includes the predicted cumulative impacts of the facility and background inventory source plus representative ambient background concentrations for all receptors and time periods where the Project has a significant impact. As shown in Table L-11, the resulting total concentrations are less than the corresponding NAAQS concentrations for all pollutants. The predicted NO_2 concentrations conservatively assume a 100% conversion rate of NO_X to NO_2 for 1-hour concentrations. Detailed results of the modeling analysis are provided in Appendix L-C.

Table L-11. Cumulative NAAQS Compliance Assessment

Pollutant	Averaging Period	Cumulative Impact Concentration ¹ (μg/m³)	Ambient Background (μg/m³)	Total Impact Plus Background (μg/m³)	NAAQS (μg/m³)
NO	1-Hour	81.8	87	168.8	188
NO ₂	Annual	1.9	21	22.9	100
PM _{2.5}	24-hour	3.5	24	27.5	35

Notes: Total cumulative impact concentrations based on consideration of all receptors and time periods where the Project has a predicted significant impact concentration (based on 5-year average maximum H1H and lower-ranked concentrations for 1-hour NO_2 and 24-hour $PM_{2.5}$). NO_2 concentrations conservatively assume 100% NO_X to NO_2 conversion.

3.12 PSD INCREMENT CONSUMPTION ANALYSIS

The PSD program requires a demonstration that the proposed facility, in combination with other PSD increment-consuming emission sources (as described in Section 3.11), will comply with the maximum allowable PSD "increment." This analysis is required because the Project is subject to PSD review and also has maximum predicted impacts greater than the corresponding SILs.

Table L-12 presents the results of the PSD increment compliance assessment for 24-hour $PM_{2.5}$ and annual NO_2 . Note that there is no PSD increment for 1-hour NO_2 . Detailed results for the analysis are also provided in Appendix L-C.

Table L-12. Cumulative PSD Increment Compliance Assessment

Pollutant	Averaging Period	Total Increment Consumption ¹ (μg/m³)	Maximum Allowable PSD Increment (μg/m³)
NO ₂	Annual	2.4	25
PM _{2.5}	24-hour	4.2	9

¹ Impact concentrations are conservatively based on the maximum highest first highest (H1H) concentration predicted across the range of modeled years.

4.0 EVALUATION OF ADDITIONAL IMPACTS

In accordance with PSD regulations, additional impacts must be addressed for projects subject to PSD review. The additional PSD impact analyses involving air quality modeling are discussed in this section.

4.1 CLASS I AREA AIR QUALITY RELATED VALUES

The nearest PSD Class I Areas to the Project is as follows:

- Lye Brook National Wilderness Area, Vermont located approximately 175 km from the Project.
- Brigantine National Wildlife Refuge, New Jersey located approximately 250 km from the Project.

The Federal Land Managers' (FLM) Air Quality Related Values Work Group (FLAG) has implemented initial screening criteria to determine whether impacts to Class I areas from sources greater than 50 km away would be considered negligible for all AQRVs, including visibility. The screening criteria are detailed in FLAG's October 2010 Phase I Report (United States Forest Service [USFS] et al. 2010). The FLAG Phase I Report was produced as a collaborative report by the FLMs in the USFS, National Park Service, and United States Fish and Wildlife Service (collectively "the Agencies"). The details of the screening criteria are given below.

...the Agencies will consider a source locating greater than 50 km from a Class I area to have negligible impacts with respect to Class I AQRVs if its total SO₂, NO_X, PM₁₀, and H₂SO₄ [sulfuric acid] annual emissions (in tons per year, based on 24-hour maximum allowable emissions), divided by the distance (in km) from the Class I area (Q/D) is 10 or less. The Agencies would not request any further Class I AQRV impact analyses from such sources (USFS et al. 2010).

The combined annual potential-to-emit for SO_2 , NO_x , PM_{10} , and sulfuric acid for the Project (based on 24-hour maximum emissions), is approximately 918 tpy. The approximate distance to the Lye Brook National Wilderness Area is 175 km. The resulting Q/D value of 5.2 is well below the screening level of 10. Therefore, no additional analysis of Class I area impacts is required for the Project.

4.2 VISIBILITY [ATTACHMENT 216-G]

CPV will comply with the particulate and visible emissions requirements specified in Section 22a-174-18 of the Regulations of Connecticut State Agencies. Compliance with these regulations will address the intent of the PSD plume blight visibility requirements.

The VISCREEN model was used to assess potential visibility impacts at the closest Class I Area, the Lye Brook National Wilderness Area (175 km away). The Project's maximum potential emissions were used in the analysis. The results (provided in Appendix L-E) indicate that the visibility impairment related to the Project's plume will not exceed threshold criteria.

4.3 SOILS AND VEGETATION [ATTACHMENT 216-G]

The USEPA guidance document for soils and vegetation, *A Screening Procedure for the Impacts of Air Pollution Sources on Plants, Soils, and Animals* (USEPA 1980), established a screening methodology for comparing air quality modeling impacts to "vegetation sensitivity thresholds." These methods were used to evaluate potential impacts on vegetation and soils.

4.3.1 Vegetation Assessment

As an indication of whether emissions from the Project will significantly impact the surrounding vegetation (i.e., cause acute or chronic exposure to each evaluated pollutant), the modeled predicted impact concentrations are compared against both a range of injury thresholds found in the guidance, as well as those established by the NAAQS secondary standards.

The Project site is located within Connecticut's Southern Hills-Central Hardwoods zone, and the Southwest Hills ecoregion (Dowhan and Craig 1976). Dominant tree species in the area include a variety of: oaks (*Quercus rubra*, *Q. alba*, and *Q. velutina*); hickories (*Carya ovate*, *C. cordiformis*, *C. glabra*, and *C. olvis*); tulip poplar (*Liriodendron tulipifera*); black birch (*Betula lenta*); white ash (*Fraxinus americana*); and eastern hemlock (*Tsuga canadensis*). Typical forest understories in the area contain species such as: cinnamon fern (*Osmunda cinnamomea*); sensitive fern (*Onclea sensibilis*); arrowood viburnam (*Viburnum recognitum*); and raspberry (*Rubus sp.*). Nonforested tracts within the area are typical of active and former agricultural fields with prevalent species such as: purple clover (*Trifolium pratense*); timothy (*Phleum pretense*); quack grass (*Arropyron repens*); goldenrod (*Solidago canadensis*, *S. gigantean*, and *S. tenufolia*); tall nettle (*Urtica procera*); Queen Anne's lace (*Daucus carota*); milkweed (*Asclepias sp.*); and asters (*Aster sp.*). The species prevalent in the area are common and do not represent vegetation that would be expected to be more sensitive than those used by USEPA to establish the screening concentrations provided in Table L-13.

Pollutants	Averaging Period	Maximum Project Impacts (μg/m³)	NAAQS Secondary Standards (µg/m³)	EPA's 1980 Screening Concentrations (µg/m³)		
SO ₂	1-hour	2.7	NA	917		
	3-hour	1.4	1300	786		
	Annual	0.03	NA	18		
NO ₂	4-hour	12.9 (1-hour) ¹	NA	3760		
	1-month	12.9 (1-hour) ¹	NA	561		
	Annual	1.4	100	94		
СО	1-week	176.3 (8-hour) ¹	NA	1,800,000 (weekly)		
PM ₁₀	24-hour	4.2	150	None		
PM _{2.5}	24-hour	4.2	35	None		
	Annual	0.290	15	None		

Table L-13. Vegetation Impact Screening Thresholds Assessment

Since the NAAQS secondary standards were set to protect public welfare, including protection against damage to crops and vegetation, comparing modeled emissions to these standards provides some indication if potential impacts are likely to be significant. Table L-13 lists the Project impact concentrations and compares them to the vegetation sensitivity thresholds and NAAQS secondary standards. All pollutant impact concentrations are well below the vegetation sensitivity thresholds.

4.3.2 Soil Assessment

The USEPA Screening Procedure also provides a method for assessing impacts on soils. This assessment evaluates trace element contamination of soils. Since plant and animal communities can be affected before noticeable accumulation occurs in the soils, the approach used here evaluates the way soil acts as an intermediary in the transfer of a deposited trace elements to plants. For trace elements, the concentration deposited in the soil is calculated from the maximum-predicted annual ground-level concentrations conservatively assuming that all deposited material is soluble and available for uptake by

plants. The amount of trace elements potentially taken up by plants is calculated using average plant-tosoil concentration ratios. The calculated soil and plant concentrations were then compared to screening concentration threshold criteria designed to assess potential adverse effects to soils and plants.

Soils in the Project area were generally formed in glacial till sediments that were derived from gneissic and schistose metamorphic parent material. Soils proximate to the Project site are primarily represented by two soil series, the Paxton series and the Woodbridge series. Smaller amounts of soils from the Ridgebury series are also found near watercourses and wetlands. The Paxton and Woodbridge soils are typically coarse to fine sandy loams containing coarse to gravelly materials, and are moderately well drained. Ridgebury soils are typically poorly drained fine sandy loams, formed in compact glacial till. None of the soils prevalent in the area would necessitate use of criteria differing from those considered in USEPA's screening assessment methodology, shown in Table L-14.

Table L-14 presents the results of the potential soil and plant concentrations and compares them to the corresponding screening concentration criteria. Only pollutants that are potentially emitted from the Project and which have a screening concentration are presented. A calculated concentration in excess of either of the screening concentration criteria is an indication that a more detailed evaluation may be required. However, as shown in Table L-14, calculated concentrations as a result of operation of the Project are all well below the screening criteria. Detailed calculations are provided in Appendix L-F.

Pollutant	Maximum Project Deposited Soil Concentration (ppmw)	Soil Screening Criteria (ppmw)	Percent of Soil Screening Criteria	Plant Tissue Concentration (ppmw)	Plant Screening Criteria (ppmw)	Percent of Plant Screening Criteria
Arsenic	8.39E-03	3	0.3	1.17E-03	0.25	0.5
Cadmium	3.10E-02	2.5	1.2	3.32E-01	3	11.1
Chromium	6.32E-02	8.4	0.8	1.26E-03	1	0.1
Lead	4.77E-02	1000	0.0	2.15E-02	126	0.0
Manganese	2.22E+00	2.5	88.8	1.47E-01	400	0.0
Mercury	7.36E-03	455	0.0	3.68E-03	NA	NA
Nickel	4.76E-02	500	0.0	2.14E-03	60	0.0
Selenium	7.07E-02	13	0.5	7.07E-02	100	0.1

Table L-14. Soils Impact Screening Assessment

Note: Based on screening procedures described in Chapter 5 of the USEPA guidance document for soils and vegetation, A Screening Procedure for the Impacts of Air Pollution Sources on Plants, Soils, and Animals. (USEPA 1980)

4.4 GROWTH [ATTACHMENT 216-H AND 215-C]

A growth analysis examines the potential emissions from secondary sources associated with the Project. While these activities are not directly involved in Project operation, the emissions involve those that can reasonably be expected to occur; for instance, industrial, commercial, and residential growth that will occur in the Project area due to the Project itself. Secondary emissions do not include any emissions that come directly from mobile sources, such as emissions from the tailpipe of any on-road motor vehicle or


the propulsion of a train. They also do not include sources that do not impact the same general area as the source under review.


The Project is expected to have a construction workforce reflecting 300 – 500 jobs over the approximately 2½ year construction period. A significant portion of the regional construction force in the area of the site is currently available to build the Project. However, it is possible that a small percentage of the labor force will be from outside the commuting region, and may create a small new housing demand. However, it is expected that any new housing demand can be met with existing housing stock in the region. In addition, it is expected that no induced commercial or industrial construction in the area will be necessary to support the Project. The operations staff will consist of approximately 21 to 25 workers, and will not significantly influence growth in the area. Therefore, an evaluation of secondary emission sources associated with the Project is not warranted.

5.0 REFERENCES


- Auer, A.H. 1978. Correlation of Land Use and Cover with Meteorological Anomalies. Journal of Applied Meteorology, 17, 636-643. May 1978.
- DEEP 2009. A Guideline for Performing Stationary Source Air Quality Modeling in Connecticut. July 2009, Revised December 2009.
- Dowhan and Craig 1976. Rare and Endangered Species in Connecticut and Their Habitats. Natural Resources Center, Department of Environmental Protection. 1976.
- USEPA 1980. A Screening Procedure for the Impacts of Air Pollution Sources on Plants, Soils, and Animals. EPA-450/2-81-078. U.S. Environmental Protection Agency, Research Triangle Park, NC 27711. December 1980.
- USEPA 1985. Guideline for the Determination of Good Engineering Practice Stack Height (Technical Support Document for the Stack Height Regulation) Revised. EPA-450/4-80-023R, U.S. Environmental Protection Agency, Research Triangle Park, NC 27711. June 1985.
- USEPA 2004. User's Guide for the AMS/EPA Regulatory Model (AERMOD) and Addendums. EPA-454/B-03-001 Office of Air Quality Planning and Standards, Research Triangle Park, North Carolina. September 2004.
- USEPA 2005. Guidance on Air Quality Models (Revised). Codified in the Appendix W to 40 CFR Part 51. Office of Air Quality Planning and Standards, Research Triangle Park, NC. November 2005.
- USEPA 2013. Draft Guidance for PM_{2.5} Permit Modeling, Steven D. Page, March 2013.
- USFS, NPS, and USFWS 2010. Federal Land Managers' Air Quality Related Values Work Group (FLAG): Phase 1 Report, Revised. Natural Resource Report NPS/NRPC/NRR 2010/232. October 2010.


FIGURES





SOUTH





CPV Towantic Energy Center	Ambient Air Quality Analysis – September 2014

APPENDIX L-A: DETAILED SOURCE PARAMETER DATA

CPV Towantic Energy, LLC - 7HA01 Combustion Turbine Emissions Data For Modeling


Parameter	Units	GE Design Cases																		
	Units	#1	#2	#3	#4	#28	#29	#35	#9	#31	#32	#11	#36	#13	#14	#16	#17	#23	#24	#22
Fuel	N/A	Natural Gas																		
Ambient Temperature	°F	-14.2°F	-14.2°F	-14.2°F	-14.2°F	-14.2°F	-14.2°F	59°F	59°F	59°F	59°F	59°F	90°F	90°F	100°F	100°F	100°F	100°F	100°F	100°F
Number of GTs Operating		2	2	1	2	2	2	2	2	2	2	2	2	2	2	1	2	2	2	2
Percent Load Rate	%	BASE	BASE	BASE	BASE	75%	50%	BASE	BASE	75%	50%	30%	BASE	BASE	BASE	BASE	BASE	75%	50%	41%
Duct Burner Operation		Fired	Fired	Fired	Unfired	Unfired	Unfired	Fired	Unfired	Unfired	Unfired	Unfired	Fired	Unfired	Fired	Fired	Unfired	Unfired	Unfired	Unfired
Stack Diameter	feet	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22
Co-located Eq Diameter	feet	31.11	31.11	N/A	31.11	31.11	31.11	31.11	31.11	31.11	31.11	31.11	31.11	31.11	31.11	N/A	31.11	31.11	31.11	31.11
Stack Height	feet	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150
Stack Temperature	°K	356.4	360.3	349.8	364.5	360.7	355.6	352.2	357.2	355.5	354.8	349.8	359.1	364.4	364.9	349.8	368.0	364.9	360.9	357.0
Stack Flow Rate	m³/s	650.8	656.9	646.4	663.5	528.0	417.3	598.7	605.2	495.9	407.5	313.1	562.8	587.8	589.4	570.7	592.4	474.7	384.3	337.7
Stack Exit Velocity	m/s	18.42	18.59	18.30	18.78	14.94	11.81	16.94	17.13	14.04	11.53	8.86	15.93	16.64	16.68	16.15	16.77	13.43	10.88	9.56
Stack Exit Velocity	fps	60.4	61.0	60.0	61.6	49.0	38.7	55.6	56.2	46.0	37.8	29.1	52.2	54.6	54.7	53.0	55.0	44.1	35.7	31.4
NO _x Emission Rate	g/s	2.633	2.533	3.377	2.444	1.953	1.512	2.495	2.318	1.827	1.399	1.058	2.318	2.192	2.369	2.936	2.192	1.613	1.246	1.115
CO Emission Rate	g/s	1.361	1.310	1.739	0.669	0.534	0.413	1.251	0.634	0.501	0.383	0.290	1.197	0.602	1.229	1.512	0.600	0.440	0.341	0.305
SO ₂ Emission Rate	g/s	0.611	0.588	0.782	0.565	0.458	0.354	0.585	0.543	0.431	0.328	0.249	0.543	0.516	0.556	0.686	0.514	0.378	0.293	0.262
PM ₁₀ /PM _{2.5} Emission Rate	g/s	2.520	2.457	2.570	1.226	1.158	1.104	2.558	1.215	1.144	1.090	1.050	2.407	1.201	2.533	2.268	1.200	1.116	1.072	1.056

CPV Towantic Energy, LLC - 7HA01 Combustion Turbine Emissions Data For Modeling

Parameter	Units						GE Desig	n Cases					
raiailletei		#37	#46	#47	#38	#41	#52	#53	#42	#43	#44	#51	#45
Fuel	N/A	Distillate O	il										
Ambient Temperature	°F	-14.2°F	-14.2°F	-14.2°F	-14.2°F	59°F	59°F	59°F	90°F	100°F	100°F	100°F	100°F
Number of GTs Operating		2	1	2	2	2	2	2	2	2	2	2	2
Percent Load Rate	%	BASE	BASE	75%	50%	BASE	75%	50%	BASE	BASE	BASE	75%	50%
Duct Burner Operation		Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired
Stack Diameter	feet	22	22	22	22	22	22	22	22	22	22	22	22
Co-located Eq Diameter	feet	31.11	N/A	31.11	31.11	31.11	31.11	31.11	31.11	31.11	31.11	31.11	31.11
Stack Height	feet	150	150	150	150	150	150	150	150	150	150	150	150
Stack Temperature	°K	424.4	417.9	411.1	405.5	419.0	406.7	404.5	417.5	423.2	415.9	410.4	411.1
Stack Flow Rate	m³/s	770.9	756.4	597.7	473.6	741.3	565.3	432.6	698.2	705.0	649.0	511.1	406.1
Stack Exit Velocity	m/s	21.82	21.41	16.91	13.40	20.98	16.00	12.24	19.76	19.95	18.37	14.46	11.49
Stack Exit Velocity	fps	71.6	70.2	55.5	44.0	68.8	52.5	40.2	64.8	65.4	60.2	47.4	37.7
NO _x Emission Rate	g/s	6.552	5.859	5.254	4.032	6.199	4.901	3.780	5.771	5.746	5.368	4.322	3.352
CO Emission Rate	g/s	1.600	1.424	1.273	0.982	1.512	1.194	0.921	1.411	1.399	1.310	1.051	0.816
SO ₂ Emission Rate	g/s	0.620	0.620	0.497	0.383	0.587	0.464	0.358	0.547	0.544	0.508	0.408	0.318
PM ₁₀ /PM _{2.5} Emission Rate	g/s	5.368	5.368	5.292	5.242	5.342	5.279	5.229	5.330	5.317	5.305	5.254	5.204

CPV Towantic Energy Center	Ambient Air Quality Analysis – September 2014
APPENDIX L-B: FACILITY LAYO	OUT DIAGRAMS AND BPIP DATA

CPV Towantic - Facility Layout Schematic Diagram



CPV Towantic - Summary of Building Dimensions for Significant Structures

					Ground
	Length	Width	Height	Diameter	Elevation
Structure	(ft)	(ft)	(ft)	(ft)	(ft)
Main HRSGs	120	47.8	97	NA	830
HRSG Steam Drum A	46	8.4	110.3	NA	830
HRSG Steam Drums B, C	34.2	5.8	106	NA	830
CTG Enclosure	77	35.5	37	NA	830
CTG Air Inlet	58	34	72.4	NA	830
EDG Enclosure	22	30	15	NA	830
Admin/Control/Elec Building	59	186	52	NA	830
Turbine Building	92	161	37	NA	830
STG Enclosure	44	110	64	NA	830
Fire Protection Pump House	20	30	15	NA	830
Air Cooled Condenser (ACC)	250	268	85	NA	830
Tanks:					
Condensate Tank	NA	NA	40	30	830
Demineralizer Water Tanks	NA	NA	42	60	830
Fire Protection Tanks	NA	NA	40	40	830
Fuel Oil Tanks	NA	NA	48	73	830

BPIP Input

656774.05

4594176.1

```
'C:\Users\ted.guertin\Desktop\CPV Towantic\AERMOD9\BPIP_Schematic.BST BEESTWin BPIP-Prime Files 8/27/2014 1:54:40
'P'
'METERS'
              1.0
'UTMY'
23
'HRSG2'
                            252.984
12
              29.5656
656762.3
              4594188.33
656760.98
              4594178.08
656766.69
              4594155.35
656768.32
              4594155.74
656771.85
              4594153.13
656772.43
              4594154.12
656775
              4594155.15
656777.25
              4594154.45
656779.12
              4594158.46
656780.76
              4594158.87
656775.05
              4594181.61
656769.05
              4594190.02
'HRSG1'
                            252.984
12
              29.5656
656802.8
              4594198.53
656801.45
              4594188.25
656807.16
              4594165.52
656808.82
              4594165.9
656812.39
              4594163.25
656812.91
              4594164.3
656815.47
              4594165.34
656817.73
              4594164.62
656819.64
              4594168.63
656821.24
              4594169.04
656815.57
              4594191.78
656809.54
              4594200.19
'ACC'
                            252.984
              25.91
656709.16
              4594092.44
656727.85
              4594018.58
656807.02
              4594038.58
656788.39
              4594112.23
'fireBldg'
                            252.984
               1
              4.572
656750.33
              4594148.28
656753.66
              4594134.98
656741.53
              4594131.93
656738.23
              4594145.25
'AIRIN1'
                            252.984
              22.06752
656764.73
              4594213.45
656755.06
              4594211.
656750.62
              4594228.6
656760.29
              4594231.07
'AIRIN2'
                            252.984
              22.06752
656805.23
              4594223.62
656795.53
              4594221.18
656791.11
              4594238.79
656800.81
              4594241.24
'drumC2'
                            252.984
26
              32.3088
656764.33
              4594175.02
656764.14
              4594174.91
656764.03
              4594174.79
656763.97
              4594174.65
656763.93
              4594174.51
656763.91
              4594174.3
656763.92
              4594174.13
656763.98
              4594173.88
656764.04
              4594173.76
656764.15
              4594173.55
656764.25
              4594173.43
656764.33
              4594173.36
656764.43
              4594173.3
656764.64
              4594173.21
656764.76
              4594173.23
656773.64
              4594175.46
656773.87
              4594175.59
656774.
              4594175.81
```

```
4594176.43
656773.93
              4594176.73
656773 82
              4594176.94
656773.62
              4594177.14
656773.39
              4594177.25
656773.3
              4594177.26
656773.2
              4594177.25
'drumB2'
               1
                             252.984
26
656765.79
              32.3088
              4594169.21
656765.63
              4594169.13
656765.48
              4594168.95
656765.43
              4594168.82
656765.39
              4594168.66
656765.38
              4594168.48
656765.39
              4594168.3
656765.44
              4594168.09
656765.51
              4594167.92
656765.59
              4594167.77
656765.68
              4594167.66
656765.79
              4594167.54
656765.91
              4594167.46
656766.07
              4594167.42
656766.23
              4594167.43
656775.1
              4594169.66
656775.31
              4594169.76
656775.45
              4594169.99
656775.51
              4594170.27
656775.51
              4594170.53
656775.44
              4594170.79
656775.35
              4594171.01
656775.2
              4594171.22
656775.05
              4594171.35
656774.82
              4594171.44
656774.67
              4594171.43
'drumA2'
                             252.984
 23
              33.61944
656766.4
              4594161.48
656766.12
              4594161.37
656765.89
              4594160.98
656765.84
              4594160.48
656765.86
              4594160.17
656765.87
              4594159.95
656766.05
              4594159.54
656766.23
              4594159.23
656766.39
              4594159.04
656766.58
              4594158.89
656766.76
              4594158.81
656767.06
              4594158.83
656779.01
              4594161.83
656779.17
              4594161.9
656779.37
              4594162.09
656779.48
              4594162.34
656779.54
              4594162.73
656779.5
              4594163.23
656779.35
              4594163.7
656779.14
              4594164.08
656778.84
              4594164.37
656778.57
              4594164.48
656778.35
              4594164.5
'drumA1'
                             252.984
 23
              33.61944
656806.87
              4594171.64
656806.66
              4594171.56
656806.54
              4594171.42
656806.39
              4594171.14
656806.32
              4594170.72
656806.34
              4594170.38
656806.44
              4594169.96
656806.59
              4594169.6
656806.84
              4594169.25
656807.13
              4594169.04
656807.33
              4594168.99
656807.51
              4594168.98
656819.5
              4594171.99
656819.76
              4594172.15
656819.92
              4594172.39
656820.02
              4594172.8
656820.01
              4594173.29
656819.91
              4594173.76
656819.69
              4594174.17
```

656774 03

656819.5	4594174.4	
656819.29	4594174.59	
656819.07	4594174.67	
656818.85	4594174.66	
'drumB1'	1	252.984
26	32.3088	
656806.28	4594179.37	
656806.16	4594179.32	
656806.06	4594179.24	
656805.99	4594179.12	
656805.92	4594178.98	
656805.89	4594178.84	
656805.87	4594178.64	
656805.91	4594178.35	
656805.99	4594178.12	
656806.12	4594177.9	
656806.21	4594177.8	
656806.28		
	4594177.72	
656806.4	4594177.65	
656806.55	4594177.6	
656806.73	4594177.61	
656815.59	4594179.83	
656815.76	4594179.9	
656815.92	4594180.11	
656816.	4594180.4	
656816.01	4594180.62	
656815.93	4594180.99	
656815.85	4594181.16	
656815.75	4594181.34	
656815.52	4594181.55	
656815.29	4594181.61	
656815.16	4594181.6	
'drumC1'	1	252.984
26	32.3088	
656804.82	4594185.19	
656804.69	4594185.11	
656804.58	4594185.02	
656804.52	4594184.91	
656804.48	4594184.82	
656804.43	4594184.68	
656804.42	4594184.5	
	4594184.33	
656804.42	4594184.33 4594184 12	
656804.42 656804.46	4594184.12	
656804.42 656804.46 656804.6	4594184.12 4594183.8	
656804.42 656804.46 656804.6 656804.73	4594184.12 4594183.8 4594183.61	
656804.42 656804.46 656804.6 656804.73 656804.86	4594184.12 4594183.8 4594183.61 4594183.49	
656804.42 656804.46 656804.6 656804.73 656804.86 656804.99	4594184.12 4594183.8 4594183.61	
656804.42 656804.46 656804.6 656804.73 656804.86	4594184.12 4594183.8 4594183.61 4594183.49	
656804.42 656804.46 656804.6 656804.73 656804.86 656804.99 656805.12	4594184.12 4594183.8 4594183.61 4594183.49 4594183.45 4594183.41	
656804.42 656804.46 656804.6 656804.73 656804.86 656804.99 656805.12 656805.27	4594184.12 4594183.8 4594183.61 4594183.49 4594183.45 4594183.41 4594183.42	
656804.42 656804.46 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14	4594184.12 4594183.8 4594183.61 4594183.49 4594183.41 4594183.41 4594183.42 4594185.64	
656804.42 656804.46 656804.6 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3	4594184.12 4594183.8 4594183.49 4594183.45 4594183.45 4594183.41 4594183.42 4594185.64	
656804.42 656804.46 656804.6 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3	4594184.12 4594183.8 4594183.61 4594183.45 4594183.45 4594183.41 4594185.64 4594185.72 4594185.72	
656804.42 656804.6 656804.6 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.3	4594184.12 4594183.8 4594183.61 4594183.45 4594183.45 4594183.42 4594185.64 4594185.72 4594185.84 4594186.04	
656804.42 656804.46 656804.6 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3	4594184.12 4594183.8 4594183.61 4594183.45 4594183.45 4594183.41 4594185.64 4594185.72 4594185.72	
656804.42 656804.6 656804.6 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.3	4594184.12 4594183.8 4594183.61 4594183.45 4594183.45 4594183.42 4594185.64 4594185.72 4594185.84 4594186.04	
656804.42 656804.6 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.42 656814.55	4594184.12 4594183.8 4594183.49 4594183.45 4594183.41 4594183.42 4594185.64 4594185.72 4594185.84 4594186.04 4594186.42	
656804.42 656804.46 656804.6 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.52 656814.52 656814.52	4594184.12 4594183.8 4594183.41 4594183.45 4594183.41 4594185.64 4594185.72 4594185.72 4594186.04 4594186.42 4594186.82 4594187.18	
656804.42 656804.6 656804.6 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.52 656814.52 656814.55 656814.55 656814.7 656814.7	4594184.12 4594183.8 4594183.45 4594183.45 4594183.41 4594185.64 4594185.72 4594185.84 4594186.04 4594186.42 4594186.42 4594187.18 4594187.34	
656804.42 656804.6 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.52 656814.52 656814.52 656814.77 656814.25	4594184.12 4594183.8 4594183.41 4594183.45 4594183.41 4594183.42 4594185.72 4594185.72 4594186.04 4594186.42 4594186.82 4594187.18 4594187.34 4594187.34	
656804.42 656804.46 656804.73 656804.86 656804.99 656805.27 656805.27 656814.14 656814.3 656814.42 656814.55 656814.47 656814.55 656814.07 656814.25 656814.25 656814.38	4594184.12 4594183.8 4594183.41 4594183.45 4594183.45 4594185.64 4594185.72 4594185.84 4594186.42 4594186.42 4594186.32 4594187.18 4594187.39 4594187.39	
656804.42 656804.46 656804.6 656804.73 656804.86 656804.99 656805.27 656805.27 656814.14 656814.3 656814.42 656814.55 656814.55 656814.07 656814.95 656814.95 656814.95	4594184.12 4594183.8 4594183.41 4594183.45 4594183.41 4594183.42 4594185.64 4594185.72 4594186.04 4594186.42 4594186.82 4594187.38 4594187.38 4594187.39 4594187.39	
656804.42 656804.46 656804.73 656804.86 656804.99 656805.27 656805.27 656814.14 656814.3 656814.42 656814.55 656814.47 656814.55 656814.07 656814.25 656814.3	4594184.12 4594183.8 4594183.49 4594183.45 4594183.41 4594185.64 4594185.72 4594185.04 4594186.04 4594186.82 4594186.82 4594187.18 4594187.34 4594187.34	252.984
656804.42 656804.46 656804.6 656804.73 656804.86 656804.99 656805.27 656805.27 656814.14 656814.3 656814.42 656814.55 656814.55 656814.07 656814.95 656814.95 656814.95	4594184.12 4594183.8 4594183.41 4594183.45 4594183.41 4594183.42 4594185.64 4594185.72 4594186.04 4594186.42 4594186.82 4594187.38 4594187.38 4594187.39 4594187.39	252.984
656804.42 656804.46 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.52 656814.52 656814.55 656814.55 656814.07 656813.96 656813.96	4594184.12 4594183.8 4594183.49 4594183.45 4594183.41 4594185.64 4594185.72 4594185.04 4594186.04 4594186.82 4594186.82 4594187.18 4594187.34 4594187.34	252.984
656804.42 656804.46 656804.73 656804.86 656804.99 656805.27 656805.27 656814.14 656814.3 656814.42 656814.52 656814.47 656814.25 656814.25 656814.25 656814.25 656814.25 656814.25	4594184.12 4594183.8 4594183.49 4594183.45 4594183.41 4594183.42 4594185.64 4594185.72 4594186.04 4594186.04 4594186.42 4594187.18 4594187.34 4594187.34 4594187.34 4594187.34 4594187.36 4594187.4 11.2776 4594214.63	252.984
656804.42 656804.46 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.42 656814.55 656814.55 656814.07 656813.96 656813.82 656813.82 656682.42 656682.42	4594184.12 4594183.8 4594183.41 4594183.45 4594183.41 4594183.42 4594185.72 4594185.72 4594186.04 4594186.42 4594186.42 4594187.34 4594187.34 4594187.34 4594187.34 4594187.34 4594187.42 4594187.42 4594187.42	252.984
656804.42 656804.46 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.52 656814.52 656814.55 656814.47 656814.07 656813.92 656813.82 656813.82 656813.82 656813.82 656682.42 656682.42	4594184.12 4594183.8 4594183.49 4594183.45 4594183.41 4594185.64 4594185.72 4594185.72 4594186.04 4594186.42 4594186.32 4594187.18 4594187.34 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42	252.984
656804.42 656804.46 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.42 656814.52 656814.55 656814.47 656813.96 656813.69 'STG' 6 656682.42 656737.4 656748.58	4594184.12 4594183.8 4594183.45 4594183.45 4594183.41 4594185.64 4594185.72 4594185.04 4594186.04 4594186.82 4594187.18 4594187.39 4594187.42 4594187.4 11.2776 459428.43 459428.43 459428.43 4594187.8	252.984
656804.42 656804.46 656804.73 656804.86 656804.99 656805.27 656805.27 656814.14 656814.3 656814.42 656814.55 656814.47 656814.51 656814.25 656813.96 656813.96 656813.82 656813.69 'STG' 6 656682.42 656737.4 656748.58 656701.07 656694.25	4594184.12 4594183.8 4594183.45 4594183.45 4594183.41 4594185.64 4594185.72 4594185.84 4594186.04 4594186.42 4594186.32 4594187.18 4594187.34 4594187.34 4594187.42 11.2776 4594214.63 4594214.63 4594228.43 4594187.87 4594187.4	252.984
656804.42 656804.46 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.42 656814.52 656814.55 656814.47 656813.96 656813.69 'STG' 6 656682.42 656737.4 656748.58	4594184.12 4594183.8 4594183.45 4594183.45 4594183.41 4594185.64 4594185.72 4594185.04 4594186.04 4594186.82 4594187.18 4594187.39 4594187.42 4594187.4 11.2776 459428.43 459428.43 459428.43 4594187.8	252.984
656804.42 656804.46 656804.73 656804.86 656804.99 656805.27 656805.27 656814.14 656814.3 656814.42 656814.55 656814.47 656814.51 656814.25 656813.96 656813.96 656813.82 656813.69 'STG' 6 656682.42 656737.4 656748.58 656701.07 656694.25	4594184.12 4594183.8 4594183.45 4594183.45 4594183.41 4594185.64 4594185.72 4594185.84 4594186.04 4594186.42 4594186.32 4594187.18 4594187.34 4594187.34 4594187.42 11.2776 4594214.63 4594214.63 4594228.43 4594187.87 4594187.4	252.984
656804.42 656804.46 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.42 656814.55 656814.55 656814.55 656814.07 656813.96 656813.96 656813.96 656682.42 656737.4 656748.58 656748.58	4594184.12 4594183.8 4594183.45 4594183.45 4594183.41 4594183.42 4594185.64 4594185.72 4594186.04 4594186.04 4594186.32 4594187.18 4594187.34 4594187.34 4594187.39 4594187.42 11.2776 4594214.63 459428.43 4594187.4 11.2776 459428.43 4594187.4 11.2776 459428.43 4594187.4 11.2776 4594214.63 4594183.82 4594171.87 4594199.11 4594197.22	
656804.42 656804.46 656804.73 656804.86 656804.99 656805.27 656805.27 656814.14 656814.3 656814.52 656814.52 656814.55 656814.47 656814.25 656813.96 656813.69 'STG' 656682.42 656737.4 656694.25 656694.25 656694.25 656686.81 'ADMIN'	4594184.12 4594183.8 4594183.49 4594183.45 4594183.41 4594185.64 4594185.72 4594185.72 4594186.04 4594186.04 4594186.32 4594187.33 4594187.34 4594187.39 4594187.42 11.2776 4594218.63 4594187.4 11.2776 45942187.4 11.2776 45942187.4 11.2776 45942187.4 11.2776 45942187.4 11.2776 45942187.4 11.2776 45942187.4 11.2776 45942187.4 11.2776 45942187.4 11.2776 45942187.4 11.2776 45942187.4 11.2776 45942187.4 11.2776 45942187.4 4594197.22 11.2786	
656804.42 656804.46 656804.73 656804.86 656804.99 656805.27 656805.27 656814.14 656814.3 656814.42 656814.55 656814.55 656814.52 656814.55 6566814.55	4594184.12 4594183.8 4594183.41 4594183.45 4594183.41 4594185.64 4594185.72 4594185.84 4594186.04 4594186.82 4594186.82 4594187.18 4594187.34 4594187.34 4594187.41 11.2776 4594214.63 4594214.63 4594214.63 4594197.22 1 15.8496 4594214.62	
656804.42 656804.6 656804.73 656804.86 656804.99 656805.27 656805.27 656814.14 656814.3 656814.42 656814.55 656814.55 656814.47 656814.25 656814.07 656813.96 656813.96 656813.96 656813.96 656813.96 656813.96 656813.96 656813.96 656813.96 656813.96 656813.96 656813.96 656813.96 656813.96 656813.96 656813.96 656682.42 656737.4 656748.58 656748.58 656748.58 656748.58	4594184.12 4594183.8 4594183.45 4594183.45 4594183.41 4594183.42 4594185.64 4594185.72 4594186.04 4594186.42 4594186.32 4594187.34 4594187.34 4594187.34 4594187.39 4594187.82 4594187.82 11.2776 4594214.63 459428.43 4594187.42 11.2776 4594187.42 11.2776 4594187.42 11.2776 4594187.42 11.2776 4594187.42 11.2776 4594187.42 11.2776 4594187.42 11.2776 4594187.42 11.2776 4594187.42 4594187.42 4594187.42 4594187.42 4594187.87 4594199.11 4594197.22 1 15.8496 4594214.62 4594228.45	
656804.42 656804.6 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.55 656814.55 656814.55 656814.57 656813.82 656813.82 656814.67 656814.55 656814.07 656813.82 656814.07 656813.82 656814.07 656813.82 656813.82 656813.82 656813.82 6566813.82 6566813.82 6566813.82 6566813.83 656737.4 656682.42 6566868.81 'ADMIN' 4 656682.42 656682.42 656682.42	4594184.12 4594183.8 4594183.49 4594183.45 4594183.41 4594183.42 4594185.64 4594185.72 4594185.84 4594186.04 4594186.42 4594187.38 4594187.39 4594187.39 4594187.42 4594187.42 4594187.42 11.2776 4594214.63 459428.43 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594214.63 4594214.63 459428.43 4594197.22 1 15.8496 4594214.62 4594228.45 4594211.03	
656804.42 656804.6 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.52 656814.52 656814.55 656814.07 656813.82 656813.82 656813.82 656814.67 656682.42 656737.4 656748.58 656682.42 656688.81 ADMIN' 4	4594184.12 4594183.8 4594183.49 4594183.45 4594183.41 4594185.64 4594185.72 4594185.72 4594185.72 4594186.04 4594186.42 4594187.18 4594187.34 4594187.34 4594187.42 4594187.42 11.2776 4594214.63 4594214.63 4594187.42 11.2776 4594214.63 4594187.42 4594187.42 4594187.42 11.2776 4594214.63 4594214.63 4594197.22 1 15.8496 4594214.62 4594228.45 4594214.62 4594228.45 4594214.62 4594228.45	252.984
656804.42 656804.6 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.55 656814.55 656814.55 656814.57 656813.82 656813.82 656814.67 656814.55 656814.07 656813.82 656814.07 656813.82 656814.07 656813.82 656813.82 656813.82 656813.82 6566813.82 6566813.82 6566813.82 6566813.83 656737.4 656682.42 6566868.81 'ADMIN' 4 656682.42 656682.42 656682.42	4594184.12 4594183.8 4594183.49 4594183.45 4594183.41 4594183.42 4594185.64 4594185.72 4594185.84 4594186.04 4594186.42 4594187.38 4594187.39 4594187.39 4594187.42 4594187.42 4594187.42 11.2776 4594214.63 459428.43 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594214.63 4594214.63 459428.43 4594197.22 1 15.8496 4594214.62 4594228.45 4594211.03	
656804.42 656804.6 656804.73 656804.86 656804.99 656805.12 656805.27 656814.14 656814.3 656814.52 656814.52 656814.55 656814.07 656813.82 656813.82 656813.82 656814.67 656682.42 656737.4 656748.58 656682.42 656688.81 ADMIN' 4	4594184.12 4594183.8 4594183.49 4594183.45 4594183.41 4594185.64 4594185.72 4594185.72 4594185.72 4594186.04 4594186.42 4594187.18 4594187.34 4594187.34 4594187.42 4594187.42 11.2776 4594214.63 4594214.63 4594187.42 11.2776 4594214.63 4594187.42 4594187.42 4594187.42 11.2776 4594214.63 4594214.63 4594197.22 1 15.8496 4594214.62 4594228.45 4594214.62 4594228.45 4594214.62 4594228.45	252.984
656804.42 656804.6 656804.73 656804.86 656804.99 656805.27 656805.27 656814.14 656814.3 656814.42 656814.52 656814.47 656814.25 656814.07 656813.96 656813.96 656813.96 656814.51 656814.07 656814.07 656814.07 656814.07 656814.07 656814.07 656814.07 656813.82 656813.82 656813.82 656813.82 656682.42 656737.4 656686.81 1'ADMIN' 4 656682.42 656737.38 656741.77 656686.81 1'STGENCL' 4	4594184.12 4594183.8 4594183.45 4594183.45 4594183.41 4594185.64 4594185.72 4594185.84 4594186.04 4594186.04 4594186.18 4594187.18 4594187.34 4594187.34 4594187.34 4594187.34 4594187.39 4594187.42 11.2776 4594214.63 4594187.42 11.2776 4594214.63 4594187.42 11.2776 4594214.63 4594187.42 11.2776 4594214.63 4594187.82 4594187.82 4594187.82 4594187.82 4594187.82 4594187.82 4594187.82 4594187.82 10.58496 4594214.62 4594228.45 4594211.03 4594197.18 11.9.5072	252.984
656804.42 656804.46 656804.73 656804.86 656804.99 656805.27 656805.27 656814.14 656814.3 656814.55 656814.55 656814.55 656814.57 656814.07 656813.96 656813.96 656813.96 656813.82 656737.4 656748.58 656701.07 656682.42 656682.42 656737.38 656741.77 656686.81 'ADMIN' 4 656682.42 656737.38 656741.77 656686.81 'STGENCL' 4 656702.3	4594184.12 4594183.8 4594183.49 4594183.45 4594183.41 4594183.41 4594185.64 4594185.72 4594185.84 4594186.04 4594186.42 4594187.38 4594187.38 4594187.39 4594187.42 4594187.42 4594187.42 11.2776 4594214.63 459428.43 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.42 4594187.87 4594197.22 1 15.8496 4594214.62 4594211.03 4594197.18 1 19.5072 4594194.05	252.984
656804.42 656804.6 656804.73 656804.86 656804.99 656805.27 656814.14 656814.3 656814.55 656814.55 656814.55 656814.55 656814.55 656814.07 656813.82 656814.07 656813.82 656814.07 656813.82 656814.07 656813.82 656814.07 656813.82 656813.82 656813.82 656813.82 656813.82 6566813.82 6566813.82 6566813.82 656737.4 656682.42 656737.38 656701.07 656682.42 656737.38 656741.77 656682.42 656737.38 656702.3 656702.3 656702.3	4594184.12 4594183.8 4594183.49 4594183.45 4594183.41 4594185.64 4594185.72 4594185.72 4594185.72 4594186.04 4594186.42 4594186.82 4594187.38 4594187.34 4594187.34 4594187.42 4594187.42 4594187.42 4594187.42 11.2776 4594214.63 4594214.63 4594187.42 4594187.42 11.2776 4594214.63 4594187.87 4594197.18 15.8496 4594228.45 4594214.62 4594214.63 4594214.63 4594197.22 1 15.8496 4594214.63 4594214.63 4594214.63 4594197.22 1 15.8496 4594214.63 4594214.63 4594214.63 4594214.63 4594214.63 4594214.63	252.984
656804.42 656804.46 656804.73 656804.86 656804.99 656805.27 656805.27 656814.14 656814.3 656814.52 656814.55 656814.55 656814.57 656814.57 656814.07 656814.07 656814.07 656814.07 656814.07 656814.07 656813.82 656813.82 656813.82 656813.82 656813.82 656737.4 656682.42 656737.4 656737.4 656737.4 656741.77 656686.81 'ADMIN' 4 656682.42 656737.38 656741.77 656686.81 'STGENCL' 4 656702.3 656702.3 656737.92	4594184.12 4594183.8 4594183.45 4594183.45 4594183.41 4594185.64 4594185.62 4594185.72 4594185.84 4594186.04 4594186.42 4594187.18 4594187.34 4594187.34 4594187.34 4594187.42 11.2776 4594214.63 459428.43 4594187.4 11.2776 4594214.63 459428.43 4594187.4 11.2776 4594214.63 459428.45 4594171.87 4594199.11 459428.45 4594214.62 4594214.62 4594214.62 4594214.63 4594214.63 4594214.62 4594214.63 4594214.63 4594214.62 4594214.63 4594214.62 4594214.63 4594214.63 4594214.64 4594214.65 4594214.05 4594202.16 4594189.14	252.984
656804.42 656804.6 656804.73 656804.86 656804.99 656805.27 656805.27 656814.14 656814.3 656814.42 656814.52 656814.47 656814.25 656814.25 656814.97 656814.25 656814.07 656813.96 656813.96 656813.96 656813.96 656813.82 656813.96 656813.82 656813.82 656813.82 656813.82 656813.82 656813.82 656737.4 656748.58 656701.07 656682.42 656737.38 656741.77 656686.81 956686.81 956686.81 956686.81 956686.81 956686.81 956686.81 956686.81 956686.81 956686.81 956686.81 956686.81 956686.81 956686.81 956686.81 956686.81	4594184.12 4594183.8 4594183.41 4594183.45 4594183.41 4594185.64 4594185.72 4594185.84 4594186.04 4594186.04 4594186.32 4594187.18 4594187.34 4594187.34 4594187.34 4594187.34 4594187.34 4594187.42 11.2776 4594214.63 4594214.63 4594214.63 4594228.43 4594171.87 4594199.11 4594197.22 1 15.8496 4594214.62 4594214.62 4594214.62 4594214.63 4594214.62 4594214.63 4594199.11 4594197.18 1 19.5072 4594194.05 4594194.05 4594181.06	252.984 252.984
656804.42 656804.46 656804.73 656804.86 656804.99 656805.27 656805.27 656814.14 656814.3 656814.52 656814.55 656814.55 656814.57 656814.57 656814.07 656814.07 656814.07 656814.07 656814.07 656814.07 656813.82 656813.82 656813.82 656813.82 656813.82 656737.4 656682.42 656737.4 656737.4 656737.4 656741.77 656686.81 'ADMIN' 4 656682.42 656737.38 656741.77 656686.81 'STGENCL' 4 656702.3 656702.3 656737.92	4594184.12 4594183.8 4594183.45 4594183.45 4594183.41 4594185.64 4594185.62 4594185.72 4594185.84 4594186.04 4594186.42 4594187.18 4594187.34 4594187.34 4594187.34 4594187.42 11.2776 4594214.63 459428.43 4594187.4 11.2776 4594214.63 459428.43 4594187.4 11.2776 4594214.63 459428.45 4594171.87 4594199.11 459428.45 4594214.62 4594214.62 4594214.62 4594214.63 4594214.63 4594214.62 4594214.63 4594214.63 4594214.62 4594214.63 4594214.62 4594214.63 4594214.63 4594214.64 4594214.65 4594214.05 4594202.16 4594189.14	252.984

656819.5 4594174.4

```
11.2776
12
656765.69
              4594213.7
              4594193.26
656770.82
656768.27
              4594192.6
656768.89
              4594190.22
656769.04
              4594190.03
656762.3
              4594188.33
656762.34
              4594188.59
656761.74
              4594190.96
656760.16
              4594190.56
656750.56
              4594228.61
656760.27
              4594231.04
656764.72
              4594213.45
'CTURB2'
               1
                            252.984
              11.2776
12
656806.18
              4594223.87
656811.34
              4594203.41
656808.78
              4594202.78
656809.39
              4594200.39
656809.54
              4594200.19
656802.8
              4594198.52
656802.84
              4594198.73
656802.22
              4594201.13
656800.66
              4594200.74
656791.1
              4594238.78
656800.8
              4594241.22
656805.23
              4594223.62
              1
4.572
'EDG'
                            252.984
4
656728.68
              4594235.67
656730.91
              4594226.8
656737.42
              4594228.44
656735.19
              4594237.3
'demin1'
                            252.984
32
              12.8016
656720.37
              4594148.57
656720.2
              4594150.35
656719.68
              4594152.06
656718.83
              4594153.65
656717.69
              4594155.03
656716.31
              4594156.17
656714.73
              4594157.01
656713.01
              4594157.53
656711.23
              4594157.71
656709.44
              4594157.53
656707.73
              4594157.01
656706.15
              4594156.17
656704.76
              4594155.03
656703.62
              4594153.65
656702.78
              4594152.06
656702.26
              4594150.35
656702.08
              4594148.57
656702.26
              4594146.78
656702.78
              4594145.07
656703.62
              4594143.49
656704.76
              4594142.1
656706.15
              4594140.96
656707.73
              4594140.12
656709.44
              4594139.6
656711.23
              4594139.42
656713.01
              4594139.6
656714.73
              4594140.12
656716.31
              4594140.96
656717.69
              4594142.1
656718.83
              4594143.49
656719.68
              4594145.07
656720.2
              4594146.78
'demin2'
                            252.984
32
              12.8016
656725.39
              4594128.4
656725.21
              4594130.18
656724.69
              4594131.9
656723.85
              4594133.48
656722.71
              4594134.86
656721.32
              4594136.
656719.74
              4594136.84
656718.03
              4594137.36
656716.24
              4594137.54
656714.46
              4594137.36
656712.74
              4594136.84
656711.16
              4594136.
```

```
656708.64
              4594133.48
656707.8
              4594131 9
656707.28
              4594130.18
656707.1
              4594128.4
656707.28
              4594126.61
656707.8
              4594124.9
656708.64
              4594123.32
656709.78
              4594121.93
656711.16
              4594120 79
656712.74
              4594119.95
656714.46
              4594119.43
656716.24
              4594119.25
656718.03
              4594119.43
656719.74
              4594119.95
656721.32
              4594120.79
656722.71
              4594121.93
656723.85
              4594123.32
656724.69
              4594124.9
656725.21
              4594126.61
'firetank'
                            252.984
32
              12.192
656748.51
              4594153.72
656748.39
              4594154.91
656748.05
              4594156.06
656747.48
              4594157.11
656746.73
              4594158.03
656745.8
              4594158.79
656744.75
              4594159.36
656743.6
              4594159.7
656742.42
              4594159.82
656741.23
              4594159.7
656740.08
              4594159.36
656739.03
              4594158.79
656738.1
              4594158.03
656737.35
              4594157.11
656736.78
              4594156.06
656736.44
              4594154.91
656736.32
              4594153.72
656736.44
              4594152.53
656736.78
              4594151.39
656737.35
              4594150.34
656738.1
              4594149.41
656739.03
              4594148.66
656740.08
              4594148.09
656741.23
              4594147.74
656742.42
              4594147.63
656743.6
              4594147.74
656744.75
              4594148.09
656745.8
              4594148.66
656746.73
              4594149.41
656747.48
              4594150.34
656748.05
              4594151.39
656748.39
              4594152.53
'condtank'
                            252.984
32
              12.192
656742.45
              4594171.8
656742.36
              4594172.69
656742.1
              4594173.55
656741.68
              4594174.34
656741.11
              4594175.03
656740.42
              4594175.6
656739.63
              4594176.02
656738.77
              4594176.28
656737.88
              4594176.37
656736.99
              4594176.28
656736.13
              4594176.02
656735.34
              4594175.6
656734.65
              4594175.03
656734.08
              4594174.34
656733.65
              4594173.55
656733.39
              4594172.69
656733.31
              4594171.8
656733.39
              4594170.91
656733.65
              4594170.05
656734.08
              4594169.26
656734.65
              4594168.57
656735.34
              4594168.
656736.13
              4594167.58
656736.99
              4594167.32
656737.88
              4594167.23
```

656709 78

4594134 86

656738.77	4594167.32				
656739.63	4594167.58				
656740.42	4594168.				
656741.11	4594168.57				
656741.68	4594169.26				
656742.1	4594170.05				
656742.36	4594170.91				
'fueloil'	1	252.984			
32	14.6304				
656842.98	4594109.49				
656842.77	4594111.66				
656842.14	4594113.75				
656841.11	4594115.67				
656839.72	4594117.36				
656838.04	4594118.74				
656836.12	4594119.77				
656834.03	4594120.41				
656831.86	4594120.62				
656829.69	4594120.41				
656827.6	4594119.77				
656825.68	4594118.74				
656823.99	4594117.36				
656822.61	4594115.67				
656821.58	4594113.75				
656820.95	4594111.66				
656820.73	4594109.49				
656820.95	4594107.32				
656821.58	4594105.24				
656822.61	4594103.31				
656823.99 656825.68	4594101.63 4594100.24				
656827.6	4594100.24				
656827.6	4594099.22				
656831.86	4594098.38				
656834.03	4594098.58				
656836.12	4594099.22				
656838.04	4594100.24				
656839.72	4594100.24				
656841.11	4594103.31				
656842.14	4594105.31				
656842.77	4594107.32				
5	4334107.32				
'FIREPUMP	1	252.984	5.334	656748.5	4594146.3
'EGEN	1	252.984	4.4196	656729.2	4594234.2
'CT1 #53	1	252.984	45.72	656815.8	4594161.2
'CT2 #53	1	252.984	45.72	656775.3	4594151.
'AUXBLR	1	252.984	18.8976	656687.5	4594203.9

BPIP Output

•						
SO BUILDHGT FIREF	PUMP 25.91	29.57	29.57	29.57	29.57	29.57
SO BUILDHGT FIRE	PUMP 29.57	29.57	29.57	29.57	29.57	25.91
SO BUILDHGT FIREF		25.91	25.91	25.91	25.91	25.91
SO BUILDHGT FIREF						
		29.57	29.57	29.57	29.57	29.57
SO BUILDHGT FIREF		29.57	29.57	29.57	29.57	25.91
SO BUILDHGT FIREF	PUMP 25.91	25.91	25.91	25.91	25.91	25.91
SO BUILDWID FIREF	PUMP 105.73	61.98	30.72	33.23	35.56	36.82
SO BUILDWID FIREF	PUMP 36.95	36.82	36.89	35.84	33.71	111.37
SO BUILDWID FIREF		106.57	99.25	88.92	87.02	97.86
SO BUILDWID FIREF		61.98	30.72	33.23	35.56	36.82
SO BUILDWID FIREF		36.82	36.89	35.84	33.71	111.37
SO BUILDWID FIREF	PUMP 110.65	106.57	99.25	88.92	87.02	97.86
SO BUILDLEN FIREF	PUMP 102.74	57.11	31.21	28.08	24.09	20.37
SO BUILDLEN FIREF	PUMP 16.84	16.14	19.78	23.30	27.42	111.68
SO BUILDLEN FIREF		104.16	95.57	84.08	81.71	93.65
SO BUILDLEN FIREF		57.11	31.21	28.08	24.09	20.37
SO BUILDLEN FIREF		16.14	19.78	23.30		111.68
SO BUILDLEN FIREF	PUMP 109.59	104.16	95.57	84.08	81.71	93.65
SO XBADJ FIREF	PUMP -129.37	14.40	16.93	18.63	19.75	20.28
SO XBADJ FIREF	PUMP 20.19	17.81	12.48	6.29	-1.41	-7.14
SO XBADJ FIREF	PUMP 4.48	15.97	26.97	37.16	40.48	34.07
SO XBADJ FIREF		-71.52	-48.14	-46.70	-43.84	
SO XBADJ FIREF		-33.95	-32.26	-29.59		-104.54
SO XBADJ FIREF		-120.13	-122.55		-122.19	
SO YBADJ FIREF	PUMP -23.47	-29.58	-6.29	-0.17	5.54	11.09
SO YBADJ FIREF	PUMP 16.30	21.08	25.28	28.70	31.26	-65.25
SO YBADJ FIREF	PUMP -55.79	-44.63	-32.12	-18.63	-4.58	9.59
SO YBADJ FIREF		29.58	6.29	0.17	-5.54	-11.09
		-21.08	-25.28	-28.70	-31.26	
						65.25
SO YBADJ FIREF		44.63	32.12	18.63	4.58	-9.59
SO BUILDHGT EGEN	19.51	19.51	19.51	19.51	15.85	15.85
SO BUILDHGT EGEN	15.85	22.07	22.07	22.07	29.57	29.57
SO BUILDHGT EGEN	29.57	22.07	15.85	19.51	19.51	19.51
SO BUILDHGT EGEN	19.51	19.51	19.51	19.51	15.85	15.85
SO BUILDHGT EGEN	15.85	22.07	22.07	22.07	29.57	29.57
SO BUILDHGT EGEN	29.57	29.57	29.57	29.57	19.51	19.51
SO BUILDWID EGEN	35.93	35.15	33.30	30.44	40.90	32.78
SO BUILDWID EGEN	23.67	18.86	20.07	20.67	57.11	60.26
SO BUILDWID EGEN	61.89	16.91	59.43	34.59	34.23	35.62
SO BUILDWID EGEN	35.93	35.15	33.30	30.44	40.90	32.78
SO BUILDWID EGEN	23.67	18.86	20.07	20.67	33.74	31.22
SO BUILDWID EGEN	61.89	24.09	20.37	16.84	34.23	35.62
SO BUILDLEN EGEN	25.84	29.79	32.84	34.89	58.84	59.43
SO BUILDLEN EGEN	58.22	11.26	14.11	16.53	61.98	60.69
SO BUILDLEN EGEN	57.70	20.68	32.78	16.80	15.72	21.10
SO BUILDLEN EGEN	25.84	29.79	32.84	34.89	58.84	59.43
SO BUILDLEN EGEN	58.22	11.26	14.11	16.53	27.41	30.71
SO BUILDLEN EGEN	57.70	35.56	36.82	36.95	15.72	21.10
SO XBADJ EGEN	-56.43	-58.01	-57.83	-55.89	-56.27	-55.22
SO XBADJ EGEN	-52.50	20.12	21.42	22.07	46.79	51.60
SO XBADJ EGEN	54.84	18.06	-6.43	28.53	32.51	32.04
SO XBADJ EGEN	30.60	28.22	24.99	21.00	-2.57	-4.21
SO XBADJ EGEN	-5.72	-31.39	-35.53	-38.59	-108.78	-112.29
SO XBADJ EGEN	-112.54	-91.98	-93.09	-91.37	-48.23	-53.14
SO YBADJ EGEN	1.55	-6.03	-13.43	-20.42	-5.38	-9.96
SO YBADJ EGEN	-14.24		-13.16			
SO YBADJ EGEN	-5.36	13.35	-25.51	-23.08	-16.35	-9.09
SO YBADJ EGEN	-1.55	6.03	13.43	20.42	5.38	9.96
SO YBADJ EGEN	14.24	17.91	13.16	8.02	21.35	4.89
SO YBADJ EGEN	5.36	9.92	-3.23	-16.68	16.35	9.09
SO BUILDHGT CT1 #	53 25.91	29.57	29.57	29.57	29.57	29.57
SO BUILDHGT CT1 #		29.57	29.57	29.57	29.57	29.57
SO BUILDHGT CT1 #						
_		29.57	29.57	29.57	33.62	25.91
SO BUILDHGT CT1_#		29.57	29.57	29.57	29.57	29.57
SO BUILDHGT CT1_#		29.57	29.57	29.57	29.57	29.57
SO BUILDHGT CT1_#	53 29.57	29.57	29.57	29.57	33.62	25.91
SO BUILDWID CT1_#	53 105.73	61.98	30.71	33.23	35.57	36.82
SO BUILDWID CT1 #		36.82	36.89	35.84	33.71	31.21
SO BUILDWID CT1 #		24.11	20.41	16.88	13.97	97.86
_			30.71			
SO BUILDWID CT1_#		61.98		33.23	35.57	36.82
SO BUILDWID CT1_#		36.82	36.89	35.84	33.71	31.21
SO BUILDWID CT1_#		24.11	20.41	16.88	13.97	97.86
SO BUILDLEN CT1_#	53 102.74	57.11	31.22	28.09	24.11	20.37
SO BUILDLEN CT1_#	53 16.84	16.14	19.78	23.30	27.42	30.72
SO BUILDLEN CT1 #		35.57	36.83	36.97	3.62	93.65
SO BUILDLEN CT1 #		57.11	31.22	28.09	24.11	20.37
SO BUILDLEN CT1_#		16.14	19.78	23.30	27.42	30.72
SO BUILDLEN CT1_#		35.57	36.83	36.97	3.62	93.65
SO XBADJ CT1_#	-155.73	-22.62	-0.58	-2.24	-3.84	-45.46

CPV Towantic Energy Center	Ambient Air Quality Analysis – September 2014
APPENDIX L-C: DETAILE	D AERMOD RESULTS SUMMARY

CPV Towantic Energy, LLC - 7HA01 Combustion Turbine Emissions Data For Modeling

Parameter	Units									GE Desi	gn Cases									
Farameter	Onits	#1	#2	#3	#4	#28	#29	#35	#9	#31	#32	#11	#36	#13	#14	#16	#17	#23	#24	#22
Fuel	N/A									Natur	al Gas									
NO _x Emission Rate	g/s	2.633	2.533	3.377	2.444	1.953	1.512	2.495	2.318	1.827	1.399	1.058	2.318	2.192	2.369	2.936	2.192	1.613	1.246	1.115
CO Emission Rate	g/s	1.361	1.310	1.739	0.669	0.534	0.413	1.251	0.634	0.501	0.383	0.290	1.197	0.602	1.229	1.512	0.600	0.440	0.341	0.305
SO ₂ Emission Rate	g/s	0.611	0.588	0.782	0.565	0.458	0.354	0.585	0.543	0.431	0.328	0.249	0.543	0.516	0.556	0.686	0.514	0.378	0.293	0.262
PM ₁₀ /PM _{2.5} Emission Rate	g/s	2.520	2.457	2.570	1.226	1.158	1.104	2.558	1.215	1.144	1.090	1.050	2.407	1.201	2.533	2.268	1.200	1.116	1.072	1.056

AERMOD Impacts 5 years, 1 or 2 Turbines unit (1 or 2 g/s) emissions, ug/m3 - (GE 7H) 150 ft separate stacks Worst Case over range of years 2008-2012

Updated for final site configuration 8-20-14 (TR)

008-2012																				
Annual (ma	x)	0.05066	0.04823	0.02684	0.04584	0.06059	0.08489	0.0579	0.0543	0.06822	0.08872	0.13981	0.05748	0.05226	0.05186	0.03059	0.0502	0.06516	0.09056	0.11457
1-hour		6.5498	6.50293	4.1037	6.41783	7.28093	7.94908	6.91786	6.8286	7.51179	8.00134	9.80406	7.10237	6.90103	6.89171	4.3138	6.86162	7.58315	8.10924	8.71551
3-hour		2.76245	2.68733	1.54833	2.59023	3.85117	4.94601	3.3054	3.21334	4.2387	5.06142	8.02324	3.54274	3.27144	3.26043	1.8276	3.19513	4.29116	5.22557	6.85123
8-hour		1.73652	1.67545	1.0506	1.61473	2.26178	3.81726	1.98492	1.8898	2.69513	4.03771	6.4954	2.04671	1.87147	1.85966	1.3004	1.81048	2.69384	4.30997	5.55727
24-hour - H	1H	0.65878	0.61316	0.45169	0.5689	1.02429	1.73011	0.86347	0.79463	1.25453	1.82628	3.31078	0.92398	0.7792	0.76906	0.58705	0.73643	1.22636	1.91797	2.62758
24-hour - H2	2H	0.60629	0.57725	0.33763	0.55498	0.80913	1.40654	0.71984	0.67807	0.96614	1.49118	2.67171	0.74186	0.6684	0.66362	0.42904	0.64067	0.95475	1.58713	2.16161

AERMOD Scaled Pollutant Impacts 1 or 2 Turbines, ug/m3 - GE 7H 150ft Separate Stacks

Updated for final site configuration 8-20-14 (TR)

NO2	Annual	0.13	0.12	0.09	0.11	0.12	0.13	0.14	0.13	0.12	0.12	0.15	0.13	0.11	0.12	0.09	0.11	0.11	0.11	0.13
	1-hr	17.25	16.47	13.86	15.69	14.22	12.02	17.26	15.83	13.72	11.19	10.38	16.47	15.13	16.33	12.66	15.04	12.23	10.11	9.72
CO	1-hr	8.91	8.52	7.14	4.29	3.89	3.29	8.66	4.33	3.77	3.06	2.84	8.50	4.16	8.47	6.52	4.12	3.33	2.77	2.66
	8-hr	2.36	2.20	1.83	1.08	1.21	1.58	2.48	1.20	1.35	1.55	1.88	2.45	1.13	2.28	1.97	1.09	1.18	1.47	1.69
SO2	Annual	0.0309	0.0284	0.0210	0.0259	0.0278	0.0300	0.0339	0.0295	0.0294	0.0291	0.0349	0.0312	0.0269	0.0289	0.0210	0.0258	0.0246	0.0266	0.0300
	1-hr	4.00	3.82	3.21	3.63	3.34	2.81	4.05	3.71	3.24	2.63	2.45	3.86	3.56	3.83	2.96	3.53	2.87	2.38	2.28
	3-hr	1.69	1.58	1.21	1.46	1.76	1.75	1.93	1.74	1.83	1.66	2.00	1.92	1.69	1.81	1.25	1.64	1.62	1.53	1.79
	24-hr	0.40	0.36	0.35	0.32	0.47	0.61	0.51	0.43	0.54	0.60	0.83	0.50	0.40	0.43	0.40	0.38	0.46	0.56	0.69
PM	Annual	0.13	0.12	0.07	0.06	0.07	0.09	0.15	0.07	0.08	0.10	0.15	0.14	0.06	0.13	0.07	0.06	0.07	0.10	0.12
	24-hr H1H	1.66	1.51	1.16	0.70	1.19	1.91	2.21	0.97	1.44	1.99	3.47	2.22	0.94	1.95	1.33	0.88	1.37	2.06	2.77
	24-hr H2H	1.53	1.42	0.87	0.68	0.94	1.55	1.84	0.82	1.11	1.63	2.80	1.79	0.80	1.68	0.97	0.77	1.07	1.70	2.28
PM	Annual (5yrAv)	0.091	0.084	0.049	0.040	0.052	0.078	0.106	0.047	0.060	0.081	0.130	0.099	0.045	0.094	0.053	0.043	0.057	0.081	0.105
	24-hr (H1H 5yrAv)	1.200	1.110	0.744	0.524	0.826	1.453	1.518	0.663	1.018	1.522	2.551	1.537	0.652	1.365	0.905	0.623	0.981	1.577	2.093
	24-hr (H8H 5yrAv)	0.632	0.586	0.357	0.277	0.374	0.558	0.746	0.329	0.429	0.579	1.017	0.726	0.319	0.667	0.386	0.301	0.413	0.587	0.802
NO2	1-hr (H1H 5yrAv)	6.600	6.193	5.587	5.748	7.008	8.493	7.653	6.760	8.072	8.125	8.903	7.360	6.451	6.807	6.470	6.200	7.313	7.391	8.127
	1-hr (H8H 5yrAv)	3.361	3.101	2.336	2.848	3.032	3.866	3.578	3.154	3.398	3.867	5.556	3.310	2.883	3.095	2.598	2.781	2.943	3.643	4.703

CPV Towantic Energy, LLC - 7HA01 Combustion Turbine Emissions Data For Modeling

Parameter	Units					GE	Design Ca	ses					
Parameter	Onits	#37	#46	#47	#38	#41	#52	#53	#42	#43	#44	#51	#45
Fuel	N/A					D	istillate O	il					
NO _x Emission Rate	g/s	6.552	5.859	5.254	4.032	6.199	4.901	3.780	5.771	5.746	5.368	4.322	3.352
CO Emission Rate	g/s	1.600	1.424	1.273	0.982	1.512	1.194	0.921	1.411	1.399	1.310	1.051	0.816
SO ₂ Emission Rate	g/s	0.620	0.620	0.497	0.383	0.587	0.464	0.358	0.547	0.544	0.508	0.408	0.318
PM ₁₀ /PM _{2.5} Emission Rate	g/s	5.368	5.368	5.292	5.242	5.342	5.279	5.229	5.330	5.317	5.305	5.254	5.204

AERMOD Impacts 5 years, 1 or 2 Turbines unit (1 or 2 g/s) emissions, ug/m3 - (GE 7H) 150 ft separate stacks

Worst Case over range of years 2008-2012

Annual (max)	0.02674	0.01389	0.03727	0.04898	0.02858	0.04042	0.05417	0.0306	0.02952	0.0333	0.04411	0.05596
1-hour	5.53318	3.70456	6.64745	7.41359	5.71663	6.84434	7.64872	5.99823	5.91216	6.27664	7.17392	7.78879
3-hour	1.86528	1.28083	2.75688	3.82199	1.93199	3.05084	4.1662	2.03443	2.00288	2.33507	3.5249	4.34251
8-hour	0.96586	0.49385	1.45057	1.97352	1.06318	1.5745	2.41459	1.1726	1.14374	1.2875	1.7569	2.67515
24-hour - H1H	0.32325	0.1649	0.49372	0.87528	0.35584	0.57393	1.07071	0.39389	0.38351	0.4342	0.70156	1.16371
24-hour - H2H	0.25124	0.13899	0.441	0.69882	0.27616	0.51592	0.8193	0.30025	0.27514	0.34318	0.61345	0.91896

AERMOD Scaled Pollutant Impacts 1 or 2 Turbines, ug/m3 - GE 7H 150ft Separate Stacks

NO2	Annual	0.18	0.08	0.20	0.197	0.18	0.198	0.205	0.18	0.170	0.179	0.191	0.188
	1-hr	36.25	21.71	34.93	29.89	35.44	33.55	28.91	34.61	33.97	33.69	31.00	26.10
CO	1-hr	8.85	5.27	8.46	7.28	8.64	8.18	7.04	8.46	8.27	8.22	7.54	6.36
	8-hr	1.55	0.70	1.85	1.94	1.61	1.88	2.22	1.65	1.60	1.69	1.85	2.18
SO2	Annual	0.0166	0.0086	0.0185	0.0187	0.0168	0.0188	0.0194	0.0167	0.0161	0.0169	0.0180	0.0178
002	1-hr	3.43	2.30	3.3068	2.8360	3.3537	3.1770		3.28	3.22	3.19	2.93	2.47
	3-hr	1.16	0.79	1.37	1.46	1.13	1.42	1.49	1.11	1.09	1.19	1.44	1.38
	24-hr	0.20	0.10	0.25	0.3348	0.2088	0.2664	0.3837	0.22	0.21	0.22	0.29	0.37
PM	Annual	0.14	0.07	0.20	0.26	0.15	0.21	0.283	0.16	0.16	0.18	0.23	0.291
	24-hr H1H	1.74	0.89	2.61	4.59	1.90	3.03	5.60	2.10	2.04	2.30	3.69	6.06
	24-hr H2H	1.35	0.75	2.33	3.66	1.48	2.72	4.28	1.60	1.46	1.82	3.22	4.78
PM	Annual (5yrAv)	0.097	0.050	0.137	0.188	0.104	0.150	0.217	0.112	0.107	0.120	0.166	0.229
	24-hr (H1H 5yrAv)	1.177	0.709	1.960	3.062	1.290	2.243	3.803	1.421	1.351	1.863	2.432	4.210
	24-hr (H8H 5yrAv)	0.691	0.358	0.957	1.376	0.736	1.045	1.580	0.789	0.756	0.843	1.156	1.672
NO2	1-hr (H1H 5yrAv)	10.590	5.743	11.618	14.509	10.443	11.634	15.285	10.240	9.990	9.680	12.610	14.739
	1-hr (H8H 5yrAv)	4.567	2.062	5.033	5.162	4.580	5.085	5.641	4.549	4.370	4.359	4.851	5.363

CPV Towantic Energy Center - Detailed Results table

Pollutant	Averaging Period	Rank for SIL Assessment	Max Impact (µg/m³)	•	ct Receptor cation	Max Impact Date	Elevation (m)	Worst Case Turbine	SIL (µg/m³)	NAAQS (µg/m³)	PSD Class II Increment
	i eriou	Assessment	(μg/111')	UTM-E (m)	UTM-N (m)	(YRMODYHR)	(111)	Load		(µg/iii·)	(µg/m³)
NO2	1-hour	H1H (5-year Average)	12.91	656680.7	4594393	5-year average	261.59	2 O Start	7.5	188	NA
	Annual	H1H	1.390	656859.5	4594221.4	2008	250.7	53	1	100	25
CO	1-hour	H1H	301.945	656900	4594450	09120307	256.63	2 G Start	2000	40000	NA
66	8-hour	H1H	176.262	657050	4593950	09022308	212.65	2 G Start	500	10000	NA
PM10	24-hour	H1H	4.24	656852	4594245.9	11110324	252.27	45	5	150	30
FINITO	Annual	H1H	0.29	657100	4594350	2012	271.26	45	1	NA	17
PM2.5 (NAAQS)	24-hour	H1H (5-year Average)	3.47	656852	4594245.9	5-year average	252.27	45	1.2	35	NA
FIVIZ.3 (NAAQ3)	Annual	H1H (5-year Average)	0.21	657200	4594350	5-year average	255.63	45	0.3	12	NA
PM2.5 (PSD)	24-hour	H1H	4.24	656852	4594245.9	11110324	252.27	45	1.2	NA	9
PW2.5 (P3D)	Annual	H1H	0.29	657100	4594350	2012	271.26	45	0.3	NA	4
	1-hour	H1H (5-year Average)	2.67	656950	4594500	5-year average	259.91	2 G Start	7.8	196	NA
SO2	3-hour	H1H	1.36	657050	4593950	11021503	212.65	11	25	1300	512
	24-hour	H1H	0.49	657150	4593900	09022324	217.68	11	5	365	91
	Annual	H1H	0.03	657150	4594350	2012	265.35	35	1	80	20

CPV Towantic Energy Center - Cumulative Impacts

CFV Towartic Energy Center -	Averaging	Rank for SIL	Cumulative	Project	Ambient	Total Impact w/	•	t Receptor	Max Impact Date	Elevation	NAAQS	PSD Class II
Pollutant	Period	Assessment	Impact (µg/m³)	Impact	Background (μg/m³)	Background (μg/m³)	UTM-E (m)	UTM-N (m)	(YRMODYHR)	(m)	(µg/m³)	Increment (µg/m³)
NO2 (NAAQS)	1-hour	H1H (5-year Average)	81.81	12.03	87.00	168.81	656708.9	4594416.4	5-year average	263.46	188.00	NA
	Annual	H1H	1.87	1.39	21.00	22.87	656950	4594400	2011	256.46	100.00	NA
NO2 (PSD)	Annual	H1H	2.38	1.39	NA	2.38	657000	4594400	2008	264.45	NA	25
PM2.5 (NAAQS)	24-hour	H1H (5-year Average)	3.47	3.47	24.00	27.47	656852	4594245.9	5-year average	252.27	35.00	NA
PM2.5 (PSD)	24-hour	H1H	4.24	4.24	NA	4.24	656852	4594245.9	11110324	252.27	NA	9

Note: Cumulative impacts reported for all pollutants and averaging periods for which the project has a significant impact.

CPV Towantic Energy Center	Ambient Air Quality Analysis – September 2014
ADDENDIA D. BACKCOO	UND INVENTORY COURCE DATA
APPENDIX L-D: BACKGRO	UND INVENTORY SOURCE DATA

Towantic Energy Center – Background Source Inventory for Cumulative Modeling Assessment

As described Section 3.11, the proposed Project has significant predicted impact concentrations for 1-hour NO_2 , 24-hour $PM_{2.5}$, and 24-hour PM_{10} . Therefore, cumulative modeling with other regional sources has been conducted. The source inventory was based on the DEEP Radius Search Tool for 2008 Air Emissions Inventory Data, provided by DEEP. The Radius Search Tool was used to determine the potential inventory of sources located within 50 km of the project. DEEP guidance, based on distance and actual annual emissions levels, was used to determine the final set of inventory sources for the cumulative modeling assessment. The CTDEEP guidance criteria for background source selection is summarized below:

For NAAQS modeling:

- All stacks with actual emissions of > 15 tons per year (TPY) of a given pollutant that fall
 within the radius of significance of the subject source for that pollutant;
- All stacks with actual emissions of ≥ 50 TPY that fall within 20 km of the subject source;
 and
- All stacks with actual emissions of ≥ 500 TPY that fall within 50 km of the subject source.

All sources retrieved above should be modeled at their allowable emission rate for all short term averaging times. Sources can be modeled at their actual emission rates for annual average modeling.

· For PSD increment tracking:

- All sources affecting PSD increment (defined in RCSA sections 22a-174-3a(k)(5) and 22a-174-3a(k)(6)) that fall within the radius of significance of the subject source for the applicable pollutant;
- All sources affecting PSD increment with actual stack emissions of ≥ 50 TPY that fall within 20 km of the subject source; and
- All sources affecting PSD increment with actual stack emissions of ≥ 500 TPY that fall within 50 km of the subject source.

Only one NO_X source met the CTDEEP criteria for inclusion in the cumulative NO2 NAAQS analysis. Three (3) additional sources met the criteria for the annual NO2 PSD increment analysis. No inventory sources of PM met the criteria for inclusion in the cumulative modeling assessment for $PM_{10}/PM_{2.5}$ NAAQS compliance. However, three (3) sources did meet the criteria for the PSD PM_{10} increment analysis. Note that there is no increment for 1-hour NO_2 , and that the baseline date has not yet been triggered for $PM_{2.5}$, but will be with the Project. The background sources modeled cumulatively with the project are:

NO_x Sources:

- Bridgeport Harbor Generating Station, Bridgeport, Connecticut
 - o Generator #3 Actual NO_x = 2,111.9 tpy, Distance from Project = 35.2 km (NAAQS and PSD)
- Algonquin Gas Transmission, Oxford, Connecticut
 - Turbine #1 Actual $NO_x = 1.1$ tpy, Distance from Project = 0.112 km (PSD only)
 - Turbine #2 Actual NO_x = 0.3 tpy, Distance from Project = 0.112 km (PSD only)

■ Turbine #3 – Actual NO_x = 0.2 tpy, Distance from Project = 0.112 km (PSD only)

PM₁₀ Sources:

- Algonquin Gas Transmission, Oxford, Connecticut
 - Turbine #1 Actual $NO_x = 0.1$ tpy, Distance from Project = 0.112 km (PSD only)
 - Turbine #2 Actual NO_x = 0.0 tpy, Distance from Project = 0.112 km (PSD only)
 - Turbine #3 Actual $NO_x = 0.0$ tpy, Distance from Project = 0.112 km (PSD only)

Modeled Sou	ırce Param	ters for the	Backgroun	d Inventory	/ Sources -	Oxford, CT	-			
Facility	Source ID	Easting (X)	Northing (Y)	Base Elevation	Stack Height	Temperature	Exit Velocity	Stack Diameter	PM10	NOx
		(m)	(m)	(m)	(m)	(K)	(m/s)	(m)	(g/s)	(g/s)
Bridgeport Harbor Station	Generator #3	652300	4559199	3.048	151.7904	416.48	38.775341	4.2672	NA	358.3
Algonquin	Turbine 1	656921	4594340.8	251.46	11.5824	757.04	25.812827	2.1336	0.0978	0.469
Compressor Station,	Turbine 2	656957.1	4594351.1	251.46	11.5824	757.04	25.812827	2.1336	0.0978	0.469
Oxford, CT	Turbine 3	656935.2	4594349.5	251.46	12.192	780.93	46.4499653	1.1582	0.0978	0.469

Note: Location coordinates and base elevations provided in the CTDEEP for Algonquin Compressor Station sources were incorrect and are corrected here.

CTDEEP Radius Search Tool Results for the Towantic Energy Center (Selected Sources Only - full report provided with electronic modeling files)

					Permit Issue	Stack	Stack	Stack	Stack	Stack	Stack	Source	Source	UTM_	Distance from	Allowable	Actual	Allowable	Actual
Facility Name	Facility Town	Facility Street	Description	Startup Date	Date	Number	Height	Diameter	Temp	Flow	Elevation	UTMx	UTMy	Zone	Centroid	NOx	NOx	PM10	PM10
ALGONQUIN GAS TRANSMISSION LLC	OXFORD	40 WOODRUFF	SOLAR MARS 100-	10/1/2008	12/27/2006	1	38	7	903	195550	200	656.80003	4594.2988	18	0.144	16.3	1.1	3.4	0.1
ALGONQUIN GAS TRANSMISSION LLC	OXFORD	40 WOODRUFF	SOLAR MARS 100-	10/1/2008	12/27/2006	1	38	7	903	195550	200	656.80003	4594.2988	18	0.144	16.3	0.3	3.4	0
ALGONQUIN GAS TRANSMISSION LLC	OXFORD	40 WOODRUFF	SOLAR TAURUS 60-	10/1/2008	12/27/2006	3	40	3.8	946	103700	200	656.80003	4594.2988	18	0.144	16.3	0.2	3.4	0
PSEG PWR CT LLC/BPT HARBOR STA	BRIDGEPORT	1 ATLANTIC ST	C.E. STEAM	8/1/1968	5/10/1985	3	498	14	290	1E+06	10	652.30003	4559.199	18	35.244	12456.7	2111.9	0	32.1

CPV Towantic Energy Cer	iter
-------------------------	------

Ambient Air Quality Analysis - September 2014

APPENDIX L-E: VISCREEN ANALYSIS

Visual Effects Screening Analysis for Source: Towantic Energy Center Class I Area: Lye Brook NWA

*** Level-1 Screening ***

Input Emissions for

Particulates 85.20 LB /HR
NOx (as NO2) 104.00 LB /HR
Primary NO2 0.00 LB /HR
Soot 0.00 LB /HR
Primary SO4 0.00 LB /HR

**** Default Particle Characteristics Assumed

Transport Scenario Specifications:

Background Ozone: 0.04 ppm
Background Visual Range: 40.00 km
Source-Observer Distance: 175.00 km
Min. Source-Class I Distance: 175.00 km
Max. Source-Class I Distance: 185.00 km
Plume-Source-Observer Angle: 11.25 degrees

Stability: 6

Wind Speed: 1.00 m/s

 $\texttt{R} \;\; \texttt{E} \;\; \texttt{S} \;\; \texttt{U} \;\; \texttt{L} \;\; \texttt{T} \;\; \texttt{S}$

Asterisks (*) indicate plume impacts that exceed screening criteria

Maximum Visual Impacts INSIDE Class I Area Screening Criteria ARE NOT Exceeded

					Deli	ta E	Contrast		
							=====		
Backgrnd	Theta	Azi	Distance	Alpha	Crit	Plume	Crit	Plume	
	=====	===	======	=====	====	=====	====	=====	
SKY	10.	84.	175.0	84.	2.00	0.032	0.05	0.000	
SKY	140.	84.	175.0	84.	2.00	0.005	0.05	0.000	
TERRAIN	10.	84.	175.0	84.	2.00	0.002	0.05	0.000	
TERRAIN	140.	84.	175.0	84.	2.00	0.001	0.05	0.000	

Maximum Visual Impacts OUTSIDE Class I Area Screening Criteria ARE NOT Exceeded

					Del	ta E	Contrast		
					=====	=====	=====		
Backgrnd	Theta	Azi	Distance	Alpha	Crit	Plume	Crit	Plume	
	=====	===	======	=====	====	=====	====	=====	
SKY	10.	70.	166.4	99.	2.00	0.034	0.05	0.000	
SKY	140.	70.	166.4	99.	2.00	0.005	0.05	0.000	
TERRAIN	10.	65.	163.3	104.	2.00	0.003	0.05	0.000	
TERRAIN	140.	65.	163.3	104.	2.00	0.001	0.05	0.000	

APPENDIX L-F: DETAILED CALCULATIONS FOR IMPACTS TO SOILS AND VEGETATION

Towantic - Soils and Vegetation Impacts

Screening Conc for Exposure

								·	•	
Trace Element	Annual Conc (ug/m3)	Deposited Conc (ppmw)	Avg. Soil Conc (ppmw)	Percent Increase	Soil Concentra tion Ratio	Tissue Conc	Soil	Percent of Soil Conc	Tissue	Percent of Tissue Conc
Arsenic	2.93E-05	8.39E-03	6	0.14	0.14	1.17E-03	3	0.3%	0.25	0.5%
Beryllium	3.70E-06	1.06E-03	6	0.02	NA	NA	NA	NA	NA	NA
Boron	NA	NA	10		5.3	NA	0.5	NA	11	NA
Cadmium	1.08E-04	3.10E-02	0.06	51.66	10.7	3.32E-01	2.5	1.2%	3	11.1%
Chromium	2.20E-04	6.32E-02	100	0.06	0.02	1.26E-03	8.4	0.8%	1	0.1%
Cobalt	6.06E-06	1.74E-03	8	0.02	0.11	1.91E-04	NA	NA	19	0.0%
Copper	NA	NA	20	NA	0.47	NA	40	NA	0.73	NA
Fluoride	NA	NA	200	NA	0.03	NA	400	NA	310	NA
Lead	1.66E-04	4.77E-02	10	0.48	0.45	2.15E-02	1000	0.0%	126	0.0%
Manganese	7.75E-03	2.22E+00	850	0.26	0.066	1.47E-01	2.5	88.8%	400	0.0%
Mercury	2.57E-05	7.36E-03	0.1	7.36	0.5	3.68E-03	455	0.0%	NA	NA
Nickel	1.66E-04	4.76E-02	40	0.12	0.045	2.14E-03	500	0.0%	60	0.0%
Selenium	2.47E-04	7.07E-02	0.5	14.14	1	7.07E-02	13	0.5%	100	0.1%
Vanadium	NA	NA	100	NA	0.01	NA	2.5	NA	NA	NA
Zinc	NA	NA	50	NA	0.64	NA	NA	NA	300	NA

ATTACHMENT M – APPLICANT COMPLIANCE INFORMATION

Provided on the following pages is a completed Applicant Compliance Information form (DEEP-APP-002).





Connecticut Department of Energy & Environmental Protection

Applicant Compliance Information

	DEEP ONLY	
App. No		_
Co./Ind. No.		_

	Applicant Name: CPV Towantic, LLC Mailing Address: 50 Braintree Hill Office Park, Suite 300							
	City/Town: Braintree			,		State: MA		Zip Code: 02184
	Business Phone: 781-848-3	8611				ext.:		•
	Contact Person: Andrew B	azine	et			Phone: 781 -	-848-36	11 ext.
	*E-mail: abazinet@cpv.cor	m						
	If you answer <i>yes</i> to any of the questions below, you must complete the Table of Enforcement Actions on the reverse side of this sheet as directed in the instructions for your permit application.							
A.	A. During the five years immediately preceding submission of this application, has the applicant been convicted in any jurisdiction of a criminal violation of any environmental law?							
			Yes	\boxtimes	No			
В.	B. During the five years immediately preceding submission of this application, has a civil penalty been imposed upon the applicant in any state, including Connecticut, or federal judicial proceeding for any violation of an environmental law?							
			Yes	\boxtimes	No			
C.	During the five years immed five thousand dollars been i administrative proceeding for	mpos	sed on the	applic	cant i	n any state, i	includin	n, has a civil penalty exceeding g Connecticut, or federal
			Yes	\boxtimes	No			
D.	D. During the five years immediately preceding submission of this application, has any state, including Connecticut, or federal court issued any order or entered any judgement to the applicant concerning a violation of any environmental law?							
			Yes	\boxtimes	No)		
E.	E. During the five years immediately preceding submission of this application, has any state, including Connecticut, or federal administrative agency issued any order to the applicant concerning a violation of any environmental law?							
			Yes	\boxtimes	No			

Table of Enforcement Actions

(1) Type of Action	(2a) Date Commenced	(2b) Date Terminated	(3) Jurisdiction	(4) Case/Docket/ Order No.	(5) Description of Violation
		N.			

[☐] Check the box if additional sheets are attached. Copies of this form may be duplicated for additional space.

ATTACHMENT N - MARKED UP PERMIT

Provided on the following pages is a completed markup of Town-Permit Number 144-0011 issued to Towantic Energy LLC on December 7, 2004 and later modified on June 1, 2010. Proposed modifications consistent with the current application are provided.





STATE OF CONNECTICUT

DEPARTMENT OF ENERGY & ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

NEW SOURCE REVIEW PERMIT TO CONSTRUCT AND OPERATE A STATIONARY SOURCE

Issued pursuant to Title 22a of the Connecticut General Statutes (CGS) and Section 22a-174-3a of the Regulations of Connecticut State Agencies (RCSA). (The regulatory citations identified in the prior permit have not been verified for accuracy with current versions of the regulations for this permit markup)

Owner/Operator: CPV Towantic Energy, LLC

Address: c/o GE Energy Financial Services, Inc., 800 Long50

Braintree Hill Office Park, Suite 300

Ridge Road, Stamford, CT Braintree, MA 02184

Equipment Location: Woodruff Hill Road, Oxford, CT

Equipment Description: General Electric PG7241FA7HA.01 combustion _

turbine with DLN combustor

Town-Permit Numbers: 144-0011

Town-Premises Numbers: 144-014

Permit Issue Date: 12/07/04

Modification Issue Date: JUN 0 1 2010

Expiration Date: NONE

Amey Marrella Commissioner dune 1, 2010

STATE OF CONNECTICUT, DEPARTMENT OF ENERGY & ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

This permit specifies necessary terms and conditions for the operation of this equipment to comply with state and federal air quality standards. The Permittee shall at all times comply with the terms and conditions stated herein.

PART I. DESIGN SPECIFICATIONS

A. General Description

CPV Towantic Energy, LLC operates a power generation facility consisting
of two (2) General Electric PG7241FA (GE7FA)7HA.01 combustion turbines
with acombined combined nominal gross output of 550805 MW in Oxford, CT.
 The two turbines are dual fuel fired combined cycle units with heat
recovery steam generators (HRSGs) to power a single steam turbine
generator. Supplemental firing (Duct Firing) of the HRSGs with natural
gas is conducted during periods of peak demand.

B. Equipment Design Specifications

1. Turbine

TBD

- a. Maximum Fuel Firing Rate(s): $\frac{1,710,160}{2,457,534}$ ft³/hr (gas); $\frac{13,921}{18,290}$ gallons/hr (oil)
- b. Maximum Gross Heat Input (MMBTU/hr): $\frac{1,748}{2,526}$ (gas); $\frac{1,942}{2,524}$ (oil)
- 2. Duct Firing
 - a. Maximum Fuel Firing Rate(s): 935,895 ft³/hr (gas);
 - b. Maximum Gross Heat Input (MMBTU/hr): 962

C. Control Equipment Design Specifications

- 1. Water Injection: NOx inlet concentration to SCR unit \leq 42 ppmvd @ 15% O₂ (only when burning distillate oil)
- 2. Low NOx Burner: NOx inlet concentration to SCR unit ≤ 9 ppmvd @ 15% O_2 (only when burning natural gas)
 - a. Make and Model:

3. Selective Catalytic Reduction (SCR): NOx emission to atmosphere ≤ 2 ppmvd@ 15% O_2 when burning gas and ≤ 5.90 ppmvd@ 15% O_2 when burning distillate oil

a. Make and Model: TBD

Oxidation Catalyst: CO emissions to atmosphere $\le 0.9 \le 2$ ppmvd @ 15% O_2 for all fuels burned on gas without Duct Firing, ≤ 1.7 ppmvd @ 15% O_2

on gas with Duct Firing and ≤ 2.0 ppmvd @ 15% 0_2 on distillate oil

a. Make and Model: TBD

b. Catalyst Type: TBD
FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART I. DESIGN SPECIFICATIONS, cont.

D. Stack Parameters

- 1. Minimum Stack Height (ft): 150 (above base elevation)
- 2. Minimum Exhaust Gas Flow Rate (acfm): $\frac{990,000}{663,327}$ (gas); $\frac{1.15 \times 10^6}{10^6}$ (oil)
- Stack Exit Temperature (°F): ≥206170
- 4. Minimum Distance from Stack to Nearest Property Line (ft): 165188

PART II. OPERATIONAL CONDITIONS

A. Turbine

- 1. Fuel Type(s): Natural Gas; Distillate Fuel Oil
- 2. Maximum Fuel Consumption over any Consecutive 12 Month Period: $\frac{1.46292}{2.15} \times 10^{10} \text{ ft}^3 \text{ (gas); } \frac{9.6}{1.3} \times \frac{10^6}{10^7} \text{ gallons (oil)}$
- 3. Distillate Fuel Oil Sulfur Content (% by weight, dry basis): 0.0015

B. Duct Burner

- 1. Fuel Type(s): Natural Gas
- 2. Maximum Fuel Consumption over any Consecutive 12 Month Period: 3.98 x 109 ft3 (gas);

PART III. CONTINUOUS EMISSION MONITORING REQUIREMENTS AN ASSOCIATED EMISSION LIMITS

The Permittee shall comply with the CEM requirements as set forth in RCSA \$22a-174-4, RCSA \$22a-174-22, 40 CFR 60 Subpart KKKK and 40 CFR Parts 72-78, if applicable. CEM shall be required for the following pollutant/operational parameters and enforced on the following basis:

Pollutant/Operational Parameter	Averaging Times	Emission Limit
Turbine Output	continuous	See Part ^V
Fuel Flow	continuous	See Part I
Exhaust Flow Rate	continuous	See Part I
Opacity	six minute block	10%
NOx	1 hour block	See Part VI
CO	1 hour block	See Part VI
02	1 hour block	None ¹
Humidity	1 hour block	None ¹
Ammonia	1 hour block	See Part VI

Note (1): Parameter to be monitored is not limited by conditions of this permit. Monitoring is required solely to provide basis for correction of actual exhaust gas conditions to dry conditions @ 15% O₂ by volume.

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART IV. MONITORING, RECORD KEEPING AND REPORTING REQUIREMENTS

A. Monitoring

- 1. The Permittee shall use a non-resettable totalizing fuel metering device or a billing meter to continuously monitor fuel feed to this permitted source.
- 2. The Permittee shall continuously monitor and continuously record the SCR aqueous ammonia injection rate (lb/hr), operating temperature (°F) and pressure drop (inches of water) across the catalyst bed. The Permittee shall maintain these parameters within the ranges recommended by the manufacturer to achieve compliance with the emission limits in this permit.
- 3. The Permittee shall continuously monitor and continuously record the oxidation catalyst inlet temperature (°F). The Permittee shall maintain this parameter within the ranges recommended by the manufacturer to achieve compliance with the emission limits in this permit.
- 4. The Permittee shall inspect the SCR and oxidation catalysts once per year at a minimum or more frequently if recommended by the manufacturer.
- 5. The permittee comply with the monitoring requirements of 40 CFR 60.4335 and RCSA 22a-174-22(k).

B. Record Keeping

- 1. The Permittee shall keep records of monthly and consecutive 12 month fuel consumption (for each fuel). The consecutive 12 month fuel consumption shall be determined by adding (for each fuel) the current month's fuel usage to that of the previous 11 months. The Permittee shall make these calculations within 30 days of the end of the previous month.
- 2. The Permittee shall keep records of the fuel certification for each delivery of fuel from a bulk petroleum provider or a copy of the current contract with the fuel supplier supplying the fuel used by the equipment that includes the applicable sulfur content of the fuel as a condition of each shipment. The shipping receipt or contract shall include:
 - a. date of delivery,
 - b. name of the fuel supplier,
 - c. type of fuel delivered,

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine

with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART IV. MONITORING, RECORD KEEPING AND REPORTING REQUIREMENTS, cont.

- d. percentage of sulfur in such fuel, by weight, dry basis, and
- e. the method used to determine the sulfur content of such fuel.
- 3. The Permittee shall record operating hours for each calendar month and for each period of twelve (12) consecutive calendar months. Such records shall include the dates of the recording period and the total quantity of hours of operation of the turbine during the recording period.
- 4. Compliance with the emissions limits of Part VI of this permit shall be determined by means of CEM systems, where applicable. Otherwise, periodic stack emissions testing, parametric monitoring and periodic record keeping shall be used to demonstrate compliance with the emissions limits of Part VI of this permit.
- 5. The Permittee shall calculate and record the monthly and consecutive $12 \text{ month } PM_{10}, PM_{2.5}, SO_2, NO_x$, CO, and VOC emissions in units of tons. The consecutive $12 \text{ month emissions } \text{shall be determined by adding (for each pollutant) the current month's emissions to that of the previous <math>11 \text{ months}$. Such records shall include a sample calculation for each pollutant. The Permittee shall make these calculations on or before the 15 th day of each calendar month.
 - a. For each Criteria Pollutant monitored by CEM system, emissions shall be calculated based on the actual, uncorrected measured emissions concentrations and actual, uncorrected exhaust gas measured fuel flowrate measured by the CEM systems.
 - b. For each Criteria Pollutant that is not monitored by CEM system, emissions shall be calculated according to the following formulas:

 $\text{ME}_{\text{cp,gas}} = [\Sigma (\text{ERss,gas*Hiss,gasl} + \Sigma (\text{ERsu,gas*Nsu,gasl} + \Sigma (\text{ERso,gas*Nso,gas})]/2000]$

 $\text{ME}_{\text{CD, oil}} = [\Sigma (\text{ERss,ou*Hiss,oil}) + \Sigma (\text{ERsu,ou*Nsu,ou}) + \Sigma (\text{ERso,oil*Nso,ou})]/2000$

 $ME_{cp} = ME_{cp, qas} + ME_{cp, oil}$

Where:

 $\text{ME}_{\text{cp}}\text{=}\text{the}$ total monthly emissions of criteria pollutant (tons per month) $\text{ME}_{\text{cp},\text{oil}}\text{=}$ monthly emissions of criteria pollutant from burning distillate oil (tons per month)

 $\text{ME}_{\text{cp,gas}}$ = monthly emissions of criteria pollutant from burning natural gas (tons per month)

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA) 7HA.01 combustion turbine

with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART IV. MONITORING, RECORD KEEPING AND REPORTING REQUIREMENTS, cont.

ERss, gas = applicable #/mmbtuMMBtu emission rate contained in Part VI.A.1 of this Permit

ERss, oil = applicable #/mmbtuMMBtu emission rate contained in Part VI.A.2 of this Permit

 ${\tt Hiss,gas} = {\tt total}$ heat input (${\tt mmbtu}{\tt MMBtu}$) from burning natural gas at steady-state during the month

Hiss, ou = total heat input (mmbtuMMBtu) from burning distillate oil at steady-state during the month

 ${\sf ERsu,gas} = {\sf natural}$ gas startup emission factor determined during initial stack tests

 ${\sf ERsu,ou} = {\sf distillate}$ oil startup emission factor determined during initial stack tests

Nsu,gas = number of natural gas startups occurring during the month
Nsu,oil = number of distillate oil startups occurring during the month
ERsd,gas = natural gas shutdown emission factor determined during initial
stack tests

Nsd,gas = number of natural gas shutdowns occurring during the month Nsd,oil. = number of distillate oil shutdowns occurring during the month

- 6. The Permittee shall keep records of the emissions of this turbine during the shakedown period. Emissions during shakedown shall be calculated using good engineering judgment and the best data and methodology available for estimating such emissions. Emissions during shakedown shall be counted towards the source's annual emission limitation in Part VI.C of this permit.
- 7. The Permittee shall calculate and record the monthly emissions from these premises of each Hazardous Air Pollutant listed in Subsection 112(b) of the Clean Air Act. Such records shall include the recording period, the name of each Hazardous Air Pollutant emitted, and the quantity (expressed in units of tons) of each Hazardous Air Pollutant emitted during the calendar month. Emission rates of Hazardous Air Pollutants shall be based upon initial and periodic stack emissions testing as required in accordance with Part VII of this permit.

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PC7241 (FA) 7HA.01 combustion turbine

with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART IV. MONITORING, RECORD KEEPING AND REPORTING REQUIREMENTS, cont.

- 8. The Permittee shall keep records of startup and shutdown events. Such records shall contain the following information:
 - a. date and time of startup or shutdown event,
 - b. fuel being used during startup or shutdown event,
 - c. duration of startup or shutdown event,
 - d. type of startup or shutdown event,
 - e. total NOx, VOC and CO emissions emitted (lb) during the startup or shutdown event.
- 9. The Permittee shall keep records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of the stationary gas turbine; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative. [40 CFR §60.7(b)]
- 10. The Permittee shall record all exceedances of any emission limits or deviations from manufacturer recommended operating parameters contained in this permit. Such records shall include the following for each exceedance or deviation:
 - a. the date and time,
 - b. a detailed description, and
 - c. the duration.
- 11. The Permittee shall keep records of each delivery of aqueous ammonia. The records shall include the date of delivery, the name of the supplier, the quantity of aqueous ammonia delivered, and the percentage of ammonia in solution, by weight.
- 12. The Permittee shall keep records of the inspection and maintenance of the SCR and oxidation catalysts. The records shall include the name of the person, the date, the results or actions and the date the catalyst is replaced.
- 13. The Permittee shall provide the Town of Oxford with a copy of the results of the quarterly Continuous Emissions Monitoring reports required by this permit. The Permittee shall provide the reports contemporaneous with their submission to the <a href="https://documents.org/leaf-action/leaf-action-leaf-a
- 14. The Permittee shall keep a certified copy of this permit on the premises at all times, and shall make this copy available upon request of the Commissioner for the duration of this permit. This copy shall also be available for public inspection during regular business hours.

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine

with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART IV. MONITORING, RECORD KEEPING AND REPORTING REQUIREMENTS, cont.

15. The Permittee shall keep all records required by this permit for a period of no less than five years and shall submit such records to the commissioner upon request.

C. Reporting

- 1. The Permittee shall submit a report of all exceedances or deviations for any emission limits or operating parameters contained in this permit to the commissioner within ten days of the exceedance or deviation. Such report shall include the following:
 - a. copies of the exceedance records for the month, as recorded in Part IV.B.10 of this permit,
 - b. an explanation of the likely causes of the exceedances, and
 - c. an explanation of remedial actions taken to correct the exceedance.
- 2. The Permittee shall notify the commissioner, in writing, of any emergency affecting the equipment described in this permit or malfunction of the equipment described in this permit. The Permittee shall submit such notification within ten days of the emergency or malfunction. The notification shall include the following:
 - a. a description of the emergency or malfunction and a description of the circumstances surrounding the cause or likely cause of such emergency or malfunction and,
 - b. a description of all corrective actions and preventive measures taken and/or planned with respect to such emergency or malfunction and the dates of such actions and measures.
- 3. The Permittee shall notify the commissioner, in writing, of the dates of commencement of construction, initial startup and commencement of commercial operation of this source. Such written notifications shall be submitted no later than 30 days after the subject event. Commencement of commercial operations shall mean the date when the unit is released to ISO-New England for dispatch.
- 4. The permittee shall submit all required reports to the Commissioner as required pursuant to Sections 22a-174-19a(j), 22a-174-22(1) and 40 CFR 60.4375.

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine

with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART V. OPERATING REQUIREMENTS

- A. "Steady-state" operation shall be defined as operation of the turbine when the rate of change in load, with respect to time, is zero; except for such operation that occurs during periods of start-up, shutdown, fuel switching, and equipment cleaning. Additionally, steady-state operation shall include all modes of operation during which the turbine load equals or exceeds 50% of the manufacturer's specified maximum for this turbine.
- **B.** "Transient" operation shall be defined as operation of the turbine when the rate of change in load, with respect to time, is less than or greater than zero. Additionally, transient operation shall include and describe the operation of the turbine during all phases of start-up, shutdown, fuel switching and equipment cleaning where the turbine load is less than 50% of the manufacturer's specified maximum. No period of transient operation shall ever exceed 24060 consecutive minutes.
- C. "Malfunction" shall be defined as any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment or a process to operate in a normal or usual manner. Failures that were caused in part by poor maintenance or careless operation are not malfunctions.
- D. "Shakedown" shall be defined as turbine operations including, but not limited to, the first firing of the turbine, proof of interlocks, steam blowing, chemical cleaning and initial turbine roll. Shakedown shall be considered complete upon commencement of commercial operation.
- E. "Emergency" shall be defined as any situation arising from sudden and reasonably unforeseeable events beyond the control of this source, including acts of God, which situation would require immediate corrective action to restore normal operation, and that causes the source to exceed a technology based limitation under the permit, due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include noncompliance due to the extent caused by improperly designed equipment, lack of preventative maintenance, careless or improper operations, operator error or decision to keep operating despite knowledge of these things.

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine

with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART V. OPERATING REQUIREMENTS

F. When burning distillate oil, the turbine shall not operate in steadystate at less than 100% of the manufacturer's specified maximum load
except during times of start-up, shut-down or fuel switching. At all
times when burning distillate oil, the bypass damper of the low-pressure
economizer shall be automatically activated. The Permittee shall ensure
that the bypass systems are incorporated into the design and
construction of the turbine and maintained in good operating condition.

<u>F. ____</u>

- G. This turbine shall not be operated, in steady-state, at any load less than $\frac{50}{30}$ % of the maximum load specified by the manufacturer.
- H. The Permittee shall meet all applicable requirements of the Federal Acid Rain Program codified in Title 40 CFR Parts 72-78, inclusive, by the deadlines set forth within that body of regulation.
- I. The Permittee shall comply with all applicable requirements of Section 22a-174-4 of the RCSA entitled, "Source Monitoring, Record Keeping, Reporting, and Authorization of Inspection of Air Pollution Sources".
- J. The Permittee shall operate and maintain this equipment in accordance with the manufacturer's specifications and written recommendations. The Permittee shall operate and maintain this stationary combustion turbine, air pollution control equipment, and monitoring equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction.
- K. The Permittee shall operate this facility at all times in a manner so as not to violate or contribute significantly to the violation of any applicable state noise control regulations, as set forth in RCSA Sections 22a-69-1 through 22a-69-7.4. (State Only Requirement)
- L. For one calendar year from the date of commencement of commercial operation, the Permittee shall track emissions of CO, NOx, VOC, ammonia and PM-10/2.5 during transient operation of the turbine. Emissions of ammonia, CO and NOx shall be tracked by means of the required continuous emissions monitoring systems. Emissions of VOC and PM-10/2.5 shall be correlated to fuel flow, turbine output or the combination thereof during the initial stack tests performed in accordance with Part VII of this permit. Emissions of VOC and PM-10/2.5 shall be tracked during transient operation by monitoring fuel flow, turbine output, or the combination thereof and estimating the resulting emissions according to the correlation developed during the initial stack tests.

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine

withDLN with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF ENERGY & ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART V. OPERATING REQUIREMENTS, cont.

- 1. Within sixty (60) days of the end of one (1) calendar year of commercial operation of the turbine, the Permittee shall submit a report of observed transient emissions and of any operating parameters observed in order to estimate transient emissions. This permit shall be subject to modification to include a table of emission limits for CO, NOx, VOC, ammonia and PM-10 during transient operation of the turbine. Following the modification of this permit, emissions of CO, NOx, VOC, ammonia and PM-10 during the transient operation of this turbine shall not exceed the limits of said table.
- M. The Permittee shall monitor and record ammonia slip emissions from this source during the first 36 months of commercial operation. Records shall also include <u>SCR</u> catalyst degradation over time and lifecycle costs, ammonia emissions over time, costs for <u>catalystsSCR</u> catalyst and equipment, and emerging SCR technology. This data shall be recorded and maintained on the premises and is in addition to any monitoring required under Part III of this permit. The following requirements apply:
 - 1. No later than 60 days from the last day of each calendar year of commercial operation of this source the Permittee shall submit a summary of operating data collected during the previous year, to the commissioner. This summary report is not required to be submitted for the last year of the ammonia slip monitoring required under Part V.M of this permit.
 - 2. No later than 120 days from the last day of the third calendar year of commercial operation of this source the Permittee shall submit a final report summarizing the results of the ammonia slip monitoring required under Part V.M of this permit, including conclusions regarding ammonia slip emissions during oil firing, to the commissioner.
 - 3. If, after submitting the report described in Part V.M.2 of this permit, there is a lack of data at the end of 36 months to make a good engineering determination regarding ammonia slip emissions, the commissioner may extend the ammonia slip monitoring under Part V.M of this an additional 24 months and the final report shall be submitted no later than 120 days from the last day of the fifth calendar year of commercial operation of this source.
 - 4. The permittee shall design the SCR system to meet an ammonia slip limit of 2 ppmvd while firing natural gas only. However, the enforceable limit shall remain 5 ppmvd for both allowable fuels.

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine

withDLN with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF ENERGY & ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART VI. ALLOWABLE EMISSION LIMITS

The Permittee shall not cause or allow this equipment to exceed the emission limits stated herein at any time.

An exceedance of either (i) the emission limits in the tables below, or (ii) the emissions limits developed for this permit due to an emergency; malfunction, or cleaning shall not be deemed a "Federally Permitted Release," as that term is used in 42 U.S.C. 9601(10).

The Permittee shall not cause or allow emissions of Hazardous Air Pollutants to exceed the Maximum Allowable Stack Concentration, calculated in accordance with Section 22a-174-29 of the RCSA, for each and every pollutant listed on Table 29-1, Table 29-2, or Table 29-3 that is emitted from this turbine. Compliance with Section 22a-174-29 shall be demonstrated for both transient operation and steady-state operation based on actual exhaust gas composition and volumetric flow.

A. Steady State

- Ambient Temperature = 59 °F
- Barometric pressure = 14.28 psia
- Relative Humidity = 60%
- Turbine Load = 100%
- 1. When burning Natural Gas, the Permittee shall not allow or cause emissions from the turbine, after the application of control equipment to exceed the following:

Without Duct Firing					
Criteria	#/hr	#/mmbtu	ppmvd @		
Pollutant			15% O ₂		
PM-10/2.5	14.0 9.73	8E 4.1E-3			
SOx	1.42 4.49	8.1E-4 1.5E-3			
NOx	12.88 19.40	7.4E-3	2.0		
VOC	2.66 3.37	1. 52E 28E-3	<u>1.0</u>		
CO	7.73 5.31	4.42E 2.02E-3	2. 0.9		

With Duct Firing					
Criteria	<u>#/hr</u>	#/mmbtu	ppmvd @		
Pollutant			15% O ₂		
PM-10/2.5	20.4	8.1E-3			
SOx	6.20	1.5E-3			
NOx	26.8	7.4E-3	2.0		
VOC (2 turbines operating)	5.13	1.93E-3	2.0		
VOC (1 turbine operating)	8.82	2.57E-3	2.0		
СО	13.8	3.81E-3	1.7		

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PC7241 (FA)7HA.01 combustion turbine

with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART VI. ALLOWABLE EMISSION LIMITS, continued

2. When burning Distillate Oil, the Permittee shall not allow or cause emissions from the turbine, after the application of control equipment to exceed the following:

Criteria	#/hr	#/mmbtu	ppmvd @
Pollutant			15% 02
PM-10/2.5	36.9 42.6	1.9E 2.04E-2	
SOx	2.91 4.92	1.5E-3	
NOx	42.22 52.00	2.2E 1.94E-2	5. 9 0
VOC	5.3 6.19	2.73E-3	2.0
CO	9.25 12.70	4.76E-3	2.0

- 3. Hazardous Air Pollutant Emission Limits
 - a. The Permittee shall comply with the following limitations:

Hazardous Air Pollutants	Limit		
Ammonia	5 ppmvd		

4. Opacity

Shall not exceed 10% during any six minute block average as measured by 40 CFR 60, Appendix A, Reference Method 9.

B. Transient Operation

The Permittee shall minimize emissions during periods of startup and shutdown by the following work practices. Start the ammonia injection as soon as minimum catalyst temperature is reached.

(See Part V.L of this permit for additional requirements.)

C. The Permittee is not required to demonstrate compliance with the short-term emission limits stated herein during the shakedown period. The shakedown period shall not extend beyond the required date for initial performance tests. Emissions during this period shall be counted towards the annual emission limits stated herein.

FIRM NAME: <u>CPV</u> Towantic <u>Energy</u>, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine

with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

D. Total Allowable Emissions

1. Criteria Pollutants

Criteria Pollutants	Annual Emissions (TPY)
PM-10/2.5	98.3 76.7
SOx	<u> 19.</u> 7 .1
NOx	66.8 94.7
VOC	13.2 24.5
co	85.9 64.5

2. Hazardous Air Pollutants: Section 112(b) of the Clean Air Act Amendments of 1990

The Permittee shall not cause or allow emissions of 10 tons/year or more of any individual HAP or 25 tons of any combination of HAP, on an annual basis from this premises.

- **E.** Demonstration of compliance with the above emission limits shall be met by calculating the emission rates using emission factors from the following sources:
 - 1. NOx, CO, Ammonia: Most recent CEM data.
 - 2. SOx: AP-42 Table 3.1-2a Calculated from 0.0015%S or less in fuel oil.
 - 3. PM-10 and VOC: Most recent stack test data.
 - 4. VOC: Correlating the VOC emissions to the CO emissions using the results of a diagnostic stack test and tracked using the CO CEMS.

The commissioner may require other means (e.g. stack testing) to demonstrate compliance with the above emission limits, as allowed by state or federal statute, law or regulation.

PART VII. STACK EMISSION TEST REQUIREMENTS

A. Stack testing shall be performed in accordance with the latest Emission Test Guidelines available on the DEEP website:

http://www.ct.gov/dep/cwp/view.asp?a=2684&q=322076&depNav_GID=1619http://wwww.ct.gov/deep/lib/deep/air/compliance monitoring/emission test/emission test guidelines.pdf

Stack emission testing shall be required for the following pollutants for both fuels:

 $\overline{\mathbf{X}}$ $_{\mathrm{PM}_{10}}/_{\mathrm{PM}_{2.5}}$ $\overline{\mathbf{X}}$ $_{\mathrm{SOx}}$ $\overline{\mathbf{X}}$ $_{\mathrm{NOx}}$ $\overline{\mathbf{X}}$ $_{\mathrm{CO}}$ $\overline{\mathbf{X}}$ $_{\mathrm{VOC}}$

X Hazardous Air Pollutants listed below:

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART VII. STACK EMISSION TEST REQUIREMENTS, continued

Natural Gas F1ring:

Hazardous Alr Pollutant	Hazardous Alr Pollutant			
1,3-Butadiene	Formaldehyde			
Acetaldehyde	Naphthalene			
Acrolein	Propylene Oxide			
Ammonia	Sulfuric Acid			
Benzene	Toluene			
Ethyl Benzene	Xylene			
Polynuclear Aromatic Hydrocarbons (PAH)				

D1st1llate Oil F1r1ng:

Hazardous Alr Pollutant	Hazardous Alr Pollutant			
Arsenic	Selenium			
Beryllium	Benzene			
Cadmium	1,3-Butadiene			
Chromium	Formaldehyde			
Lead	Sulfuric Acid			
Mercury	Nickel			
1,4-Dichlorobenzene	Carbon Tetrachloride			
Chlorobenzene	Chloroform			
Ethylene Dichloride	Vinylidene Chloride			
Tri-chloroethylene	Tetra-chloroethylene			
Vinyl Chloride	Methylene Chloride			
Polynuclear Aromatic				
Hydrocarbons (PAH)				

Note: Stack emission testing for NOx shall be conducted according to the requirements in RCSA 22a-174-22(k) and 40 CFR Part 60 Subpart KKKK.

Stack test results shall be reported as follows: all pollutants in units of lb/hr and PM-10/2.5 1n units of lb/MMBTU, NOx and CO in units of ppmvd at 15% \mathbf{O}_2 , ammonia and HAPs in units of $\mu g/m^3$ and ppmvd at 15% \mathbf{O}_2 .

All stack emissions tests shall be conducted in accordance with the requirements of Section 22a-174-5 of the RCSA. The Commissioner may attach additional requirements to the requirements of Section 22a-174-5 in order to demonstrate continual compliance with the requirements of this permit.

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine

withDLN with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART VII. STACK EMISSION TEST REQUIREMENTS, cont.

The Permittee shall perform one set of initial stack tests on the turbine when burning natural gas without duct firing, one set of initial stack tests when burning natural gas with duct firing and one set of initial stack tests when burning when burning distillate oil.

B. The Permittee shall conduct initial stack testing within 60 days of achieving the maximum production rate, but not later than 180 days after initial startup. Test results must be submitted within 45 days after testing.

Testing being conducted pursuant to 40 CFR Part 60, the test report is to be submitted within 180 days after the initial startup date or within 60 days after reaching maximum production rate. [40 CFR §60.8(a)]

- C. Testing shall be performed at least once every three years from the date of the initial compliance stack test required in Part VII.A of this permit for all pollutants listed in Part VII.A with the following exceptions:
 - 1. After the initial stack test, stack testing may not be required for pollutants requiring CEMs (NOx, CO, and $\mathrm{NH_3}$). The commissioner retains the right to require stack testing of any pollutant at any time to demonstrate compliance.
 - 2. Fuel oil analysis of the metals in the distillate oil may be substituted for stack testing for metallic HAPs while firing distillate oil.

PART VIII. SPECIAL REQUIREMENTS

A. The Permittee has purchased external emission reductions to comply with \$22a-174-3(1) of the RCSA. The emissions reductions offset NOx emissions allowable under Permit Nos.144-0010, 144-0011, 144-0015, 144-0016, 144-0018 at a ratio of 1.2 to 1. The external emission reductions were secured, approved and made federally enforceable prior to issuance of this construction permit.

Pollutant	Total Reductions	Total Reductions		
	Required	Obtained		
NOx	174 233.6	177 233.6		

The emission reductions were obtained from Consolidated Edison Company of New York, Incorporated (ConEdison) and conform to the requirements of the United States Environmental Protection Agency (USEPA) Economic Incentive Program Rules; Final Rules, published April 7, 1994, (Federal Register, Volume 69, page 16690) and the USEPA Emissions Trading Policy Statement, published December 4, 1986 (Federal Register, Volume 51,

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine

withDLN with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART VIII. SPECIAL REQUIREMENTS, continued

Number 233). Specifically, the reductions are real, quantifiable, surplus, permanent, and enforceable since they were reviewed and transferred to Towantic Energy LLC in accordance with the Interim Reciprocity Agreement by and between the State of Connecticut Department of Energy and Environmental Protection and the State of New York Department of Environmental Conservation on the Interstate Trading of Emission Reduction Credits, executed February 1, 1999. The Permittee shall maintain ownership of the emissions reductions for the life of the electric generating facility.

- **B.** The Permittee shall comply with all applicable requirements of the Federal Acid Rain Program codified in Title 40.CFR Parts 72-78, inclusive, by the deadlines set forth within the aforementioned regulation.
- C. The Permittee shall notify the commissioner, in writing, of the commencement of construction, completion of construction and commencement of commercial operation of this source. Such written notifications shall be submitted no later than 30 days after the subject event.
- D. Prior to commencement of construction, the Permittee shall submit to the Commissioner copies of the manufacturer's specifications for all air pollution control equipment to be used with this turbine.
- E. Upon completion of construction, the Permittee shall certify to the Commissioner, in writing, that the facility has been constructed in accordance with the terms and conditions of its construction permit.
- F. Upon completion of construction of the turbines and control equipment regulated under Permit #144-0010 and Permit #144-0011, the Permittee shall prepare and submit a written standby plan in accordance with subdivision (d)(2) of Section 22a-174-6 of the RCSA. The standby plan shall be subject to the requirements of subdivisions (d)(2) through (d)(5) of Section 22a-174-6 of the RCSA. The Permittee shall not operate the sources regulated under Permits #144-0010 and #144-0011 until the Commissioner has approved a standby plan submitted in accordance with this permit.
- **G.** Upon completion of construction of the turbines and control equipment regulated under Permit #144-0010 and Permit #144-0011, the Permittee shall submit a comprehensive operation and maintenance plan for all air pollution emitting activities and the air pollution control equipment, which will ensure continuous compliance with applicable regulations and permit conditions. The Permittee shall not operate the sources regulated under Permits #144-0010 and #144-0011 until the Commissioner has

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine

with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART VIII. SPECIAL REQUIREMENTS, continued

approved an operation and maintenance plan submitted in accordance with this permit.

H. Prior to the completion of construction, the Permittee shall submit a report to the Commissioner on the feasibility of using solid ammonia, urea, as an alternative to aqueous ammonia for the control of NOxemissions. The Commissioner may prescribe the information required in this report. If the Commissioner determines that the use of urea is feasible, he may modify the permit to require its use.

Η.

PART IX. ADDITIONAL TERMS AND CONDITIONS

- A. The Permittee shall comply with all applicable requirements of Section 22a-174-6 of the RCSA, entitled "Air Pollution Emergency Episode Procedures".
- B. The Permittee shall comply with all applicable sections of the following New Source Performance Standard(s) at all times.

Title 40 CFR Part 60, Subpart: KKKK and A

Copies of the Code of Federal Regulations (CFR) are available online at the U.S. Government Printing Office website.

- C. The Permittee shall comply with all applicable requirements of RCSA 22a-174-22c The Clean Air Interstate Rule (CAIR) Nitrogen Oxides (NOx) Ozone Season Trading Program.
- D. The Permittee shall comply with all applicable requirements of RCSA 22a-174-19a Control of sulfur dioxide emissions from power plants and other large stationary sources of air pollution.
- E. The Permittee shall comply with all applicable requirements of RCSA 22a-174-31 Control of Carbon Dioxide Emissions. [State Only Requirement]
- F. This permit does not relieve the Permittee of the responsibility to conduct, maintain and operate the regulated activity in compliance with all applicable requirements of any federal, municipal or other state agency. Nothing in this permit shall relieve the Permittee of other obligations under applicable federal, state and local law.

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine

with DLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART IX. ADDITIONAL TERMS AND CONDITION, continued

- **G.** Any representative of the <u>DEP_DEEP</u> may enter the Permittee's site in accordance with constitutional limitations at all reasonable times without prior notice, for the purposes of inspecting, monitoring and enforcing the terms and conditions of this permit and applicable state law.
- H. This permit may be revoked, suspended, modified or transferred in accordance with applicable law.
- I. This permit is subject to and in no way derogates from any present or future property rights or other rights or powers of the State of Connecticut and conveys no property rights in real estate or material, nor any exclusive privileges, and is further subject to any and all public and private rights and to any federal, state or local laws or regulations pertinent to the facility or regulated activity affected thereby. This permit shall neither create nor affect any rights of persons or municipalities who are not parties to this permit.
- J. Any document, including any notice, which is required to be submitted to the commissioner under this permit shall be signed by a duly authorized representative of the Permittee and by the person who is responsible for actually preparing such document, each of whom shall certify in writing as follows: "I have personally examined and am familiar with the information submitted in this document and all attachments thereto, and I certify that based on reasonable investigation, including my inquiry of those individuals responsible for obtaining the information, the submitted information is true, accurate and complete to the best of my knowledge and belief. I understand that any false statement made in the submitted information may be punishable as a criminal offense under section 22a-175 of the Connecticut General Statutes, under section 53a-157b of the Connecticut General Statutes, and in accordance with any applicable statute."
- K. Nothing in this permit shall affect the commissioner's authority to institute any proceeding or take any other action to prevent or abate violations of law, prevent or abate pollution, recover costs and natural resource damages, and to impose penalties for violations of law, including but not limited to violations of this or any other permit issued to the Permittee by the commissioner.
- L. Within 15 days of the date the Permittee becomes aware of a change in any information submitted to the commissioner under this permit, or that any such information was inaccurate or misleading or that any relevant information was omitted, the Permittee shall submit the correct or omitted information to the commissioner.

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine withDLN combustor

STATE OF CONNECTICUT, DEPARTMENT OF **ENERGY &** ENVIRONMENTAL PROTECTION BUREAU OF AIR MANAGEMENT

PART IX. ADDITIONAL TERMS AND CONDITIONS, continued

- M. The date of submission to the commissioner of any document required by this permit shall be the date such document is received by the commissioner. The date of any notice by the commissioner under this permit, including but not limited to notice of approval or disapproval of any document or other action, shall be the date such notice is personally delivered or the date three days after it is mailed by the commissioner, whichever is earlier. Except as otherwise specified in this permit, the word "day" means calendar day. Any document or action which is required by this permit to be submitted or performed by a date which falls on a Saturday, Sunday or legal holiday shall be submitted or performed by the next business day thereafter.
- N. Any document required to be submitted to the commissioner under this permit shall, unless otherwise specified in writing by the commissioner, be directed to: Office of Director; Engineering & Enforcement Division; Bureau of Air Management; Department of Energy and Environmental Protection; 79 Elm Street, 5th Floor; Hartford, Connecticut 06106-5127.

FIRM NAME: CPV Towantic Energy, LLC

EQUIPMENT LOCATION: Woodruff Hill Road, Oxford, CT

EQUIPMENT DESCRIPTION: General Electric PG7241 (FA)7HA.01 combustion turbine withDLN with DLN combustor

ATTACHMENT O - COASTAL CONSISTENCY REVIEW FORM

Not required, as the Project is not located within the coastal zone or in a coastal community.



ATTACHMENT P - COPY OF RESPONSE TO REQUEST FOR NATURAL DIVERSITY DATABASE (NDDB) STATE LISTED SPECIES REVIEW FORM

A copy of the letter received on June 10, 2014 in response to the Natural Diversity Database (NDDB) State Listed Species Review request made for the Project on March 21, 2014. Although some recommended actions are noted to avoid potential species impacts, no threatened or endangered species or sensitive communities are identified on the Project site.





Bureau of Natural Resources Wildlife Division Natural History Survey – Natural Diversity Data Base

June 10, 2014

Ms. Lynn Gresock Tetra Tech, Inc. 238 Little Road, Suite 201-B Westford, MA 01886

Regarding: CPV Towantic Energy Center, Oxford, CT – Commercial/Industrial Development Natural Diversity Data Base 201405771

Dear Ms. Gresock:

In response to your request for a Natural Diversity Data Base (NDDB) Review of State Listed Species for the CPV Towantic Energy Center in Oxford, CT, our records for this site indicate the following extant populations of species on or within the vicinity of the site:

Red bat (Lasiurus borealis) Protection Status: Species of Special Concern

Red bats are considered to be "tree-roosting" bats. They roost out in the foliage of deciduous and coniferous trees, camouflaged as dead leaves or cones. Red bats are primarily solitary roosters. They can be found roosting and feeding around forest edges and clearings. Typically, larger diameter trees (12-inch DBH and larger) are more valuable to these bats. Additionally, trees with loose, rough bark such as maples, hickories, and oaks are more desirable than other tree species due to the increased cover that the loose bark provides. Large trees with cavities are also utilized by this species. Retaining the above mentioned trees, wherever possible, may minimize the potential for negative impacts to this state-listed species.

Hoary bat (Lasiurus cinereus) Protection Status: Species of Special Concern

Hoary bats are found in Connecticut during the spring and summer seasons and migrate south to overwinter. Their diet primarily consists of moths and beetles. These bats will roost high in large coniferous and deciduous trees.

Silver-haired bat (Lasionycteris noctivagans) Protection Status: Species of Special Concern

Silver-haired bats typical roost sites include tree foliage, tree hollows, and crevices behind loose bark, but they are most likely to be found near water. They will typically give birth to their young in June or July, and the young will stay in roost until August.

Recommendations: Work should be conducted in the winter when the bats are not in the area, specifically work should not be conducted between May 1st through August 15th. Long-term

impacts can be minimized by retaining large diameter coniferous and deciduous trees whenever possible, particularly close to brooks and streams. If these bats are found, please report the information to the Wildlife Division.

Eastern box turtle (Terrapene carolina Carolina) Protection Status: Species of Special Concern

Eastern box turtles inhabit old fields and deciduous forests, which can include power lines and logged woodlands. They are often found near small streams and ponds. The adults are completely terrestrial but the young may be semiaquatic, and hibernate on land by digging down in the soil from October to April. They have an extremely small home range and can usually be found in the same area year after year. Eastern box turtles have been negatively impacted by the loss of suitable habitat. Some turtles may be killed directly by construction activities, but many more are lost when important habitat areas for shelter, feeding, hibernation, or nesting are destroyed. As remaining habitat is fragmented into smaller pieces, turtle populations can become small and isolated.

Recommendations: The following guidelines should be implemented:

- ❖ Siltation and Erosion Control Measures:
 - Where possible, AVOID installing sediment and erosion control materials from 1) late August through September and 2) from March through mid-May. These two time periods are when amphibians and reptiles are most active, moving to and from wetlands to breed.
 - Most wildlife travels between different habitats throughout the year, the layout of how sediment and erosion control materials are placed is very important. If silt fencing needs to be installed and left up during peak times of amphibian migration, we recommend that it be installed in such a way to allow for animals to pass through. We would encourage a staggered layout for silt fence installation. We would be happy to provide additional guidance on placement of sediment and erosion control materials to limit impacts to wildlife.
 - The use of erosion control products with netting embedded in the product to maintain its shape and structure, has been shown to be fatal to wildlife in Connecticut, in particular snakes. Snakes can get tangled and trapped within the netting as they maneuver through the net openings. When reptiles are trapped, their ability to thermoregulate is compromised and in areas exposed to sun, trapped reptiles quickly overheat and die. To limit the potential for needless mortality to long-lived reptiles, we recommend the following considerations:
 - o Given the high variability of the composition of products with bio-degradable and degradable netting, we recommend that these products NOT be used.

- Use erosion control options that DO NOT contain netting such as net-less blankets or hay bales.
- o Reconfigure/lower the grade of slopes so products without netting can be utilized.
- Siltation and erosion control measures should be removed as soon as soils are stable so as to not impede reptile and amphibian migrations between wetlands and uplands.
- * Rip-rap: If rip-rap is going to be used, consider covering the rip-rap with local stream bank material.
- Stockpiles of Soil: Stockpiles of soil should be cordoned off with silt fencing so turtles do not attempt to try and nest in them.
- ❖ Native Plantings: Any plantings should be composed of species native to northeastern United States and appropriate for use in riparian habitat.

The Natural Diversity Data Base includes all information regarding critical biological resources available to us at the time of the request. This information is a compilation of data collected over the years by the Department of Energy and Environmental Protection's Natural History Survey and cooperating units of DEEP, private conservation groups and the scientific community. This information is not necessarily the result of comprehensive or site-specific field investigations. Consultations with the Data Base should not be substituted for on-site surveys required for environmental assessments. Current research projects and new contributors continue to identify additional populations of species and locations of habitats of concern, as well as, enhance existing data. Such new information is incorporated into the Data Base as it becomes available. If the project is not implemented within 12 months, then another Natural Diversity Data Base review should be requested for up-to-date information.

Please be advised a more detailed review may be conducted as part of any subsequent environmental permit applications submitted to the Department of Energy and Environmental Protection for the proposed site. Should state involvement occur in some other manner, specific restrictions or conditions relating to the species discussed above may apply.

Thank you for consulting the Natural Diversity Data Base. If you have further questions, I can be reached by email at Elaine.hinsch@ct.gov or by phone at (860) 424-3011.

Sincerely, /s/ Elaine Hinsch Program Specialist II Wildlife Division

ATTACHMENT Q – CONSERVATION OR PRESERVATION RESTRICTION INFORMATION


Not required, as no conservation or preservation restrictions are associated with the Project site.



ATTACHMENT R – COPY OF WRITTEN ENVIRONMENTAL JUSTICE PUBLIC PARTICIPATION PLAN APPROVAL LETTER

Not required, as the Project is not located in an Environmental Justice community.





Facility-Wide Potential Annual Emissions (TPY)

Pollutant	Unit 1 (CT & HRSG) (tpy)	Unit 2 (CT & HRSG) (tpy)	Auxiliary Boiler (tpy)	Emergency Generator (tpy)	Fire Pump (tpy)	Fugitive Emissions (tpy)	Facility Total (tpy)
NO _x	94.7	94.7	2.02	2.98	0.40	N/A	194.7
со	64.5	64.5	6.83	0.32	0.09	N/A	136.2
VOC	24.5	24.5	0.75	0.08	0.01	N/A	49.9
SO ₂	19.7	19.7	0.28	0.003	0.001	N/A	39.7
PM	76.7	76.7	1.29	0.02	0.01	N/A	154.7
PM ₁₀	76.7	76.7	1.29	0.02	0.01	N/A	154.7
PM _{2.5}	76.7	76.7	1.29	0.02	0.01	N/A	154.7
CO ₂	1,326,584	1,326,584	21,605	353	60	N/A	2,675,185
CH₄	24.6	24.6	0.407	0.014	0.0024	21.6	71.3
N ₂ O	2.72	2.72	0.041	0.003	0.0005	N/A	5.48
CO ₂ e	1,328,009	1,328,009	21,627	354	60	554	2,678,612
H ₂ SO ₄	12.66	12.66	0.02	0.0002	0.00004	N/A	25.3
Lead (Pb)	1.7E-02	1.7E-02	9.1E-05	1.7E-06	2.8E-07	N/A	0.034
NH ₃	77.7	77.7	N/A	N/A	N/A	N/A	155.3
Total HAPS	5.60	5.60	0.35	0.01	0.003	N/A	11.6

Vendor Emissions 7HA.01 Combustion Turbine & Duct Burner CPV Towantic Energy, LLC

AMBIENT CONDITIONS:	Ī		-14.2	°F				59	°F		90	°F	Ī		100°F		
GE CASE #:	#1	#2	#3	#4	#28	#29	#35	#9	#31	#32	#36	#13	#14	#16	#17	#23	#24
Fuel	Natural Gas																
Number of GTs Operating	2	2	1	2	2	2	2	2	2	2	2	2	2	1	2	2	2
GT Operating Load	BASE	BASE	BASE	BASE	75%	50%	BASE	BASE	75%	50%	BASE	BASE	BASE	BASE	BASE	75%	50%
Fuel Heating Value, Btu/lb (HHV)	22,809	22,809	22,809	22,809	22,809	22,809	22,809	22,809	22,809	22,809	22,809	22,809	22,809	22,809	22,809	22,809	22,809
Evaporative Cooler Status	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	On	On	On	On	Off	Off
Duct Burner Status	Fired	Fired	Fired	Unfired	Unfired	Unfired	Fired	Unfired	Unfired	Unfired	Fired	Unfired	Fired	Fired	Unfired	Unfired	Unfired
Chiller Status	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Ambient Relative Humidity, %	20	20	20	20	20	20	60	60	60	60	60	60	40	40	40	40	40
BAROMETRIC PRESSURE, psia	14.30	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3
GT Heat Input (MMBtu/hr/unit, HHV)	2,526	2,526	2,526	2,526	2,047	1,582	2,426	2,426	2,017	1,538	2,213	2,303	2,297	2,297	2,297	1,686	1,308
DB Heat Input (MMBtu/hr/unit, HHV)	198	97	962	0	0	0	110	0	0	0	209	0	190	766	0	0	0
Net Power (kW)	824,384	799,755	499,169	775,214	609,074	442,484	791,905	765,698	589,174	420,106	722,051	702,508	730,334	423,370	687,889	485,913	349,487
Gross Power (kW)	836,396	810,532	508,975	784,998	617,403	449,562	804,949	777,538	598,755	428,041	735,670	714,007	743,946	433,792	699,335	495,367	357,890
Heat Rate (Btu/kW-hr, gross)	6,514	6,473	6,854	6,437	6,631	7,038	6,302	6,241	6,736	7,184	6,584	6,452	6,684	7,060	6,568	6,805	7,309
Heat Rate (Btu/kW-hr, net)	6,609	6,560	6,989	6,518	6,722	7,150	6,405	6,337	6,846	7,320	6,708	6,558	6,809	7,234	6,677	6,937	7,485
	935894.94																
HRSG STACK EXHAUST GAS																	
Exhaust Flow, lb/hr	5,021,800	5,017,200	5,057,000	5,012,700		3,234,000	4,655,900		3,828,300	3,155,300	4,262,100	4,386,900	4,385,100	4,411,700			2,909,600
Stack Temperature, °F	181.9	188.9	170.0	196.4	189.6	180.4	174.2	183.2	180.2	179.0	186.7	196.2	197.2	170.0	202.8	197.1	190.0
O ₂ , Vol. %	11.55%	11.88%	9.07%	12.20%	12.25%	12.56%	11.18%	11.84%	12.17%	12.80%	10.74%	11.40%	10.69%	8.58%	11.40%	12.35%	12.77%
CO ₂ , Vol. %	4.36%	4.21%	5.50%	4.06%	4.03%	3.89%	4.43%	4.13%	3.98%	3.69%	4.46%	4.12%	4.45%	5.42%	4.12%	3.74%	3.55%
H ₂ O, Vol. %	8.45%	8.15%	10.68%	7.86%	7.82%	7.54%	9.58%	8.99%	8.70%	8.13%	11.45%	11.16%	11.81%	13.68%	11.19%	9.80%	9.43%
N ₂ , Vol. %	74.76%	74.87%	73.88%	74.99%	75.01%	75.12%	73.93%	74.16%	74.27%	74.49%	72.49%	72.46%	72.19%	71.47%	72.43%	73.24%	73.38%
Ar, Vol. %	0.89%	0.89%	0.88%	0.89%	0.89%	0.89%	0.88%	0.88%	0.88%	0.89%	0.87%	0.86%	0.86%	0.85%	0.86%	0.87%	0.87%
MW, lb/lb-mole	28.43	28.45	28.29	28.47	28.47	28.49	28.31	28.35	28.37	28.41	28.11	28.11	28.07	27.96	28.11	28.23	28.25
HRSG EXHAUST STACK EMISSIONS (PER S	TACK):																
NOX, ppmvd @ 15% O2	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0
NOX, lb/MMBtu as NO2 (EPA Method 19)	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074	0.0074
NOX, ID/MINIBILITIES NOZ (EPA Metriod 19)	20.90	20.10	26.80	19.40	15.50	12.00	19.80	18.40	14.50	11.10	18.40	17.40	18.80		17.40	12.80	9.89
VOC, ppmvd @ 15% O2 as CH4	1.5	1.5	20.00	1.0	1.0	1.00	1.5	1.0	14.50	1.10	1.5	17.40	1.5	23.30 2.0	17.40	12.00	1.0
VOC, ppffivd @ 13% O2 as CH4 VOC, lb/MMBtu as CH4 (EPA Method 19)	0.0019	0.0019	0.0026	0.0013	0.0013	0.0013	0.0019	0.0013	0.0013	0.0013	0.0019	0.0013	0.0019	0.0026	0.0013	0.0013	0.0013
VOC. lb/hr as CH4	5.13	4.94	8.82	3.37	2.69	2.08	4.72	3.19	2.53	1.93	4.51	3.03	4.63	7.24	3.02	2.22	1.72
CO, ppmvd @ 15% O2	1.7	1.7	1.7	0.9	0.9	0.9	1.7	0.9	0.9	0.9	1.7	0.9	1.7	1.7	0.9	0.9	0.9
CO, lb/MMBtu (EPA Method 19)	0.0038	0.0038	0.0038	0.0020	0.0020	0.0020	0.0038	0.0020	0.0020	0.0020	0.0038	0.0020	0.0038	0.0038	0.0020	0.0020	0.0020
CO. lb/hr	10.80	10.40	13.80	5.31	4.24	3.28	9.93	5.03	3.98	3.04	9.50	4.78	9.75	12.00	4.76	3.49	2.71
SO2, lb/hr	4.85	4.67	6.20	4.49	3.64	2.81	4.64	4.31	3.42	2.60	4.31	4.09	4.42	5.45	4.08	3.00	2.33
H2SO4, lb/hr	3.11	3.00	3.99	2.89	2.34	1.81	2.98	2.77	2.20	1.67	2.77	2.63	2.84	3.50	2.62	1.93	1.49
H2SO4, lb/MMBtu	0.00114	0.00114	0.00114	0.00114	0.00114	0.00114	0.00117	0.00114	0.00109	0.00109	0.00114	0.00114	0.00114	0.00114	0.00114	0.00115	0.00114
PM/PM ₁₀ /PM _{2.5} , lb/hr	20.00	19.50	20.40	9.73	9.19	8.76	20.30	9.64	9.08	8.65	19.10	9.53	20.10	18.00	9.52	8.86	8.51
PM/PM ₁₀ /PM _{2.5} , lb/MMBtu	0.0073	0.0074	0.0058	0.0039	0.0045	0.0055	0.0080	0.0040	0.0045	0.0056	0.0079	0.0041	0.0081	0.0059	0.0041	0.0053	0.0065
NH ₃ , ppmvd @ 15% O2	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
NH3, lb/MMBtu (EPA Method 19)	0.0068	0.0068	0.0068	0.0068	0.0068	0.0068	0.0068	0.0068	0.0068	0.0068	0.0068	0.0068	0.0068	0.0068	0.0068	0.0068	0.0068
NH ₃ , lb/hr	19.30	18.60	24.70	17.90	14.30	11.10	18.30	17.00	13.40	10.20	17.00	16.10	17.40	21.50	16.10	11.80	9.14
CO ₂ , lb/hr (40 CFR 75, App. G, Eq. G-4)	323,796	311,778	414,627	300,274	243,307	188,022	301,448	288,363	239,687	182,755	287,847	273,774	295,530	364,023	272,974	200,335	155,455
CH ₄ , lb/hr (40 CFR 98, Subpart C, Table 2)	6.01	5.78	7.69	5.57	4.51	3.49	5.59	5.35	4.45	3.39	5.34	5.08	5.48	6.75	5.06	3.72	2.88
N ₂ O, lb/hr (40 CFR 98, Subpart C, Table 2)	0.60	0.58	0.77	0.56	0.45	0.35	0.56	0.53	0.44	0.34	0.53	0.51	0.55	0.68	0.51	0.37	0.29
CO ₂ e, lb/hr (CH4 GWP = 25, N2O GWP = 298)	324,125	312,095	415,048	300,579	243,554	188,213	301,754	288,656	239,931	182,941	288,139	274,053	295,831	364,393	273,251	200,538	155,613
CO ₂ e, lb/MW-hr (gross)	775.1	770.1	815.5	765.8	789.0	837.3	749.7	742.5	801.4	854.8	783.3	767.6	795.3	840.0	781.5	809.7	869.6
/																	

Vendor Emissions 7HA.01 Combu CPV Towantic Energy, LLC

AMBIENT CONDITIONS:	I	-14	.2F			59°F		90°F	Ī	10	0°F	
GE CASE #:	#37	#46	#47	#38	#41	#52	#53	#42	#43	#44	#51	#45
Fuel	Distillate C)il										
Number of GTs Operating	2	1	2	2	2	2	2	2	2	2	2	2
GT Operating Load	BASE	BASE	75%	50%	BASE	75%	50%	BASE	BASE	BASE	75%	50%
Fuel Heating Value, Btu/lb (HHV)	19,398	19,398	19,398	19,398	19,398	19,398	19,398	19,398	19,398	19,398	19,398	19,398
Evaporative Cooler Status	Off	Off	Off	Off	Off	Off	Off	On	On	Off	Off	Off
Duct Burner Status	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired
Chiller Status	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Ambient Relative Humidity, %	20	20	20	20	60	60	60	60	40	40	40	40
BAROMETRIC PRESSURE, psia GT Heat Input (MMBtu/hr/unit, HHV)	14.3 2,524	14.3 2,524	14.3 2,022	14.3 1,555	14.3 2,389	14.3 1,891	14.3 1,459	14.3 2,227	14.3 2,217	14.3 2,068	14.3 1,664	14.3 1,293
DB Heat Input (MMBtu/hr/unit, HHV)	0	0	0	0	0	0	0	0	0	2,000	0	0
Net Power (kW)	716,117	351,779	565,752	412,348	691,128	544,157	395,427	635,396	622,185	577,681	455,598	328,366
Gross Power (kW)	725,936	356,270	574,551	420,076	702,281	554,034	404,064	646,841	633,588	588,788	465,751	337,499
Heat Rate (Btu/kW-hr, gross)	6,954	7,085	7,038	7,401	6,803	6,825	7,220	6,886	7,000	7,023	7,146	7,661
Heat Rate (Btu/kW-hr, net)	7,049	7,175	7,147	7,540	6,913	6,949	7,378	7,010	7,128	7,158	7,305	7,874
, ,	18,290				,			,				
HRSG STACK EXHAUST GAS												
Exhaust Flow, lb/hr	4,989,600	4,989,600	4,000,500	3,223,500	4,838,400	3,810,500	2,937,900	4,546,500	4,529,700	4,249,400	3,398,900	2,703,800
Stack Temperature, °F	304.3	292.6	280.3	270.3	294.6	272.4	268.4	291.9	302.0	289.0	279.0	280.3
O ₂ , Vol. %	11.09%	12.17%	11.17%	11.72%	11.10%	11.16%	11.25%	10.90%	10.90%	11.03%	11.07%	11.40%
CO ₂ , Vol. %	5.66%	5.09%	5.66%	5.42%	5.50%	5.54%	5.55%	5.42%	5.42%	5.39%	5.44%	5.33%
H ₂ O, Vol. %	10.62%	9.17%	10.20%	9.14%	11.62%	11.06%	10.52%	13.08%	13.09%	12.63%	12.11%	11.28%
N ₂ , Vol. %	71.78%	72.70%	72.11%	72.85%	70.94%	71.39%	71.82%	69.77%	69.76%	70.11%	70.54%	71.14%
Ar, Vol. %	0.85%	0.87%	0.86%	0.87%	0.84%	0.85%	0.86%	0.83%	0.83%	0.84%	0.84%	0.85%
MW, lb/lb-mole	28.40	28.50	28.45	28.54	28.27	28.34	28.40	28.11	28.10	28.15	28.21	28.29
HRSG EXHAUST STACK EMISSIONS (PER S	6											
NOX, ppmvd @ 15% O2	5	5	5	5	5	5	5	5	5	5	5	5
NOX, lb/MMBtu as NO2 (EPA Method 19)	0.0194	0.0194	0.0194	0.0194	0.0194	0.0194	0.0194	0.0194	0.0194	0.0194	0.0194	0.0194
NOX, lb/hr as NO2	52.00	46.50	41.70	32.00	49.20	38.90	30.00	45.80	45.60	42.60	34.30	26.60
VOC, ppmvd @ 15% O2 as CH4	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0
VOC, lb/MMBtu as CH4 (EPA Method 19)	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027	0.0027
VOC, lb/hr as CH4	6.19	6.19	4.95	3.98	6.03	4.74	3.64	5.70	5.68	5.32	4.24	3.37
CO, ppmvd @ 15% O2	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0
CO, lb/MMBtu (EPA Method 19)	0.0047	0.0047	0.0047	0.0047	0.0047	0.0047	0.0047	0.0047	0.0047	0.0047	0.0047	0.0047
CO, lb/hr	12.70	11.30	10.10	7.79	12.00	9.48	7.31	11.20	11.10	10.40	8.34	6.48
SO2, lb/hr	4.92	4.92	3.95	3.04	4.66	3.68	2.84	4.34	4.32	4.03	3.24	2.52
H2SO4, lb/hr	3.16	3.16	2.53	1.95	2.99	2.37 0.00125	1.83	2.79	2.78	2.59	2.09	1.62
H2SO4, lb/MMBtu PM/PM ₁₀ /PM _{2.5} , lb/hr	0.00125 42.60	0.00125 42.60	0.00125 42.00	0.00125 41.60	0.00125 42.40	41.90	0.00125 41.50	0.00125 42.30	0.00125 42.20	0.00125 42.10	0.00126 41.70	0.00125 41.30
PM/PM ₁₀ /PM _{2.5} , lb/MMBtu	0.0169	0.0169	0.0208	0.0268	0.0177	0.0222	0.0284	0.0190	0.0190	0.0204	0.0251	0.0319
NH ₃ , ppmvd @ 15% O2	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
NH3, lb/MMBtu (EPA Method 19)	0.0072	0.0072	0.0072	0.0072	0.0072	0.0072	0.0072	0.0072	0.0072	0.0072	0.0072	0.0072
NH ₃ , lb/hr	19.20	17.20	15.40	11.80	18.20	14.40	11.10	16.90	16.90	15.70	12.70	9.83
CO ₂ , lb/hr (40 CFR 75, App. G, Eq. G-4)	409,618	409,618	328,117	252,275	387,664	306,811	236,730	361,405	359,860	335,528	270,068	209,797
CH ₄ , lb/hr (40 CFR 98, Subpart C, Table 2)	7.57	7.57	6.07	4.66	7.17	5.67	4.38	6.68	6.65	6.20	4.99	3.88
N ₂ O, lb/hr (40 CFR 98, Subpart C, Table 2)	1.51	1.51	1.21	0.93	1.43	1.13	0.88	1.34	1.33	1.24	1.00	0.78
CO ₂ e, lb/hr (CH4 GWP = 25, N2O GWP = 298)		410,258	328,630	252,670	388,270	307,291	237,100	361,970	360,423	336,053	270,490	210,125
CO ₂ e, lb/MW-hr (gross)	1,130.3	1,151.5	1,144.0	1,203.0	1,105.7	1,109.3	1,173.6	1,119.2	1,137.7	1,141.5	1,161.5	1,245.2

Startup/Shutdown Operating Data

hot starts/unit/gas	200	number/yr	1.00	hours/event	6	Avg. hours downtime	420	minutes/event
warm starts/unit/gas	0	number/yr	1.00	hours/event	30	Avg. hours downtime	1,860	minutes/event
cold starts/unit/gas	50	number/yr	1.00	hours/event	60	Avg. hours downtime	3,660	minutes/event
shutdowns/unit/gas	250	number/yr	1.00	hours/event	N/A	Avg. hours downtime	N/A	minutes/event
hot starts/unit/oil	0	number/yr	1.00	hours/event	6	Avg. hours downtime	420	minutes/event
warm starts/unit/oil	0	number/yr	1.00	hours/event	30	Avg. hours downtime	1,860	minutes/event
cold starts/unit/oil	0	number/yr	1.00	hours/event	60	Avg. hours downtime	3,660	minutes/event
shutdowns/unit/oil	0	number/yr	1.00	hours/event	N/A	Avg. hours downtime	N/A	minutes/event

Startup/Shutdown Emissions Self-Correcting Analysis

			Gas Start			Oil Start	
		NOx	CO	VOC	NOx	CO	VOC
Emissions per hot start	lbs	70.0	238.0	36.0	102.0	231.0	90.0
Emissions per warm start	lbs	93.0	242.0	37.0	104.0	230.0	87.0
Emissions per cold start	lbs	93.0	242.0	37.0	104.0	230.0	87.0
Emissions per shutdown	lbs	19.0	121.0	60.0	34.0	18.0	23.0
Shutdown/Hot start - duration (including downtime)	hrs	8.00	8.00	8.00	8.00	8.00	8.00
Shutdown/Warm start - duration (including downtime)	hrs	32.00	32.00	32.00	32.00	32.00	32.00
Shutdown/Cold start - duration (including downtime)	hrs	62.00	62.00	62.00	62.00	62.00	62.00
Shutdown/Hot start - avg hourly emissions ¹	lb/hr	11.13	44.88	12.00	12.75	28.88	11.25
Shutdown/Warm start - avg hourly emissions ¹	lb/hr	3.50	11.34	3.03	3.25	7.19	2.72
Shutdown/Cold start - avg hourly emissions ¹	lb/hr	1.81	5.85	1.56	1.68	3.71	1.40
Steady state average hourly (annual) ²	lb/hr	21.61	7.98	4.17	21.61	7.98	4.17
Hot start - self correcting?	lb/hr	yes	no	no	yes	no	no
Warm start - self correcting?	lb/hr	yes	no	yes	yes	yes	yes
Cold start - self correcting?	lb/hr	yes	yes	yes	yes	yes	yes

¹ Includes balance of the hour at the steady state annual average hourly rate

Startup/Shutdown Potential Emissions Increase (tpy/unit)

SUSD Type	Gas NOx	Gas CO	Gas VOC	Oil NOx	Oil CO	Oil VOC
Shutdown/Hot Start	-	29.52	6.27	-	0.00	0.00
Shutdown/Warm Start	-	0.00	-	-	-	-
Shutdown/Cold Start	-	-	-	-	-	-
TOTAL	0.00	29.52	6.27	0.00	0.00	0.00

Note: Maximum of hot start/warm start/transition used for worst case hot start

² Based upon average annual hourly emissions with 3,000 hr/yr gas with duct firing, 720 hr/yr oil firing and gas without duct firing balance of the year

Operating Scenario	GE Case	Hours Per Year	Gross Generation Rate (kW/hr)	Heat Input HHV (MMBtu/hr)	Gross Generation Rate (MW/yr)	HHV	Gross Heat Rate (Btu/kW-hr)	Net Heat Rate (Btu/kW-hr)
Gas No Duct Firing	Case #9	3,790	777,538	4,852	2,946,869	18,390,068	6,241	6,401
Gas With Duct Firing (ISO)	Case #35	4,250	804,949	5,072	3,421,033	21,557,876	6,302	6,463
Oil	Case #41	720	702,281	4,778	505,642	3,439,835	6,803	6,977
TOTAL (new & clean)		8,760			6,873,545	43,387,779	6,312	6,474
TOTAL (12.8% degradation	n margin)						7,120	7,303

Operating Scenario	GE Case	Hours Per Year	Gross Generation Rate (kW/hr)	CO₂e Emission Rate (lb/hr)	Gross Generation Rate (MW/yr)	CO₂e Emission Rate (tpy)	CO₂e Emission Rate Gross (lb/MW-hr)	CO ₂ e Emission Rate Net (lb/MW-hr)
Gas No Duct Firing	Case #9	3,790	777,538	577,312	2,946,869	1,094,007	742	762
Gas With Duct Firing (ISO)	Case #35	4,250	804,949	603,509	3,421,033	1,282,456	750	769
Oil	Case #41	720	702,281	776,541	505,642	279,555	1,106	1,134
TOTAL (new & clean)		8,760			6,873,545	2,656,017	773	793
TOTAL (12.8% degradation	n margin)						872	894

Emissions From Ancillary Equipment CPV Towantic Energy, LLC

Emissions from Ancillary Equipment (tpy)

	Auxiliary Boiler	Emergency Generator	Fire Pump
Pollutant	92.4 MMBtu/hr	2206 bhp	315 kW
NO _x	9 ppmvd @ 3% O ₂	4.08 g/bhp	3.8 g/kW
	0.011 lb/MMBtu	1.37 lb/MMBtu	1.08 lb/MMBtu
	1.01 lb/hr	19.84 lb/hr	2.64 lb/hr
	2.02 TPY	2.98 TPY	0.40 TPY
CO	50 ppmvd @ 3% O ₂	0.44 g/bhp	0.9 g/kW
	0.037 lb/MMBtu	0.15 lb/MMBtu	0.26 lb/MMBtu
	3.42 lb/hr	2.14 lb/hr	0.63 lb/hr
	6.83 TPY	0.32 TPY	0.094 TPY
VOC	9.6 ppmvd @ 3% O ₂	0.11 g/bhp	0.1 g/kW
	0.0041 lb/MMBtu	0.004 lb/MMBtu	0.007 lb/MMBtu
	0.38 lb/hr	0.53 lb/hr	0.069 lb/hr
	0.75 TPY	0.08 TPY	0.010 TPY
PM ₁₀ /PM _{2.5}	N/A ppmvd @ 3% O ₂	0.03 g/bhp	0.13 g/kW
_	0.007 lb/MMBtu	0.00003 lb/MMBtu	0.00023 lb/MMBtu
_	0.65 lb/hr	0.15 lb/hr	0.09 lb/hr
	1.29 TPY	0.02 TPY	0.014 TPY
SO ₂	0.0015 lb/MMBtu	0.0015 lb/MMBtu	0.0015 lb/MMBtu
	0.14 lb/hr	0.02 lb/hr	0.0037 lb/hr
	0.28 TPY	0.003 TPY	0.0006 TPY
H_2SO_4	0.00011 lb/MMBtu	0.00011 lb/MMBtu	0.00011 lb/MMBtu
	0.011 lb/hr	0.00166 lb/hr	0.00028 lb/hr
	0.02 TPY	0.0002 TPY	0.00004 TPY
Pb	4.9E-07 lb/MMBtu	7.7E-07 lb/MMBtu	7.7E-07 lb/MMBtu
	4.5E-05 lb/hr	1.1E-05 lb/hr	1.9E-06 lb/hr
	9.1E-05 TPY	1.7E-06 TPY	2.8E-07 TPY
CO ₂	116.9 lb/MMBtu	163.1 lb/MMBtu	163.1 lb/MMBtu
	10,802 lb/hr	2,354 lb/hr	400 lb/hr
	21,605 TPY	353 TPY	60 TPY
CH ₄	0.0022 lb/MMBtu	0.0066 lb/MMBtu	0.0066 lb/MMBtu
	0.2037 lb/hr	0.095 lb/hr	0.016 lb/hr
	0.41 TPY	0.0143 TPY	0.0024 TPY
N ₂ O	0.00022 lb/MMBtu	0.0013 lb/MMBtu	0.0013 lb/MMBtu
Ī	0.0204 lb/hr	1.9E-02 lb/hr	0.00324135 lb/hr
	0.041 TPY	2.9E-03 TPY	4.9E-04 TPY
CO ₂ e	10,814 lb/hr	2,362 lb/hr	401 lb/hr
ľ	21,627 TPY	354 TPY	60 TPY

NOTES:

Natural Gas SO2 emissions based upon a sulfur content of 0.5 gr/100 dscf

ULSD SO2 emissions based upon a sulfur content of 15 ppmw

Aux Boiler and Gas Heater criteria pollutant emission factors from BACT analysis

Emergency Generator criteria pollutant emission factors based on Tier 2 emission standards in 40 CFR 89.

Fire Pump criteria pollutant emission factors based on post -2009 emission standards in 40 CFR 60 Subpart IIII.

H2SO4 emissions assume a 5% conversion of SO2 --> SO3 (on a molar basis)

Fuel specific CO2, CH4 and N2O emission factors from 40 CFR 98, Subpart C

Pb emission factor for ULSD from AP-42 Section 3.1

Potential HAP Emissions (tpy) CPV Towantic Energy, LLC

		Potential A	nnual Emis	sions (tpy)		
HAP	CTGs	HRSGs	Auxiliary	Em.	Fire	TOTALS
	0103	111/303	Boiler	Generator	Pump	
Organic Compounds						
Acetaldehyde	7.80E-01	0.00E+00	0	5.46E-05	2.82E-04	7.81E-01
Acrolein	1.25E-01	0.00E+00	0	1.71E-05	3.40E-05	1.25E-01
Benzene	3.29E-01	6.23E-04	3.88E-04	1.68E-03	3.43E-04	3.32E-01
1,3-Butadiene	3.59E-02	0.00E+00	0	0	1.44E-05	3.59E-02
Dichlorobenzene	0.00E+00	3.56E-04	2.22E-04	0	0	5.78E-04
Ethylbenzene	6.24E-01	0.00E+00	0	0	0	6.24E-01
Formaldehyde	2.67E+00	2.23E-02	1.37E-02	1.71E-04	4.34E-04	2.70E+00
Hexane	0.00E+00	5.34E-01	3.33E-01	0	0	8.67E-01
Propylene oxide	5.66E-01	0.00E+00	0	8.34E-03	1.31E-03	5.75E-01
Toluene	2.54E+00	1.01E-03	6.10E-04	6.08E-04	1.50E-04	2.54E+00
Xylene	1.25E+00	0.00E+00	0	4.18E-04	1.05E-04	1.25E+00
PAHs						
Acenaphthene	0	5.34E-07	3.33E-07	3.07E-06	5.22E-07	4.46E-06
Acenaphthylene	0	5.34E-07	4.44E-07	1.10E-04	1.86E-05	1.29E-04
Anthracene	0	7.12E-07	3.33E-07	4.05E-06	6.87E-07	5.78E-06
Benzo(a)anthracene	0	5.34E-07	3.33E-07	3.64E-06	6.17E-07	5.12E-06
Benzo(a)pyrene	0	3.56E-07	2.22E-07	4.07E-07	6.91E-08	1.05E-06
Benzo(b)fluoranthene	0	5.34E-07	3.33E-07	2.15E-07	3.64E-08	1.12E-06
Benzo(g,h,i)perylene	0	3.56E-07	2.22E-07	1.06E-06	1.80E-07	1.82E-06
Benzo(k)fluoranthene	0	5.34E-07	3.33E-07	3.36E-07	5.70E-08	1.26E-06
Chrysene	0	5.34E-07	3.33E-07	7.64E-07	1.30E-07	1.76E-06
Dibenz(a,h)anthracene	0	3.56E-07	2.22E-07	1.26E-06	2.14E-07	2.05E-06
7,12-Dimethylbenz(a) anthracene	0	4.75E-06	2.96E-06	0	0	7.71E-06
Fluoranthene	0	8.91E-07	5.36E-07	1.65E-05	2.80E-06	2.07E-05
Fluorene	0	8.31E-07	4.99E-07	6.32E-05	1.07E-05	7.53E-05
Indeno(1,2,3-cd)pyrene	0	5.34E-07	3.33E-07	8.12E-07	1.38E-07	1.82E-06
3-Methylchloranthrene	0	5.34E-07	3.33E-07	0	0	8.67E-07
2-Methylnaphthalene	0	7.12E-06	4.44E-06	0	0	1.16E-05
Naphthalene	8.56E-02	1.81E-04	1.15E-04	1.84E-04	3.12E-05	8.61E-02
Phenanthrene	0	5.05E-06	3.14E-06	6.37E-05	1.08E-05	8.27E-05
Pyrene	0	1.48E-06	9.06E-07	1.03E-05	1.76E-06	1.45E-05
TOTAL PAH	4.57E-02	2.07E-04	1.26E-04	3.64E-04	6.17E-05	4.64E-02
Metals						
Arsenic	7.07E-03	5.94E-05	3.70E-05	1.00E-07	1.70E-08	7.17E-03
Beryllium	7.67E-04	3.56E-06	2.22E-06	0.00E+00	0.00E+00	7.73E-04
Cadmium	2.97E-02	3.27E-04	2.03E-04	1.11E-08	1.89E-09	3.02E-02
Chromium	4.62E-02	4.16E-04	2.59E-04	2.68E-05	4.56E-06	4.69E-02

Potential HAP Emissions (tpy) CPV Towantic Energy, LLC

		Potential A	nnual Emis	sions (tpy)		
HAP	CTGs	HRSGs	Auxiliary	Em.	Fire	TOTALS
	0103	1111003	Boiler	Generator	Pump	
Chromium VI	8.32E-03	7.48E-05	4.62E-05	4.85E-06	8.23E-07	8.45E-03
Cobalt	1.60E-03	2.43E-05	1.52E-05	0.00E+00	0.00E+00	1.64E-03
Lead	3.36E-02	1.45E-04	9.06E-05	1.67E-06	2.83E-07	3.39E-02
Manganese	1.37E+00	1.10E-04	6.84E-05	6.11E-07	1.04E-07	1.37E+00
Mercury	6.94E-03	7.42E-05	4.62E-05	2.23E-08	3.79E-09	7.06E-03
Nickel	4.89E-02	6.23E-04	3.88E-04	3.20E-06	5.44E-07	4.99E-02
Selenium	4.35E-02	7.12E-06	4.44E-06	5.54E-07	9.41E-08	4.35E-02
Max. Single HAP						2.70
Total All HAPs	1.06E+01	5.61E-01	3.49E-01	1.21E-02	2.82E-03	11.56

HAP Emission Factors CPV Towantic Energy, LLC

	C	ΓG Emission Facto	ors
HAP	CTG	CTG	HRSG
	(gas)	(oil)	
	lb/MMBtu	lb/MMBtu	lb/MMBtu
Organic Compounds		Т	T
Acetaldehyde	4.00E-05		
Acrolein	6.40E-06		
Benzene	1.20E-05	5.50E-05	2.10E-06
1,3-Butadiene	4.30E-07	1.60E-05	
Dichlorobenzene			1.20E-06
Ethylbenzene	3.20E-05		
Formaldehyde	1.12E-04	2.80E-04	7.50E-05
Hexane			1.80E-03
Propylene oxide	2.90E-05		
Toluene	1.30E-04		3.40E-06
Xylene	6.40E-05		
PAHs			
Acenaphthene			1.80E-09
Acenaphthylene			1.80E-09
Anthracene			2.40E-09
Benzo(a)anthracene			1.80E-09
Benzo(a)pyrene			1.20E-09
Benzo(b)fluoranthene			1.80E-09
Benzo(g,h,i)perylene			1.20E-09
Benzo(k)fluoranthene			1.80E-09
Chrysene			1.80E-09
Dibenz(a,h)anthracene			1.20E-09
7,12-Dimethylbenz(a) anthracene			1.60E-08
Fluoranthene			3.00E-09
Fluorene			2.80E-09
Indeno(1,2,3-cd)pyrene			1.80E-09
3-Methylchloranthrene			1.80E-09
2-Methylnaphthalene			2.40E-08
Naphthalene	1.30E-06	3.50E-05	6.10E-07
Phenanthrene			1.70E-08
Pyrene			5.00E-09
TOTAL PAH	2.20E-06	1.61E-06	6.98E-07
Metals			
Arsenic	2.00E-07	1.84E-06	2.00E-07
Beryllium	1.20E-08	3.10E-07	1.20E-08
Cadmium	1.10E-06	4.80E-06	1.10E-06
Chromium	1.40E-06	1.10E-05	1.40E-06

HAP Emission Factors CPV Towantic Energy, LLC

	C1	G Emission Facto	ors
НАР	CTG (gas)	CTG (oil)	HRSG
	lb/MMBtu	lb/MMBtu	lb/MMBtu
Chromium VI	2.52E-07	1.98E-06	2.52E-07
Cobalt	8.20E-08		8.20E-08
Lead	4.90E-07	1.40E-05	4.90E-07
Manganese	3.70E-07	7.90E-04	3.70E-07
Mercury	2.50E-07	1.20E-06	2.50E-07
Nickel	2.10E-06	4.60E-06	2.10E-06
Selenium	2.40E-08	2.50E-05	2.40E-08
Max. Single HAP			
Total All HAPs	4.36E-04	1.24E-03	1.89E-03

Notes:

- 1. Blank entry indicates no emission factor reported in the reference cited.
- 2. Organic HAP emission factors for CTGs are from Tables 3.1-3 and 3.1.4 of AP-42 except gas-firing for formaldehyde which is based on the California Air Resources Board air toxics emission factor database. Metal HAP emission factors for gas firing are from AP-42 Table 1.4-4, for oil firing from AP-42 Table 3.1-5 except for arsenic which is based on the California Air Resources Board air toxics emission factor database.
- 3. Emission factors for the HRSG and auxiliary boiler are from AP-42 Tables 1.4-3 and 1.4-4.
- 4. Emission factors for organics from the emergency diesel generator are from AP-42 Tables 3.4-3 and 3.4-4, for the fire pump from AP-42 Table 3.3-2.
- 5. Metal emission factors for the emergency generator and fire pump are based on the paper "Survey of Ultra-Trace Metals in Gas Turbine Fuels", 11th Annual International Petroleum Conference, Oct 12-15, 2004. Where trace metals were detected in any of 13 samples, the average result is used. Where no metals were detected in any of 13 samples, the detection limit was used.
- 6. Hexavalent chrome is based on 18% of the total chrome emissions per EPA 453/R-98-004a.

Potential Ancillary Source HAP Emissions (lb/hr) CPV Towantic Energy, LLC

НАР	Auxilia	ary Boiler	Em. G	enerator	Fire	Pump
	lb/MMBtu	lb/hr	lb/MMBtu	lb/hr	lb/MMBtu	lb/hr
Organic Compounds	l .					
Acetaldehyde		0.00E+00	2.52E-05	3.64E-04	7.67E-04	1.88E-03
Acrolein		0.00E+00	7.88E-06	1.14E-04	9.25E-05	2.27E-04
Benzene	2.10E-06	1.94E-04	7.76E-04	1.12E-02	9.33E-04	2.29E-03
1,3-Butadiene		0.00E+00		0.00E+00	3.91E-05	9.58E-05
Dichlorobenzene	1.20E-06	1.11E-04		0.00E+00		0.00E+00
Ethylbenzene		0.00E+00		0.00E+00		0.00E+00
Formaldehyde	7.40E-05	6.84E-03	7.89E-05	1.14E-03	1.18E-03	2.89E-03
Hexane	1.80E-03	1.66E-01		0.00E+00		0.00E+00
Propylene oxide		0.00E+00	3.85E-03	5.56E-02	3.56E-03	8.72E-03
Toluene	3.30E-06	3.05E-04	2.81E-04	4.06E-03	4.09E-04	1.00E-03
Xylene		0.00E+00	1.93E-04	2.79E-03	2.85E-04	6.98E-04
PAHs						
Acenaphthene	1.80E-09	1.66E-07	1.42E-06	2.05E-05	1.42E-06	3.48E-06
Acenaphthylene	2.40E-09	2.22E-07	5.06E-05	7.30E-04	5.06E-05	1.24E-04
Anthracene	1.80E-09	1.66E-07	1.87E-06	2.70E-05	1.87E-06	4.58E-06
Benzo(a)anthracene	1.80E-09	1.66E-07	1.68E-06	2.43E-05	1.68E-06	4.12E-06
Benzo(a)pyrene	1.20E-09	1.11E-07	1.88E-07	2.71E-06	1.88E-07	4.61E-07
Benzo(b)fluoranthene	1.80E-09	1.66E-07	9.91E-08	1.43E-06	9.91E-08	2.43E-07
Benzo(g,h,i)perylene	1.20E-09	1.11E-07	4.89E-07	7.06E-06	4.89E-07	1.20E-06
Benzo(k)fluoranthene	1.80E-09	1.66E-07	1.55E-07	2.24E-06	1.55E-07	3.80E-07
Chrysene	1.80E-09	1.66E-07	3.53E-07	5.10E-06	3.53E-07	8.65E-07
Dibenz(a,h)anthracene	1.20E-09	1.11E-07	5.83E-07	8.42E-06	5.83E-07	1.43E-06
7,12-Dimethylbenz(a) anthracene	1.60E-08	1.48E-06		0.00E+00		0.00E+00
Fluoranthene	2.90E-09	2.68E-07	7.61E-06	1.10E-04	7.61E-06	1.86E-05
Fluorene	2.70E-09	2.49E-07	2.92E-05	4.21E-04	2.92E-05	7.15E-05
Indeno(1,2,3-cd)pyrene	1.80E-09	1.66E-07	3.75E-07	5.41E-06	3.75E-07	9.19E-07
3-Methylchloranthrene	1.80E-09	1.66E-07		0.00E+00		0.00E+00
2-Methylnaphthalene	2.40E-08	2.22E-06		0.00E+00		0.00E+00
Naphthalene	6.20E-07	5.73E-05	8.48E-05	1.22E-03	8.48E-05	2.08E-04
Phenanthrene	1.70E-08	1.57E-06	2.94E-05	4.24E-04	2.94E-05	7.20E-05
Pyrene	4.90E-09	4.53E-07	4.78E-06	6.90E-05	4.78E-06	1.17E-05
TOTAL PAH	6.80E-07	6.28E-05	1.68E-04	2.43E-03	1.68E-04	4.12E-04
Metals						
Arsenic	2.00E-07	1.85E-05	4.62E-08	6.67E-07	4.62E-08	1.13E-07
Beryllium	1.20E-08	1.11E-06		0.00E+00		0.00E+00
Cadmium	1.10E-06	1.02E-04	5.13E-09	7.41E-08	5.13E-09	1.26E-08

Potential Ancillary Source HAP Emissions (lb/hr) CPV Towantic Energy, LLC

НАР	Auxilia	ary Boiler	Em. G	Senerator	Fire	Fire Pump		
	lb/MMBtu	lb/hr	lb/MMBtu	lb/hr	lb/MMBtu	lb/hr		
Chromium	1.40E-06	1.29E-04	1.24E-05	1.79E-04	1.24E-05	3.04E-05		
Chromium VI	2.50E-07	2.31E-05	2.24E-06	3.23E-05	2.24E-06	5.49E-06		
Cobalt	8.20E-08	7.58E-06		0.00E+00		0.00E+00		
Lead	4.90E-07	4.53E-05	7.69E-07	1.11E-05	7.69E-07	1.88E-06		
Manganese	3.70E-07	3.42E-05	2.82E-07	4.07E-06	2.82E-07	6.91E-07		
Mercury	2.50E-07	2.31E-05	1.03E-08	1.49E-07	1.03E-08	2.52E-08		
Nickel	2.10E-06	1.94E-04	1.48E-06	2.14E-05	1.48E-06	3.63E-06		
Selenium	2.40E-08	2.22E-06	2.56E-07	3.70E-06	2.56E-07	6.27E-07		
Max. Single HAP			•		-			
Total All HAPs	1.89E-03	1.74E-01	5.61E-03	8.10E-02	7.66E-03	1.88E-02		

Potential HAP Emissions (lb/hr/unit) - 7HA01 CPV Towantic Energy, LLC

AMBIENT CONDITIONS:			-14.2	°F			I		59°F			90	°F	Ī		10	0°F		ĺ
GE CASE #:	#1	#2	#3	#4	#28	#29	#35	#9	#31	#32	#11	#36	#13	#14	#16	#17	#23	#24	#22
Fuel	Natural Gas																		
Number of GTs Operating	2	2	1	2	2	2	2	2	2	2	2	2	2	2	1	2	2	2	2
GT Heat Input (MMBtu/hr/unit, HHV	2,526	2,526	2,526	2,526	2,047	1,582	2,426	2,426	2,017	1,538	555	2,213	2,303	2,297	2,297	2,297	1,686	1,308	1,170
DB Heat Input (MMBtu/hr/unit, HHV)	198	97	962	0	0	0	110	0	0	0	0	209	0	190	766	0	0	0	0
НАР																			
Organic Compounds																			
Acetaldehyde	1.011E-01	1 011F-01	1.011E-01	1 011F-01	8 188F-02	6.328F-02	9 705F-02	9.705E-02	8 066F-02	6 150F-02	2 221F-02	8 853F-02	9.214E-02	9 187F-02	9 187F-02	9.187E-02	6 742F-02	5 232F-02	4 680F-02
Acrolein	1.617E-02		1.617E-02					1.553E-02				1.416E-02				1.470E-02			
Benzene	3.073E-02		3.234E-02					2.911E-02					2.764E-02			2.756E-02			
1,3-Butadiene	1.086E-03	1.086E-03	1.086E-03	1.086E-03	8.802E-04	6.802E-04		1.043E-03					9.905E-04			9.876E-04			
Dichlorobenzene	2.375E-04		1.155E-03					0.000E+00					0.000E+00			0.000E+00			
Ethylbenzene	8.084E-02	8.084E-02	8.084E-02	8.084E-02	2 6.551E-02	5.062E-02	7.764E-02	7.764E-02	6.453E-02	4.920E-02	1.777E-02	7.082E-02	7.371E-02	7.349E-02	7.349E-02	7.349E-02	5.394E-02	4.185E-02	3.744E-02
Formaldehyde	2.978E-01	2.902E-01	3.551E-01	2.830E-01	2.293E-01	1.772E-01	2.800E-01	2.717E-01	2.259E-01	1.722E-01	6.219E-02	2.635E-01	2.580E-01	2.715E-01	3.147E-01	2.572E-01	1.888E-01	1.465E-01	1.310E-01
Hexane	3.562E-01	1.742E-01	1.732E+00	0.000E+0	0.000E+00	0.000E+00	1.982E-01	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.754E-01	0.000E+00	3.416E-01	1.379E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
Propylene oxide	7.326E-02	7.326E-02	7.326E-02	7.326E-02	5.936E-02	4.588E-02	7.036E-02	7.036E-02	5.848E-02	4.459E-02	1.610E-02	6.418E-02	6.680E-02	6.660E-02	6.660E-02	6.660E-02	4.888E-02	3.793E-02	3.393E-02
Toluene	3.291E-01	3.288E-01	3.317E-01	3.284E-01	2.661E-01	2.056E-01	3.158E-01	3.154E-01	2.622E-01	1.999E-01	7.218E-02	2.884E-01	2.994E-01	2.992E-01	3.012E-01	2.986E-01	2.191E-01	1.700E-01	1.521E-01
Xylene	1.617E-01	1.617E-01	1.617E-01	1.617E-01	I 1.310E-01	1.012E-01	1.553E-01	1.553E-01	1.291E-01	9.841E-02	3.554E-02	1.416E-01	1.474E-01	1.470E-01	1.470E-01	1.470E-01	1.079E-01	8.371E-02	7.489E-02
PAHs	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
Acenaphthene	3.562E-07	1.742E-07	1.732E-06	0.000E+0	0.000E+00	0.000E+00	1.982E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.754E-07	0.000E+00	3.416E-07	1.379E-06	0.000E+00	0.000E+00	0.000E+00	0.000E+00
Acenaphthylene	3.562E-07	1.742E-07	1.732E-06	0.000E+0	0.000E+00	0.000E+00	1.982E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.754E-07	0.000E+00	3.416E-07	1.379E-06	0.000E+00	0.000E+00	0.000E+00	0.000E+00
Anthracene	4.750E-07	2.323E-07	2.309E-06	0.000E+0	0.000E+00	0.000E+00	2.642E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00	5.006E-07	0.000E+00	4.555E-07	1.838E-06	0.000E+00	0.000E+00	0.000E+00	0.000E+00
Benzo(a)anthracene	3.562E-07	1.742E-07	1.732E-06	0.000E+0	0.000E+00	0.000E+00	1.982E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.754E-07	0.000E+00	3.416E-07	1.379E-06	0.000E+00	0.000E+00	0.000E+00	0.000E+00
Benzo(a)pyrene	2.375E-07	1.161E-07	1.155E-06	0.000E+0	0.000E+00	0.000E+00	1.321E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00	2.503E-07	0.000E+00	2.277E-07	9.192E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00
Benzo(b)fluoranthene	3.562E-07	1.742E-07	1.732E-06	0.000E+0	0.000E+00	0.000E+00	1.982E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.754E-07	0.000E+00	3.416E-07	1.379E-06	0.000E+00	0.000E+00	0.000E+00	0.000E+00
Benzo(g,h,i)perylene	2.375E-07	1.161E-07	1.155E-06	0.000E+0	0.000E+00	0.000E+00	1.321E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00	2.503E-07	0.000E+00	2.277E-07	9.192E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00
Benzo(k)fluoranthene	3.562E-07	1.742E-07	1.732E-06	0.000E+0	0.000E+00	0.000E+00	1.982E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.754E-07	0.000E+00	3.416E-07	1.379E-06	0.000E+00	0.000E+00	0.000E+00	0.000E+00
Chrysene	3.562E-07	1.742E-07	1.732E-06	0.000E+0	0.000E+00	0.000E+00	1.982E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.754E-07	0.000E+00	3.416E-07	1.379E-06	0.000E+00	0.000E+00	0.000E+00	0.000E+00
Dibenz(a,h)anthracene	2.375E-07	1.161E-07	1.155E-06	0.000E+0	0.000E+00	0.000E+00	1.321E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00	2.503E-07	0.000E+00	2.277E-07	9.192E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00
7,12-Dimethylbenz(a) anthracene	3.166E-06	1.549E-06	1.539E-05	0.000E+0	0.000E+00	0.000E+00	1.761E-06	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.337E-06	0.000E+00	3.036E-06	1.226E-05	0.000E+00	0.000E+00	0.000E+00	0.000E+00
Fluoranthene	5.937E-07	2.904E-07	2.886E-06	0.000E+0	0.000E+00	0.000E+00	3.303E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00	6.257E-07	0.000E+00	5.693E-07	2.298E-06	0.000E+00	0.000E+00	0.000E+00	0.000E+00
Fluorene	5.541E-07		2.694E-06				3.083E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00	5.840E-07	0.000E+00	5.314E-07	2.145E-06	0.000E+00	0.000E+00	0.000E+00	0.000E+00
Indeno(1,2,3-cd)pyrene	3.562E-07	1.742E-07	1.732E-06	0.000E+00	0.000E+00	0.000E+00	1.982E-07	0.000E+00	0.000E+00	0.000E+00	0.000E+00		0.000E+00			0.000E+00			
3-Methylchloranthrene	3.562E-07		1.732E-06					0.000E+00					0.000E+00			0.000E+00			
2-Methylnaphthalene	4.750E-06		2.309E-05					0.000E+00					0.000E+00			0.000E+00			
Naphthalene	3.405E-03		3.871E-03					3.154E-03					2.994E-03			2.986E-03			
Phenanthrene	3.364E-06		1.636E-05					0.000E+00					0.000E+00			0.000E+00			
Pyrene	9.895E-07		4.811E-06					0.000E+00					0.000E+00			0.000E+00			
TOTAL PAH	5.696E-03		6.230E-03					5.337E-03					5.067E-03			5.053E-03			
Metals	0.000E+00		0.000E+00					0.000E+00					0.000E+00			0.000E+00			
Arsenic	5.448E-04		6.977E-04					4.852E-04				4.844E-04				4.593E-04			
Beryllium	3.269E-05		4.186E-05					2.911E-05					2.764E-05			2.756E-05			
Cadmium	2.997E-03		3.837E-03					2.669E-03					2.534E-03			2.526E-03			
Chromium VI	3.814E-03		4.884E-03					3.397E-03					3.225E-03			3.215E-03			
Chromium VI	6.865E-04		8.791E-04					6.114E-04					5.805E-04			5.788E-04			
Cobalt	2.234E-04		2.861E-04					1.989E-04					1.889E-04			1.883E-04			
Lead	1.335E-03		1.709E-03					1.189E-03					1.129E-03			1.125E-03			
Manganese	1.008E-03		1.291E-03					8.977E-04					8.523E-04			8.498E-04			
Mercury	6.811E-04		8.721E-04					6.065E-04					5.758E-04			5.742E-04			
Nickel	5.721E-03		7.326E-03					5.095E-03				5.086E-03				4.823E-03			
Selenium	6.538E-05	ხ.∠ყნ E- 05	8.372E-05	ნ.∪ნ3E-05	4.913E-05	3.797E-05	o.U8/E-05	5.823E-05	4.840E-05	ა.ხყ0E-05	1.333E-05	5.812E-05	ე.ე∠გF-02	5.96/E-05	7.350E-05	5.512E-05	4.045E-05	ა.1ა9E-05	∠.8U8E-U5

Potential HAP Emissions CPV Towantic Energy, LL

AMBIENT CONDITIONS:		-14	.2F		I	59°F	1	90°F		10	0°F	
GE CASE #:	#37	#46	#47	#38	#41	#52	#53	#42	#43	#44	#51	#45
Fuel	Distillate O											
Number of GTs Operating	2	1	2	2	2	2	2	2	2	1	2	2
GT Heat Input (MMBtu/hr/unit, HHV		2,524	2,022	1,555	2,389	1,891	1,459	2,227	2,217	2,068	1,664	1,293
DB Heat Input (MMBtu/hr/unit, HHV)	0	0	0	0	0	0	0	0	0	0	0	0
HAP					_		•	_	-			
Organic Compounds												
Acetaldehyde	0.000E±00	0.000E+00	0.000E±00	0.000E±00	0.000E±00	0.000E±00	0.000E±00	0.000E+00	0.000E±00	0.000E±00	0.000E±00	0.000E+00
Acrolein		0.000E+00						0.000E+00				0.000E+00
Benzene		1.388E-01					8.023E-02	1.225E-01				7.110E-02
1.3-Butadiene		4.038E-02				3.025E-02		3.563E-02			2.663E-02	
Dichlorobenzene		0.000E+00						0.000E+00				0.000E+00
Ethylbenzene		0.000E+00						0.000E+00				0.000E+00
Formaldehyde		7.067E-01				5.294E-01		6.236E-01				3.620E-01
Hexane		0.000E+00						0.000E+00				0.000E+00
Propylene oxide		0.000E+00						0.000E+00				0.000E+00
Toluene		0.000E+00				0.000E+00		0.000E+00				0.000E+00
Xylene		0.000E+00						0.000E+00				0.000E+00
PAHs		0.000E+00						0.000E+00				0.000E+00
Acenaphthene		0.000E+00				0.000E+00		0.000E+00				0.000E+00
Acenaphthylene		0.000E+00						0.000E+00				0.000E+00
Anthracene		0.000E+00						0.000E+00				0.000E+00
Benzo(a)anthracene		0.000E+00			0.000E+00			0.000E+00				0.000E+00
Benzo(a)pyrene		0.000E+00						0.000E+00				0.000E+00
Benzo(b)fluoranthene		0.000E+00				0.000E+00		0.000E+00				0.000E+00
Benzo(g,h,i)perylene		0.000E+00						0.000E+00				0.000E+00
Benzo(k)fluoranthene		0.000E+00						0.000E+00				0.000E+00
Chrysene		0.000E+00						0.000E+00				0.000E+00
Dibenz(a,h)anthracene		0.000E+00						0.000E+00				0.000E+00
7,12-Dimethylbenz(a) anthracene		0.000E+00					0.000E+00	0.000E+00				0.000E+00
Fluoranthene		0.000E+00						0.000E+00				0.000E+00
Fluorene		0.000E+00						0.000E+00				0.000E+00
Indeno(1,2,3-cd)pyrene		0.000E+00						0.000E+00				0.000E+00
3-Methylchloranthrene		0.000E+00						0.000E+00				0.000E+00
2-Methylnaphthalene		0.000E+00						0.000E+00				0.000E+00
Naphthalene		8.834E-02				6.617E-02		7.794E-02				4.525E-02
Phenanthrene		0.000E+00						0.000E+00				0.000E+00
Pyrene		0.000E+00						0.000E+00				0.000E+00
TOTAL PAH		4.053E-03				3.036E-03		3.576E-03				2.076E-03
Metals		0.000E+00						0.000E+00				0.000E+00
Arsenic		4.649E-03				3.482E-03		4.101E-03				2.381E-03
Beryllium	7.825E-04	7.825E-04	6.268E-04	4.819E-04	7.405E-04	5.861E-04	4.522E-04	6.904E-04	6.874E-04	6.409E-04	5.159E-04	4.008E-04
Cadmium	1.212E-02	1.212E-02	9.705E-03	7.462E-03	1.147E-02	9.075E-03	7.002E-03	1.069E-02	1.064E-02	9.924E-03	7.988E-03	6.205E-03
Chromium	2.776E-02	2.776E-02	2.224E-02	1.710E-02	2.628E-02	2.080E-02	1.605E-02	2.450E-02	2.439E-02	2.274E-02	1.831E-02	1.422E-02
Chromium VI		4.998E-03				3.743E-03		4.409E-03				2.560E-03
Cobalt		0.000E+00						0.000E+00				0.000E+00
Lead	3.534E-02	3.534E-02	2.831E-02	2.176E-02	3.344E-02	2.647E-02	2.042E-02	3.118E-02	3.104E-02	2.895E-02	2.330E-02	1.810E-02
Manganese	1.994E+00	1.994E+00	1.597E+00	1.228E+00		1.494E+00		1.759E+00				1.021E+00
Mercury		3.029E-03					1.750E-03	2.672E-03				1.551E-03
Nickel	1.161E-02	1.161E-02	9.301E-03	7.151E-03	1.099E-02	8.697E-03	6.710E-03	1.024E-02	1.020E-02	9.511E-03	7.655E-03	5.947E-03
Selenium		6.310E-02					3.647E-02	5.567E-02				3.232E-02
	. /-											

Summary of Estimated Fugitive GHG Emissions CPV Towantic Energy, LLC

Circuit Breaker SF6 Emissions

SF6 Storage Capacity	111 lbs
SF6 Leak Rate	1.0% per year
SF6 emissions	1.11 lbs/year
GHG emissions (CO2e)	12.7 tons per year

Natural Gas Handling Fugitive Emissions

Component Type	Component Count	Emission factor (scfh/component) ¹	CH4 Emissions (tpy) ²	GHG Emissions (tpy)
Connector	10	1.69	3.08	77.04
Flanges, Regulator, Other	10	0.772	1.41	35.19
Control Valves	10	9.34	17.03	425.76
Orifice Meter	3	0.212	0.12	2.90
TOTALS			21.64	540.9

¹ Emission factors are from 40 CFR 98, Subpart W, Table W-7

² Conservatively assumes 100% CH4

Summary of Baseline Emissions CPV Towantic Energy, LLC

SUMMARY OF BASELINE EMISSION RATES AND REDUCTIONS

	Combus	stion Turbir	nes #1 and	#2 ¹	Auxiliary Boiler						
Pollutant	Baseline Emission Rate (lb/MMBtu) ²	Baseline (tpy) ³	BACT (tpy) ⁴	Reduction (tpy)	Baseline Emission Rate (lb/MMBtu) ⁵	Baseline (tpy) ⁶	BACT (tpy) ⁷	Reduction (tpy)			
NO_x	0.32	3400	94.7	3306	0.10	18.5	2.0	16.5			
СО	0.082	871.4	35.0	836.4	0.084	15.5	6.8	8.7			
VOC	0.0021	22.3	18.2	4.1	0.0055	1.02	0.75	0.3			
GHGs ⁸	119	2,032,758	1,328,009	704,749	N/A	N/A	N/A	N/A			

¹ Emissions presented are on a per turbine basis

² From AP-42 Section 3.1 for uncontrolled natural gas fired combustion turbines except for GHGs

³ Based upon the rated heat input of the combustion turbine firing gas at 59F of 2,426 MMBtu/hr for 8,760 hr/yr

⁴ Proposed ton per year emissions excluding contribution from startup and shutdown emissions.

⁵ From AP-42 Section 1.4 for uncontrolled natural gas fired boilers <100 MMBtu/hr.

⁶ Based upon the rated heat input of the auxiliary boiler of 92.4MMBtu/hr for 4,000 hr/yr

⁷ Proposed ton per year emissions.

⁸ Baseline based upon conventional steam generation with a heat rate of 10,000 Btu/kWh for 390MW firing gas


Pipeline Costs for Carbon Transport CPV Towantic Energy, LLC

Diameter	16	inches
Miles	100	miles
Motoriolo	¢24 702 045	\$70,350 + \$2.01×L × (330.5 × D ² + 686.7 × D + 26,960)
Materials		
Labor	. , ,	\$371,850 + \$2.01 × L × (343.2 × D ² + 2,074 × D + 170,013)
Misc	. , ,	$147,250 + 1.55 \times L \times (8,417 \times D + 7,234)$
Right of Way	\$5,045,760	\$51,200 + \$1.28 × L × (577 × D + 29,788)
Surge Tank	\$1,244,724	Fixed cost = $$1,244,724$
Control System	\$111,907	Fixed cost = \$111,907
TOTAL	\$112,123,162	

Source: National Energy Technology Lab report "Carbon Dioxide Transport and Storage Costs in NETL Studies" (March 2013)

Combustion Turbine Maximum HAP Emission Rates for MASC - 7HA.01 CPV Towantic Energy, LLC

	Er	mission Factors		Emissio	n Rates
HAP	CTG - Gas Firing	CTG - Oil Firing	Duct Burners	Gas Firing	Oil Firing
	lb/MMBtu	lb/MMBtu	lb/MMBtu	lb/hr	lb/hr
Organic Compounds					
Acetaldehyde	4.00E-05		4.00E-05	1.09E-01	0.00E+00
Acrolein	6.40E-06		6.40E-06	1.74E-02	0.00E+00
Benzene	1.20E-05	5.50E-05	1.20E-05	3.27E-02	1.39E-01
1,3-Butadiene	4.30E-07	1.60E-05	4.30E-07	1.17E-03	4.04E-02
Dichlorobenzene				0	0
Ethylbenzene	3.20E-05		3.20E-05	8.72E-02	0.00E+00
Formaldehyde	1.10E-04	2.80E-04	3.50E-04	3.47E-01	7.07E-01
Hexane				0	0
Propylene oxide	2.90E-05		2.90E-05	7.90E-02	0.00E+00
Toluene	1.30E-04		1.30E-04	3.54E-01	0.00E+00
Xylene	6.40E-05		6.40E-05	1.74E-01	0.00E+00
Naphthalene	1.30E-06	3.50E-05	1.30E-06	3.54E-03	8.83E-02
Metals					
Arsenic	2.00E-07	1.84E-06	2.00E-07	5.45E-04	4.65E-03
Beryllium	1.20E-08	3.10E-07	1.20E-08	3.27E-05	7.82E-04
Cadmium	1.10E-06	4.80E-06	1.10E-06	3.00E-03	1.21E-02
Chromium	1.40E-06	1.10E-05	1.40E-06	3.81E-03	2.78E-02
Chromium VI	2.50E-07		2.50E-07	6.81E-04	0.00E+00
Cobalt	8.20E-08		8.20E-08	2.23E-04	0.00E+00
Lead	4.90E-07	1.40E-05	4.90E-07	1.33E-03	3.53E-02
Manganese	3.70E-07	7.90E-04	3.70E-07	1.01E-03	1.99E+00
Mercury	2.50E-07	1.20E-06	2.50E-07	6.81E-04	3.03E-03
Nickel	2.10E-06	4.60E-06	2.10E-06	5.72E-03	1.16E-02
Selenium	2.40E-08	2.50E-05	2.40E-08	6.54E-05	6.31E-02



SIZE	DWG NO	SH	REV	REVISIONS						
Α	240A2083	1	F		REVISIONS					
THIS DOCUMENT SHALL BE REVISED			-	REV	DESCRIPTION	DATE (dd-mmm-yyyy)	APPROVED			
THIS REV	IN ITS ENTIRETY ALL SHEETS OF THIS DOCUMENT ARE THE SAME REVISION LEVEL AS INDICATED IN THE REVISION BLOCK		Ē	- А В С	Preliminary Issue Preliminary Issue Preliminary Issue Preliminary Issue	17-Mar-2014 17-Apr-2014 28-Apr-2014 01-May-2014	P. Kulkarni P. Kulkarni P. Kulkarni P. Kulkarni			
		D E F	Preliminary Issue Preliminary Issue Preliminary Issue	19-Jun-2014 08-Jul-2014 25-Aug-2014	P. Kulkarni P. Kulkarni P. Kulkarni					

Combined Cycle Systems

Combined Cycle Systems Emissions Estimates

2x1 7HA.01 ST-D602 40LSB ACC

© COPYRIGHT 2014 General Electric - Proprietary Information

All Rights Reserved. This document contains proprietary information. No part of this document may be used by or disclosed to others, reproduced, transmitted, stored in a retrieval system nor translated into any human or computer language, in any form or any means, electronic, mechanical magnetic, optical, chemical, manual or otherwise, without the prior written permission of the General Electric Company.

SIGNATURES	DATE (dd-mmm-yyyy)				GENERAL ELECTRIC COMPANY GENERAL ELECTRIC
PREPARED BY A. Kos	17-Mar-2014	g (GE Ene	ergy	INTERNATIONAL, INC. POWER PLANT SYSTEMS
ENVIRONMENTAL	47.14				
H. Xu	17-Mar-2014				
PROJECT ENGINEER				CPV Tow	vantic vantic
ISSUED					
		MADE FOR	: IPS # 974919		MDL - T218
FIRST MADE FOR:		SIZE A CAGE CODE NON			DWG NO 240A2083
Competitive Power Ventures	SCALE	NONE	PA#	SHEET 1 of 11	



Drawing Revision Status

Drawing Number: 240A2083

Revision	Date	Description
-	17-Mar-2014	Draft
А	17-Apr-2014	Added cases with GT using liquid fuel
В	28-Apr-2014	Added cases based on customer's request
С	01-May-2014	Added 2 additional cases based on customer's request, NOx for DO set at
D	19-Jun-2014	Added 4 cases for NG (20, 50, 59, 90F; fully fired to ST limits) Updated Distillate performance based on updated cycle deck
E	08-Jul-2014	HB's# 1, 33, 34 and 35 changed such that ST output ~280MW by reducing
		the amount of duct firing (as per direction from CPV)
F	25-Aug-2014	Updated Stack VOC Concentrations



OPERATING POINT		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Case Description		310/ DR Eiring	10% DB Firing	100% DB Firing	Unfired	19% DB Firing	Unfired	200/ DP Eiring	10% DB Firing	90% DR Eiring							
SITE CONDITIONS		21% DB FII III g	10% DB FILING	riilig	Offilied	Offilied	Offilieu	Offilied	Offilieu	Offified	Offilied	Offilied	13% DB FILIII	Offilied	20% DB FITTING	10% DB FILLING	00% DB FIIIIIg
Ambient Temperature	°F	-14.2	-14.2	-14.2	-14.2	-14.2	20	50	50	59	59	59	90	90	100	100	100
Ambient Pressure	psia	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3
Ambient Relative Humidity	%	20	20	20	20	20	60	60	60	60	60	60	60	60	40	40	40
PLANT STATUS																	
HRSG Duct Burner		Fired	Fired	Fired	Unfired	Fired	Unfired	Fired	Fired	Fired							
SCR		Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating
CO Catalyst		Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating
Evaporative Cooler state (On or Off) Gas Turbine Load	%	Off BASE	Off BASE	Off BASE	Off BASE	Off 47%	Off BASE	Off BASE	Off 96%	Off BASE	Off 97%	Off 30%	On BASE	On BASE	On BASE	On BASE	On BASE
Gas Turbines Operating	70	2	2	1	2	2	2	2	2	2	2	2	2	2	2	2	1
GT Diluent Injection Type		None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None
GT Diluent Injection Flow (per GT)	10^3 lb/hr	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
FUEL DATA																	
Fuel Type		NG	NG	NG	NG	NG	NG	NG	NG	NG	NG	NG	NG	NG	NG	NG	NG
HHV	BTU/lb			22808.87948		22808.87948					22808.87948			22808.87948			
LHV	BTU/lb	20571	20571	20571	20571	20571	20571	20571	20571	20571	20571	20571	20571	20571	20571	20571	20571
Fuel Mol. Wt.	lb/mole	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257
Fuel Bound Nitrogen	Wt %	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Fuel Sulfur Content	grains/100 SCF @ 60°F	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
HRSG DATA (PER UNIT)																	
HRSG EXIT EXHAUST GAS Composition:																	
Ar	mol %	0.8873	0.8887	0.8768	0.8901	0.8901	0.8900	0.8900	0.8900	0.8800	0.8801	0.8901	0.8572	0.8600	0.8570	0.8584	0.8483
CO2	mol %	4.3607	4.2075	5.5031	4.0604	3.8504	4.1100	4.1400	4.1200	4.1300	4.1104	3.5804	4.4363	4.1200	4.4450	4.2855	5.4198
H2O N2	mol % mol %	8.4465 74.7564	8.1478 74.8743	10.6753 73.8772	7.8608 74.9875	7.4607 75.1475	8.1600 74.7900	8.7300 74.3700	8.7000 74.3800	8.9900 74.1600	8.9609 74.1774	7.9308 74.5775	11.7666 72.2247	11.1600 72.4600	11.8129 72.1908	11.5070 72.3094	13.6822 71.4659
02	mol %	11.5491	11.8817	9.0676	12.2012	12.6513	12.0500	11.8700	11.9100	11.8400	11.8712	13.0213	10.7152	11.4000	10.6943	11.0397	8.5837
Molecular weight		28.4329	28.4517	28.2927	28.4698	28.4941	28.4417	28.3824	28.3838	28.3524	28.3534	28.4186	28.0762	28.1139	28.0722	28.0912	27.9560
Temperature	°F	182	189	170	196	179	190	185	184	183	182	170	190	196	197	200	170
Mass Flow	lb/hr	5021800	5017200	5057000	5012700	3151100	4923500	4725000	4571700	4647300	4545500	2460200	4395400	4386900	4385100	4380800	4411700
Actual Volume Flow	Actual ft3/hr	85039000	85830000	84463000	86691000	52979000	84426000	80592000	77841000	79080000	77212000	40908000	76329000	76805000	77005000	77159000	74572000
HRSG EXIT EXHAUST GAS EMISSIONS																	
NOx	ppmvd @ 15% O2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
NOx	lb/hr as NO2	20.9	20.1	26.8	19.4	11.5	19.3	18.7	18	18.4	17.9	8.4	18.9	17.4	18.8	18.1	23.3
со	ppmvd @ 15% O2	1.7	1.7	1.7	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	1.7	0.9	1.7	1.7	1.7
СО	lb/hr	10.8	10.4	13.8	5.31	3.16	5.28	5.12	4.93	5.03	4.9	2.3	9.76	4.78	9.75	9.38	12
VOC	ppmvd @ 15% O2	1.5	1.5	2	1	1	1	1	1	1	1	1	1.5	1	1.5	1.5	2
VOC	lb/hr as methane	5.13	4.94	8.82	3.37	2.01	3.35	3.25	3.13	3.19	3.11	1.46	4.63	3.03	4.63	4.45	7.24
CO2	lb/hr	339000	327000	433000	315000	187000	313000	303000	292000	298000	290000	136000	306000	283000	306000	294000	376000
NH3	ppmvd @ 15% O2	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
NH3	lb/hr	19.3	18.6	24.7	17.9	10.7	17.8	17.3	16.6	17	16.5	7.76	17.4	16.1	17.4	16.8	21.5
SOx Particulates - Filterable + Condensible,	lb/hr as SO2	4.848	4.668	6.204	4.488	2.712	4.536	4.392	4.236	4.308	4.2	1.98	4.428	4.092	4.416	4.26	5.448
Including Sulfates	lb/hr	20	19.5	20.4	9.73	8.71	9.75	9.68	9.6	9.64	9.58	8.33	20.2	9.53	20.1	19.2	18
Sulfuric Acid Mist	lb/hr	3.11	3	3.99	2.89	1.74	2.91	2.82	2.72	2.77	2.7	1.27	2.84	2.63	2.84	2.73	3.5

The notes page is an integral part of this document and must be reviewed prior to use of this data.



OPERATING POINT		17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
Case Description		Harffer of	240/ DD 51-1	400/ DD Fishs	720/ DD 51-1	Haffar d	H-Gd	Harffer of	H-fired	I to floor d	H-fld	U o Consul	H-fired	H-fired	H-fired	Ha Carad	LL-Cond
SITE CONDITIONS		Unfired	24% DB Firing	10% DB Firing	/3% DB Firing	Unfired											
Ambient Temperature	°F	100	100	100	100	100	100	100	100	100	50	50	-14.2	-14.2	-14.2	59	59
Ambient Pressure	psia	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3
Ambient Relative Humidity	%	40	40	40	40	40	40	40	40	40	60	60	20	20	20	60	60
PLANT STATUS																	
HRSG Duct Burner		Unfired	Fired	Fired	Fired	Unfired											
SCR		Operating															
CO Catalyst		Operating															
Evaporative Cooler state (On or Off) Gas Turbine Load	%	On BASE	Off BASE	Off BASE	Off BASE	Off BASE	Off 41%	Off 75%	Off 50%	Off BASE	Off 75%	Off 50%	Off 75%	Off 50%	Off BASE	Off 75%	Off 50%
Gas Turbines Operating	70	2	2	2	1	2	2	2	2	1	2	2	2	2	1	2	2
GT Diluent Injection Type		None															
GT Diluent Injection Flow (per GT)	10^3 lb/hr	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
FUEL DATA																	
<u>FUEL DATA</u> Fuel Type		NG															
HHV	BTU/lb		22808.87948			22808.87948					22808.87948				22808.87948		
LHV	BTU/lb	20571	20571	20571	20571	20571	20571	20571	20571	20571	20571	20571	20571	20571	20571	20571	20571
Fuel Mol. Wt.	lb/mole	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257	16.8257
Fuel Bound Nitrogen	Wt %	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Fuel Sulfur Content	grains/100 SCF @ 60°F	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
HRSG DATA (PER UNIT)																	
HRSG EXIT EXHAUST GAS Composition:																	
Ar	mol %	0.8599	0.8661	0.8683	0.8583	0.8699	0.8701	0.8701	0.8700	0.8699	0.8899	0.8900	0.8901	0.8901	0.8901	0.8800	0.8900
CO2	mol %	4.1196	4.4919	4.2472	5.3562	4.0696	3.5704	3.7404	3.5500	4.0696	4.0196	3.7200	4.0304	3.8904	4.0604	3.9800	3.6900
H2O	mol %	11.1889	11.2516	10.7808	12.9150	10.4390	9.4709	9.8010	9.4300	10.4390	8.4992	7.9200	7.8208	7.5408	7.8608	8.7000	8.1300
N2	mol %	72.4328	72.6664	72.8497	72.0191	72.9827	73.3673	73.2373	73.3800	72.9827	74.4526	74.6900	75.0075	75.1175	74.9875	74.2700	74.4900
O2	mol %	11.3989	10.7239	11.2540	8.8514	11.6388	12.7213	12.3512	12.7700	11.6388	12.1388	12.7800	12.2512	12.5613	12.2012	12.1700	12.8000
Molecular weight		28.1109	28.1380	28.1674	28.0344	28.1886	28.2487	28.2282	28.2515	28.1886	28.3969	28.4324	28.4709	28.4889	28.4698	28.3705	28.4074
Temperature	°F	203	191	194	170	198	183	197	190	186	180	179	190	180	208	180	179
Mass Flow Actual Volume Flow	lb/hr Actual ft3/hr	4376400 77400000	4104500 71241000	4098400 71399000	4126500 69556000	4094000 71628000	2585100 44130000	3552200 62023000	2909600 50212000	4094000 70418000	3853500 65175000	3173100 53491000	4031000 68987000	3234000 54529000	5012700 88197000	3828300 64798000	3155300 53237000
HRSG EXIT EXHAUST GAS EMISSIONS																	
NOx	ppmvd @ 15% O2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
NOx	lb/hr as NO2	17.4	17.8	16.8	21.5	16	8.85	12.8	9.89	16	14.8	11.3	15.5	12	19.4	14.5	11.1
СО	ppmvd @ 15% O2	0.9	1.7	1.7	1.7	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9
СО	lb/hr	4.76	9.21	8.68	11.1	4.39	2.42	3.49	2.71	4.39	4.05	3.08	4.24	3.28	5.31	3.98	3.04
VOC	ppmvd @ 15% O2	1	1.5	1.5	2	1	1	1	1	1	1	1	1	1	1	1	1
VOC	lb/hr as methane	3.02	4.37	4.12	6.76	2.79	1.54	2.22	1.72	2.79	2.57	1.96	2.69	2.08	3.37	2.53	1.93
CO2	lb/hr	282000	288000	272000	347000	260000	144000	207000	161000	260000	240000	183000	251000	194000	315000	236000	180000
NH3	ppmvd @ 15% O2	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
NH3	lb/hr	16.1	16.4	15.5	19.8	14.8	8.17	11.8	9.14	14.8	13.7	10.4	14.3	11.1	17.9	13.4	10.2
SOx Particulates - Filterable + Condensible,	lb/hr as SO2	4.08	4.176	3.936	5.028	3.768	2.076	3	2.328	3.768	3.468	2.64	3.636	2.808	4.488	3.42	2.604
Including Sulfates	lb/hr	9.52	17.6	19	17.2	9.26	8.38	8.86	8.51	9.26	9.11	8.67	9.19	8.76	9.73	9.08	8.65
Sulfuric Acid Mist	lb/hr	2.62	2.68	2.53	3.23	2.42	1.34	1.93	1.49	2.42	2.23	1.7	2.34	1.81	2.89	2.2	1.67

The notes page is an integral part of this document and must be reviewed prior to use of this data.



OPERATING POINT		33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48
Case Description		420/ DD Firir -	440/ DD Fining	440/ DD 51-1	220/ DD Firir -	H-fd	Harffer al	Harffer al	Hadina d	Ha Carad	Hadian d	H-fired	Hadian d	Harffer al	Hadian d	Ha Carad	Hadian d
SITE CONDITIONS		13% DB FIRING	11% DB Firing	11% DB FIRING	22% DB FIRING	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired
Ambient Temperature	°F	20	50	59	90	-14.2	-14.2	20	50	59	90	100	100	100	-14.2	-14.2	50
Ambient Pressure	psia	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3
Ambient Relative Humidity	%	60	60	60	60	20	20	60	60	60	60	40	40	40	20	20	60
PLANT STATUS																	
HRSG Duct Burner		Fired	Fired	Fired	Fired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired	Unfired
SCR		Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating	Operating
CO Catalyst		Operating Off	Operating Off	Operating Off	Operating Off	Operating Off	Operating Off	Operating Off	Operating Off	Operating Off	Operating On	Operating On	Operating Off	Operating Off	Operating Off	Operating Off	Operating Off
Evaporative Cooler state (On or Off) Gas Turbine Load	%	BASE	BASE	BASE	BASE	BASE	50%	BASE	BASE	BASE	BASE	BASE	BASE	50%	BASE	75%	75%
Gas Turbines Operating	,,	2	2	2	2	2	2	2	2	2	2	2	2	2	1	2	2
GT Diluent Injection Type		None	None	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water
GT Diluent Injection Flow (per GT)	10^3 lb/hr	0	0	0	0	167.1	82.9	171.2	172.5	168.5	143.8	143.2	138.3	65.8	167.1	123.5	120.8
FUEL DATA																	
Fuel Type	PTII/Ib	NG 22808.87948	NG 22808.87948	NG 22808.87948	NG 22808.87948	DO	DO	DO	DO	DO	DO	DO	DO	DO	DO	DO	DO
HHV LHV	BTU/lb BTU/lb	22808.87948	20571	20571	22808.87948	19398 18300	19398 18300	19398 18300	19398 18300	19398 18300	19398 18300	19398 18300	19398 18300	19398 18300	19398 18300	19398 18300	19398 18300
Fuel Mol. Wt.	lb/mole	16.8257	16.8257	16.8257	16.8257	138.2500	138.2500	138.2500	138.2500	138.2500	138.2500	138.2500	138.2500	138.2500	138.2500	138.2500	138.2500
Fuel Bound Nitrogen	Wt %	0	0	0	0	≤ 0.015%	≤ 0.015%	≤ 0.015%	≤ 0.015%	≤ 0.015%	≤ 0.015%	≤ 0.015%	≤ 0.015%	≤ 0.015%	≤ 0.015%	≤ 0.015%	≤ 0.015%
Fuel Sulfur Content	grains/100 SCF @ 60°	F 0.5	0.5	0.5	0.5	3.83	3.83	3.83	3.83	3.83	3.83	3.83	3.83	3.83	3.83	3.83	3.83
HRSG DATA (PER UNIT)																	,
HRSG EXIT EXHAUST GAS																	
Composition: Ar	mol %	0.8882	0.8884	0.8784	0.8666	0.8501	0.8700	0.8500	0.8499	0.8400	0.8300	0.8300	0.8399	0.8499	0.8700	0.8600	0.8500
CO2	mol %	4.3076	4.3101	4.3094	4.4582	5.6606	5.4200	5.6000	5.5194	5.5000	5.4200	5.4200	5.3895	5.3295	5.0900	5.6600	5.5600
H2O	mol %	8.5450	9.0605	9.3381	11.4473	10.6211	9.1400	10.9100	11.4089	11.6200	13.0800	13.0900	12.6287	11.2789	9.1700	10.2000	10.8500
N2	mol %	74.6383	74.2401	74.0234	72.4874	71.7772	72.8500	71.5300	71.1029	70.9400	69.7700	69.7600	70.1130	71.1429	72.7000	72.1100	71.5600
O2	mol %	11.6209 28.4175	11.5009 28.3616	11.4508 28.3306	10.7404 28.1138	11.0911 28.4008	11.7200	11.1100 28.3629	11.1189	11.1000 28.2744	10.9000 28.1064	10.9000 28.1054	11.0289 28.1530	11.3989 28.2943	12.1700 28.4999	11.1700	11.1800 28.3653
Molecular weight		28.41/5	28.3010	28.3300	28.1138	28.4008	28.5378	28.3029	28.3005	28.2744	28.1004	28.1054	28.1530	28.2943	28.4999	28.4471	28.3033
Temperature	°F	181	179	178	187	304	270	293	295	295	292	302	289	280	293	280	273
Mass Flow Actual Volume Flow	lb/hr Actual ft3/hr	4929300 83427000	4729900 79909000	4652400 78550000	4262100 73539000	4989600 100730000	3223500 61879000	4962300 98760000	4919300 98497000	4838400 96865000	4546500 91238000	4529700 92125000	4249400 84805000	2703800 53066000	4989600 98839000	4000500 78095000	3856700 74800000
HRSG EXIT EXHAUST GAS EMISSIONS																	
NOx	ppmvd @ 15% O2	2	2	2	2	5	5	5	5	5	5	5	5	5	5	5	5
NOX	lb/hr as NO2	20.3	19.5	19.2	18.4	52	32	51.2	50.1	49.2	45.8	45.6	42.6	26.6	46.5	41.7	39.5
СО	ppmvd @ 15% O2	1.7	1.7	1.7	1.7	2	2	2	2	2	2	2	2	2	2	2	2
со	lb/hr	10.5	10.1	9.93	9.5	12.7	7.79	12.5	12.2	12	11.2	11.1	10.4	6.48	11.3	10.1	9.62
VOC	ppmvd @ 15% O2	1.5	1.5	1.5	1.5	2	2	2	2	2	2	2	2	2	2	2	2
VOC	lb/hr as methane	4.98	4.8	4.72	4.51	6.19	3.98	6.16	6.12	6.03	5.7	5.68	5.32	3.37	6.19	4.95	4.79
CO2	lb/hr	329000	316000	311000	297000	438000	269000	431000	422000	414000	386000	384000	358000	224000	392000	350000	333000
NH3	ppmvd @ 15% O2	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
NH3	lb/hr	18.7	18	17.7	17	19.2	11.8	18.9	18.5	18.2	16.9	16.9	15.7	9.83	17.2	15.4	14.6
SOx Particulates - Filterable + Condensible,	lb/hr as SO2	4.752	4.584	4.512	4.308	4.92	3.036	4.848	4.752	4.656	4.344	4.32	4.032	2.52	4.92	3.948	3.744
Including Sulfates Sulfuric Acid Mist	lb/hr lb/hr	20.7 3.06	19.9 2.94	20 2.9	19.1 2.77	42.6 3.16	41.6 1.95	42.5 3.12	42.5 3.05	42.4 2.99	42.3 2.79	42.2 2.78	42.1 2.59	41.3 1.62	42.6 3.16	42 2.53	41.9 2.41
Sanarie Adia Wilst	/111	5.00	2.57	2.5	2.//	3.10	1.55	J.12	3.03	2.33	2.73	2.70	2.33	1.02	5.10	2.33	2.71

The notes page is an integral part of this document and must be reviewed prior to use of this data.

CPV Towantic

Оg	E Energy Cycle Systems		
Combined	Cycle Systems	Emissions	Estimates

OPERATING POINT		49	50	51	52	53
Case Description		Unfired	Unfired	Unfired	Unfired	Unfired
SITE CONDITIONS	0.5	=0		400	=0	=0
Ambient Temperature	°F	50 14.3	100 14.3	100 14.3	59 14.3	59 14.3
Ambient Pressure	psia		14.3 40	14.3 40		
Ambient Relative Humidity	%	60	40	40	60	60
PLANT STATUS						
HRSG Duct Burner		Unfired	Unfired	Unfired	Unfired	Unfired
SCR		Operating	Operating	Operating	Operating	Operating
CO Catalyst		Operating	Operating	Operating	Operating	Operating
Evaporative Cooler state (On or Off)		Off	Off	Off	Off	Off
Gas Turbine Load	%	50%	BASE	75%	75%	50%
Gas Turbines Operating		2	1	2	2	2
GT Diluent Injection Type		Water	Water	Water	Water	Water
GT Diluent Injection Flow (per GT)	10^3 lb/hr	83.8	138.3	98.6	118.7	81.4
FUEL DATA						
Fuel Type		DO	DO	DO	DO	DO
HHV	BTU/lb	19398	19398	19398	19398	19398
LHV	BTU/lb	18300	18300	18300	18300	18300
Fuel Mol. Wt.	lb/mole	138.2500	138.2500	138.2500	138.2500	138.2500
Fuel Bound Nitrogen	Wt %	≤ 0.015%	≤ 0.015%	≤ 0.015%	≤ 0.015%	≤ 0.015%
Fuel Sulfur Content	grains/100 SCF @ 60°F	3.83	3.83	3.83	3.83	3.83
HRSG DATA (PER UNIT)						
HRSG EXIT EXHAUST GAS						
Composition:	mol %	0.8599	0.8399	0.8401	0.8500	0.8601
CO2	mol %	5.5694	5.3895	5.4405	5.5400	5.5506
H2O	mol %	10.3390	12.6287	12.1112	11.0600	10.5211
N2	mol %	71.9628	70.1130	70.5371	71.3900	71.8172
02	mol %	11.2689	11.0289	11.0711	11.1600	11.2511
Molecular weight		28.4226	28.1530	28.2146	28.3403	28.4007
· ·						
Temperature	°F	269	278	279	272	268
Mass Flow	lb/hr	2982000	4249400	3398900	3810500	2937900
Actual Volume Flow	Actual ft3/hr	57365000	83502000	66779000	73868000	56521000
HRSG EXIT EXHAUST GAS EMISSIONS						
NOx	ppmvd @ 15% O2	5	5	5	5	5
NOx	lb/hr as NO2	30.6	42.6	34.3	38.9	30
CO	ppmvd @ 15% O2	2	2	2	2	2
co	lb/hr	7.44	10.4	8.34	9.48	7.31
	•					
VOC	ppmvd @ 15% O2	2	2	2	2	2
VOC	lb/hr as methane	3.7	5.32	4.24	4.74	3.64
CO2	lb/hr	257000	358000	288000	328000	253000
NH3	ppmvd @ 15% O2	5	5	5	5	5
NH3	lb/hr	11.3	15.7	12.7	14.4	11.1
SOx	lb/hr as SO2	2.892	4.032	3.24	3.684	2.844
Particulates - Filterable + Condensible, Including Sulfates	lb/hr	41.5	42.1	41.7	41.9	41.5
Sulfuric Acid Mist	lb/hr	1.86	2.59	2.09	2.37	1.83

The notes page is an integral part of this document and must be reviewed prior to use of this data.

Spec. No. T218

Heat Balance data provided by GE has been removed as confidential and proprietary information from the Permit Application for Stationary Sources of Air Pollution for the CPV Towantic Energy Center that GE considers to be trade secrets. 68 pages of heat balance data were provided with each page containing a header beginning with the letter "HB...." followed by additional descriptors. This information was provided to CPV Towantic, LLC by GE under the protection of a Non-Disclosure Agreement, and was inadvertently included in the application. These 68 pages contain sensitive and proprietary GE design information that has been removed from the submitted permit application. These 68 pages do not contain any air pollutant emissions data, and have been replaced by a replacement sheet identified as "CPV Towantic Unit Heat Consumption and Gross Power Output" (following this page).

The first 6 pages of Appendix B consists of GE-provided emission data identified as Drawing Number 240A2083. GE has expressly provided CPV Towantic, LLC permission to include the emissions data provided in the first 6 pages of Appendix B and the attached "CPV Towantic Unit Heat Consumption and Gross Power Output" replacement sheet. The contents of the 6 page drawing includes emissions data, exhaust data and operating data for the combustion turbines. These 6 pages plus the "CPV Towantic Unit Heat Consumption and Gross Power Output" replacement sheet provide all necessary technical data for evaluation of the permit application.

The GE confidential and proprietary information is being held by the Department and any requests to view this information should contact the Department at:

Office of Director; Engineering & Enforcement Division; Bureau of Air Management; Department of Energy and Environmental Protection; 79 Elm Street, 5th Floor; Hartford, Connecticut 06106-5127.

CPV TowanticUnit Heat Consumption and Gross Power Output

Ambient Temperature	°F	59	59	59
Ambient Relative Humidity	%	60	60	60
Fuel Type		NG	NG	DO
Gas Turbine Heat Consumption ¹	MMBTU/hr, HHV	2423.5	2423.5	2391.2
Duct Burner Heat Consumption ¹	MMBTU/hr, HHV	0.0	110.0	0.0
Gross CC Power Output	MW	777.5	804.9	702.3

¹ Heat consumption values are on a per turbine basis

GE Energy

GE COMPANY PROPRIETARY



1.0 INTRODUCTION

CB Nebraska Boiler & CB Natcom form the engineered boiler/burner division of the Cleaver-Brooks family of companies. We are committed to offering integrated boiler/burner solutions to the industry. This group of companies has been in this business for more than 80 years and continues to enjoy a large percentage of the market share. We maintain our leadership in the industrial watertube market by



offering innovative solutions and a true single-source responsibility to our customers for boilers, burners, controls & auxiliary equipment. This commitment to overall system design ensures that your equipment operates efficiently and lasts for years to come.

For your unique application, we are offering a packaged solution with the following design features:

1.1 OUTLET STEAM CONDITIONS:

Capacity: 77000 LB/HR ×

Operating Pressure: 200 PSIG (at exit of non-return valve) ×

Steam Temperature: Saturated at 387 °F Steam Quality: 99.5% dry steam ×

1.2 BOILER DESIGN:

Type: D-Type Industrial Watertube

Model: NB-300D-70 Vessel Design Pressure: 250 psig

1.3 BURNER DESIGN:

Type: Ultra Low-NOx Register

Main Fuel: Natural Gas Emissions: 9 PPM Nox

1.4 ECONOMIZER DESIGN:

Type: Rectangular Finned-Tube

Arrangement: Vertical Gas Flow; Counter-Current Water Flow

Design Pressure: 300 psig Inlet Feedwater Temp: 228°F

1.5 STACK DESIGN:

Type: Freestanding

Diameter (at exit): 78" Height (from grade): 125 ft



6940 Comhusker Highway Lincoln, NE 68507 402.434.2000 cleaverbrooks.com

"Standard" Burner Emissions Values (in lb/mmbtu)

	Natural Gas	#2 Oil	#6 Oil
NOx	0.100	0.120 ¹	0.440^{2}
CO	0.037	0.077	0.077
SO_2^*	0.006	0.052	0.540
VOC	0.004	0.005	0.006
PM_{10}	0.007	0.050	0.100

"Low-NOx" Burner Emissions Values (in lb/mmbtu)

	Natural Gas	#2 Oil	#6 Oil
NOx	0.036	0.100^{1}	0.380^{2}
CO	0.037	0.077	0.077
SO_2^*	0.006	0.052	0.540
VOC	0.004	0.005	0.005
PM_{10}	0.007	0.050	0.100

"Ultra Low-NOx" Burner Emissions Values (in lb/mmbtu)

	Natural Gas	#2 Oil	#6 Oil
NOx	0.011	0.100 ¹	NA
CO	0.037	0.077	NA
SO_2^*	0.006	0.052	NA
VOC	0.004	0.005	NA
PM_{10}	0.007	0.050	NA

¹ Based on a fuel-bound Nitrogen content not exceeding 0.02% (by weight).

The above values are based on industry averages and may or may not represent requirements for any given region of the United States. Emissions regulations vary from state-to-state.

² Based on a fuel-bound Nitrogen content <u>not exceeding</u> 0.40% (by weight).

^{**}Based on a sulfur content <u>not exceeding</u> 0.2 grains of Sulfur per 100 CUFT of natural gas OR 0.5% (by weight) for fuel oils. Sulfur emissions are not burner-dependent.



3.0 BOILER DESIGN DATA

Boiler Dimensions:		Units
Height to Main Steam Outlet	14 Ft 7 In	FT
Overall Width of Unit	11 Ft 7.5 In	FT
Overall Length of Unit*	25.33 Ft.	FT
*Add approximately 6-8 ft length for burner.		
Weight of Unit (Dry)	80,249.49	LBS
Weight of Unit (Wet)	102,381.53	LBS
Surface Area / Volume:		Units
Furnace Volume	1,379	FT3
Furnace Projected Area	819	FT2
Evaporator Area	4,277	FT2
Total Area	5,096	FT2
Economizer Area	13,317	FT2
Superheater Area	-	FT2
Tubing Data:		Units
Tube OD	2.0	IN
Tube Wall Thickness – Furnace Section	0.105	IN
Tube Wall Thickness – Convection Section	0.105	IN
Tube Material	SA178A	
Corrosion Allowance	NA	IN
Steam Drum:		Units
Inside Drum Diameter:	42 In	IN
Drum Length	25.33 Ft. Seam/Seam	FT
Drum Material:	SA516 Grade 70	
Corrosion Allowance:	NA	IN
Water Drum:		Units
Drum Diameter:	24 In	IN
Drum Length	25.33 Ft. Seam/Seam	FT
Drum Material:	SA106 Grade B	
Corrosion Allowance:	NA	IN
Standard Drum Connections:	Quantity	Type
Main Steam Outlet:	One	Flanged
Safety Valves:	Per ASME Code	Flanged
Feedwater Inlet:	One	Flanged
Bottom Drum Blowoff:	Two	Flanged
Water Column:	Two	Threaded
		(NPT)
Feedwater Regulator:	Two	Flanged
Vent:	One	NPT
Continuous Blowdown:	One	NPT
Chemical Feed:	One	NPT
Sootblower:	Two	Flanged
Auxiliary L.W. Cutouts:	One	NPT
,		

^{*}The above information is preliminary and shall be confirmed at time of engineering submittal.

NO. 24679-N Page 12 10-22-2009



4.0 BOILER PERFORMANCE DATA

Fuel: Natural Gas

Boiler load - %	100%	75%	50%	25%	Units
Steam Flow - ¤	77,000	57,750	38,500	19,250	Lb/Hr
Steam Pressure – Operating - ¤	200.0	200.0	200.0	200.0	PSIG
Steam Temperature - ¤	387.0	387.0	387.0	387.0	°F
Fuel Input (HHV)	92.4	69.1	46.0	23.2	MMBTU/Hr
Ambient Air Temperature	80.0	80.0	80.0	80.0	°F
Relative Humidity	60	60	60	60	%
Excess Air	25	25	25	25	%
Flue Gas Recirculation	25	25	25	25	%
Steam Output Duty	77	58	39	19	MMBTU/hr
Heat Release Rate	67,012	50,097	33,366	16,805	BTU/FT3-Hr
Heat Release Rate	112,882	84,389	56,204	28,308	BTU/FT2-Hr
Deaerator Pegging Steam	-	ı	-	ı	Lb/Hr
Feed Water Temperature	227	227	227	227	°F
Water Temp. Leaving Economizer	321	309	297	288	±10°F
Blow Down	1.0	1.0	1.0	1.0	%
Boiler Gas Exit Temperature	543	498	451	409	±10°F
Economizer Gas Exit Temp.	299	282	266	251	±10°F
Air Flow	84,454	63,137	42,050	21,179	Lb/Hr
Flue Gas to Stack	88,692	66,305	44,160	22,241	Lb/Hr
Flue Gas Including FGR	110,865	82,881	55,200	27,802	Lb/Hr
Fuel Flow	4,237	3,167	2,109	1,062	Lb/Hr
Flue Gas Losses/Efficiency-%					
Dry Gas Loss	4.5	4.2	3.8	3.5	%
Air Moisture Loss	0.1	0.1	0.1	0.1	%
Fuel Moisture Loss	10.6	10.6	10.5	10.4	%
Casing Loss	0.5	0.7	1.0	2.0	%
Margin	0.5	0.5	0.5	0.5	%
Efficiency - LHV	92.8	93.1	93.2	92.5	%
Efficiency – HHV - ¤	83.7	84.0	84.1	83.5	%
Total Pressure Drop Including					
Economizer	9.46	5.30	2.35	0.56	IN WC
Products of Combustion - CO2	7.7	7.7	7.7	7.7	%
- H2O	16.9	16.9	16.9	16.9	%
-N2	71.7	71.7	71.7	71.7	%
-02	3.8	3.8	3.8	3.8	%
-S02	-	-	-	-	%
GAS- % volume	NG				
methane	90.00				
ethane	5.00				
nitrogen	5.00				
LHV-Btu/lb	19,687				
HHV-Btu/lb	21,815				

^{*}The above information is preliminary and shall be confirmed at time of engineering submittal.

NO. 24679-N Page 13 10-22-2009

Diesel Generator Set





Image shown may not reflect actual package

Standby 1500 ekW 1875 kVA 60 Hz 1800 rpm 480 Volts

Caterpillar is leading the power generation Market place with Power Solutions engineered to deliver unmatched flexibility, expandability, reliability, and cost-effectiveness.

FUEL/EMISSIONS STRATEGY

 EPA Certified for Stationary Emergency Application (EPA Tier 2 emissions levels)

DESIGN CRITERIA

 The generator set accepts 100% rated load in one step per NFPA 110 and meets ISO 8528-5 transient response.

UL 2200

 UL 2200 packages available. Certain restrictions may apply. Consult with your Cat dealer.

FULL RANGE OF ATTACHMENTS

- Wide range of bolt-on system expansion attachments, factory designed and tested
- Flexible packaging options for easy and cost effective installation

SINGLE-SOURCE SUPPLIER

 Fully prototype tested with certified torsional vibration analysis available

WORLDWIDE PRODUCT SUPPORT

- Cat[®] dealers provide extensive post sale support including maintenance and repair agreements
- Cat dealers have over 1,800 dealer branch stores operating in 200 countries.
- The Cat[®] SOS[™] program effectively detects internal engine component condition, even the presence of unwanted fluids and combustion by products.

CAT 3512C ATAAC DIESEL ENGINE

- Reliable, rugged, durable design
- Field proven in thousands of applications worldwide
- Four-stroke diesel engine combines consistent performance and excellent fuel economy with minimum weight

CAT GENERATOR

- Matched to the performance and output characteristics of Caterpillar engines
- Single point access to accessory connections
- UL 1446 Recognized Class H insulation

CAT EMCP 4 CONTROL PANELS

- Simple user friendly interface and navigation
- Scalable system to meet a wide range of customer needs
- Integrated Control System and Communications Gateway

STANDBY 1500 ekW 1875 kVA

60 Hz 1800 rpm 480 Volts



Factory Installed Standard & Optional Equipment

System	Standard	Optional
Air Inlet	Single element canister type air cleaner with service indicator	[] Dual element air cleaners
Cooling	Package mounted radiator	
Exhaust	Exhaust flange outlet	[] Mufflers
Fuel	Secondary fuel filters Fuel cooler Fuel priming pump	
Generator	Matched to the performance and output characteristics of Cat engines	[] Oversize & premium generators [] Permanent magnet excitation (PMG) [] Internal excitation (IE) [] Winding temperature detectors [] Anti-condensation space heaters
Power Termination	Bus bar	[] Circuit breakers, UL listed [] Bottom cable entry [] Right, left, and/or rear power termination
Governor	• ADEM™ A3	[] Load share module
Control Panel	• EMCP 4	 [] EMCP 4.2 [] EMCP 4.3 [] EMCP 4.4 [] Local & remote annunciator modules [] Digital I/O Module [] Generator temperature monitoring & protection
Mounting		[] Spring type vibration isolator [] IBC 2006 seismic certification
Starting / Charging	24 volt starting motor(s) Batteries with rack and cables Battery disconnect switch	 [] Battery chargers (10 & 20 Amp) [] 45A charging alternator [] Oversize batteries [] Ether starting aids [] Heavy duty starting motors [] Barring device (manual) [] Air starting motor with control & silencer [] Jacket water heater
General	Paint – Caterpillar Yellow except rails and radiators gloss black	[] UL 2200 listed [] CSA Certification
	gioco bidoit	[] Sort Sortmodulori

STANDBY 1500 ekW 1875 kVA

60 Hz 1800 rpm 480 Volts



SPECIFICATIONS

CAT GENERATOR

Frame	1447
Excitation	PM
Pitch	0.6667
Number of poles	4
Number of leads	
Number of bearings	Single Bearing
Insulation	Class H
IP rating	Drip proof IP23
Over speed capability - % of rated	125%
Wave form deviation	2 %
Voltage regulator	3 phase sensing
Voltage regulationLess than ±1/29	% (steady state)
Less than +1/2% (3%	speed change)

CAT DIESEL ENGINE

3512C ATAAC, V-16, 4 stroke, water-cooled diesel

170.00 mm (6.69 in)
190.00 mm (7.48in)
51.80 (3161.03 in ³)
14.7:1
TA
Electronic unit injection
ADEM™ A3

CAT EMCP 4 CONTROL PANELS

EMCP 4 controls including:

- Run / Auto / Stop Control
- Speed & Voltage Adjust
- Engine Cycle Crank
- Emergency stop pushbutton

EMCP 4.2 controller features:

- 24-volt DC operation
- Environmental sealed front face
- Text alarm/event descriptions

Digital indication for:

- RPM
- DC volts
- Operating hours
- Oil pressure (psi, kPa or bar)
- Coolant temperature
- Volts (L-L & L-N), frequency (Hz)
- Amps (per phase & average)
- Power Factor (per phase & average)
- kW (per phase, average & percent)
- kVA (per phase, average & percent)
- kVAr (per phase, average & percent)
- kW-hr & kVAr-hr (total)

Warning/shutdown with common LED indication of shutdowns for:

- Low oil pressure
- High coolant temperature
- Overspeed
- Emergency stop
- Failure to start (overcrank)
- Low coolant temperature
- Low coolant level

Programmable protective relaying functions:

- Generator phase sequence
- Over/Under voltage (27/59)
- Over/Under Frequency (81 o/u)
- Reverse Power (kW) (32)
- Reverse Reactive Power (kVAr) (32RV)
- Overcurrent (50/51)

Communications

- Customer data link (Modbus RTU)
- Accessory module data link
- Serial annunciator module data link
- 6 programmable digital inputs
- 4 programmable relay outputs (Form A)
- 2 programmable relay outputs (Form C)
- 2 programmable digital outputs

Compatible with the following optional modules:

- Digital I/O module
- Local Annunciator
- Remote annunciator
- RTD module
- Thermocouple module

STANDBY 1500 ekW 1875 kVA

60 Hz 1800 rpm 480 Volts **Technical Data**



Open Generator Set - 1800 rpm/60 Hz/480 Volts		
EPA Certified for Stationar Emergency Applications		
(EPA Tier 2 emissions levels)		
Generator Set Package Performance		
Genset Power rating @ 0.8 pf	1875 kVA	
Genset Power Rating with fan	1500 ekW	
Fuel Consumption		
100% Load with fan	396.0 L/hr	104.6 Gal/hr
75% Load with fan	310.5 L/hr	82.0 Gal/hr
50% Load with fan	219.8 L/hr	58.1 Gal/hr
Cooling System ¹		
Air flow restriction (system)	0.12 kPa	0.48 in. water
Air flow (max @ rated speed for radiator arrangement)	2075 m3/min	73278 cfm
Engine coolant capacity with radiator	390.8 L	103.2 gal
Engine coolant capacity	156.8 L	41.4 gal
Radiator coolant capacity	234.0 L	61.8 gal
Inlet Air		
Combustion air inlet flow rate	129.4 m³/min	4569.7 cfm
Exhaust System		
Exhaust stack gas temperature (engine out)	403.9 °C	759.0 °F
Exhaust gas flow rate	308.9 mm ³ /min	10908.7 cfm
Exhaust flange size (internal diameter)	203.2 mm	8.0 in
Exhaust system backpressure (maximum allowable)	6.7 kPa	26.9 in water
Heat Rejection		
Heat rejection to cooolant (total)	616 kW	35032 Btu/min
Heat rejection to exhaust (total)	1322 kW	75182 Btu/min
Heat rejection to aftercooler	481 kW	27354 Btu/min
Heat rejection to atmosphere from engine	124 kW	7052 Btu/min
Heat rejection to atmosphere from generator	74 kW	3141 Btu/min
Alternator ²		
Motor starting capabiliy @30% voltage dip	4350 skVA	
Frame	1447	
Temperature Rise	150 °C	270 °F
Lube System		
Sump refil with filter	310.4 L	82 gal
Emissions (Nominal) ³		Ü
NOx g/hp-hr	4.08 g/hp-hr	
CO g/hp-hr	0.44 g/hp-hr	
HC g/hp-hr	0.11 g/hp-hr	
PM g/hp-hr	0.03 g/hp-hr	

¹ For ambient and altitude capabilities consult your Cat dealer. Air flow restriction (system) is added to existing restriction from factory.

² Generator temperature rise is basd on a 40 degree C ambient per NEMA M G1-32. UL 2200 Listed ppackages may have oversized generators with a different temperature rise and motor starting characteristics.

³ Emissions data measurement procedures are consistent with those described in EPA CFR 40 Part 89, Subpart D & E and ISO8178-1for measuring HC, CO, PM, NOx.

Data shown is based on steady state operating conditions of 77°F, 28.42 in HG and number 2 diesel fuel with 35°API and LHV of 18,390 btu/lb. The nominal emissions data shown is subject to instrumentation, measurement, facility and engine to engine variations. Emissions data is based on 100%load and thus cannot be used to compare to EPA regulations which use values based on a weighted cycle. Emissions values are tailpipe out with aftertreatment installed. Values shown as zero may be greater than zero but were below the detection level of the equipment used at the time of measurement.

PERFORMANCE DATA[DM8260]

Performance Number: DM8260 Change Level: 03

SALES MODEL: 3512C COMBUSTION: DI ENGINE SPEED (RPM): ENGINE POWER (BHP): 2,206 1,800 GEN POWER WITH FAN (EKW): 1,500.0 COMPRESSION RATIO: FAN POWER (HP): 88.5 RATING LEVEL: STANDBY ASPIRATION: TA PUMP QUANTITY: AFTERCOOLER TYPE: ATAAC FUEL TYPE: DIESEL AFTERCOOLER CIRCUIT TYPE: JW+OC, ATAAC MANIFOLD TYPE: DRY INLET MANIFOLD AIR TEMP (F): GOVERNOR TYPE: ADEM3 JACKET WATER TEMP (F): 210.2 **ELECTRONICS TYPE:** ADEM3 TURBO CONFIGURATION: PARALLEL **CAMSHAFT TYPE:** STANDARD TURBO QUANTITY:

 CAMSHAFT TYPE:
 STANDARD
 TURBO QUANTITY:
 4

 IGNITION TYPE:
 CI
 TURBOCHARGER MODEL:
 GTB4708BN-52T-0.96

 INJECTOR TYPE:
 EUI
 CERTIFICATION YEAR:
 2006

| THE CONTROL | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 | 2000 |

INDUSTRY	SUBINDUSTRY	APPLICATION
ELECTRIC POWER	STANDARD	PACKAGED GENSET
OIL AND GAS	LAND PRODUCTION	PACKAGED GENSET

General Performance Data

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	BRAKE MEAN EFF PRES (BMEP)	BRAKE SPEC FUEL CONSUMPTN (BSFC)	VOL FUEL CONSUMPTN (VFC)	INLET MFLD PRES	INLET MFLD TEMP	EXH MFLD TEMP	EXH MFLD PRES	ENGINE OUTLET TEMP
EKW	%	BHP	PSI	LB/BHP-HR	GAL/HR	IN-HG	DEG F	DEG F	IN-HG	DEG F
1,500.0	100	2,206	307	0.332	104.6	77.5	120.9	1,145.6	74.6	759.0
1,350.0	90	1,983	276	0.336	95.2	72.2	116.1	1,102.7	68.8	726.8
1,200.0	80	1,768	246	0.343	86.6	66.9	113.2	1,069.1	63.1	708.7
1,125.0	75	1,662	232	0.346	82.0	63.4	111.5	1,052.3	59.5	700.6
1,050.0	70	1,556	217	0.348	77.4	59.7	109.8	1,035.3	55.8	693.6
900.0	60	1,349	188	0.352	67.9	51.1	107.1	1,000.5	47.6	682.5
750.0	50	1,144	159	0.355	58.1	40.6	107.5	963.7	38.4	686.4
600.0	40	940	131	0.359	48.2	30.0	108.4	921.9	29.4	686.0
450.0	30	736	103	0.368	38.6	20.9	107.1	856.1	21.9	667.6
375.0	25	632	88	0.376	33.9	16.9	106.2	809.6	18.8	648.1
300.0	20	527	73	0.388	29.2	13.3	105.2	754.6	16.0	621.1
150.0	10	312	43	0.443	19.7	7.3	103.2	609.7	11.4	526.2

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	COMPRESSOR OUTLET PRES	COMPRESSOR OUTLET TEMP	WET INLET AIR VOL FLOW RATE	ENGINE OUTLET WET EXH GAS VOL FLOW RATE	WET INLET AIR MASS FLOW RATE	WET EXH GAS MASS FLOW RATE	WET EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)	DRY EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)
EKW	%	BHP	IN-HG	DEG F	CFM	CFM	LB/HR	LB/HR	FT3/MIN	FT3/MIN
1,500.0	100	2,206	82	449.8	4,570.7	10,909.2	20,179.4	20,912.0	4,401.2	3,984.7
1,350.0	90	1,983	77	428.8	4,387.3	10,167.0	19,354.1	20,020.6	4,213.1	3,825.4
1,200.0	80	1,768	71	409.0	4,190.2	9,533.7	18,456.0	19,062.3	4,012.0	3,655.5
1,125.0	75	1,662	68	396.6	4,062.8	9,156.1	17,861.1	18,435.5	3,879.9	3,539.6
1,050.0	70	1,556	64	382.7	3,917.6	8,750.8	17,185.6	17,727.5	3,730.8	3,407.5
900.0	60	1,349	55	350.3	3,576.3	7,863.4	15,607.1	16,082.3	3,384.9	3,097.2
750.0	50	1,144	44	309.9	3,132.5	6,856.9	13,608.7	14,015.1	2,941.7	2,693.8
600.0	40	940	33	266.6	2,669.6	5,821.5	11,547.1	11,884.6	2,498.4	2,290.8
450.0	30	736	23	224.6	2,255.4	4,830.1	9,719.1	9,989.4	2,106.6	1,937.5
375.0	25	632	19	204.3	2,072.0	4,354.9	8,915.9	9,153.2	1,932.9	1,782.3
300.0	20	527	15	184.3	1,901.9	3,888.6	8,175.8	8,380.0	1,769.0	1,636.5
150.0	10	312	9	148.8	1,629.0	3,012.8	6,991.2	7,129.2	1,502.5	1,404.3

Rating Specific Emissions Data - John Deere Power Systems



Nameplate Rating Information

Clarke Model
Power Rating (BHP / kW)
Certified Speed (RPM)

JW6H-UFADJ0				
350 / 261				
1760				

Rating Data

Rating			6090HFC47A	
Certified Pow	Certified Power (kW)		315	
Rated Sp	eed		1760	
Vehicle Model	Number		Clarke Fire	Pump
Units	g/kW-h	r	g/hp-hr	
NOx	3.5		2.6	
HC	0.1		0.1	
NOx + HC	3.7		2.7	
Pm	0.14		0.11	
СО	0.9		0.7	

Certificate Data

Engine Model Year	2014
EPA Family Name	EJDXL09.0114
EPA JD Name	450HAB
EPA Certificate Number	EJDXL09.0114-013
CARB Executive Order	Not Applicable
Parent of Family	6090HFG84A

Units	g/kW-hr
NOx	3.8
HC	0.1
NOx + HC	3.9
Pm	0.13
CO	0.9

^{*} The emission data listed is measured from a laboratory test engine according to the test procedures of 40 CFR 89 or 40 CFR 1039, as applicable. The test engine is intended to represent nominal production hardware, and we do not guarantee that every production engine will have identical test results. The family parent data represents multiple ratings and this data may have been collected at a different engine speed and load. Emission results may vary due to engine manufacturing tolerances, engine operating conditions, fuels used, or other conditions beyond our control.

This information is property of Deere & Company. It is provided solely for the purpose of obtaining certification or permits of Deere powered equipment. Unauthorized distribution of this information is prohibited